

Severity

High

Analysis Summary

CVE-2022-21934

Johnson Controls Metasys could allow a remote authenticated attacker to bypass security restrictions, caused by an unspecified flaw. By sending a specially-crafted request, an attacker could exploit this vulnerability to lock other users out of the system and take over accounts.

Impact

- Security Bypass

Indicators Of Compromise

CVE

- CVE-2022-21934

Affected Vendors

- Johnson Controls

Affected Products

- Johnson Controls Metasys 10
- Johnson Controls Metasys 11

Remediation

Refer to Johnson Controls for patch, upgrade or suggested workaround information.

[Johnson Controls](#)