

## Severity

High

## Analysis Summary

CVE-2021-41545

Siemens Desigo products are vulnerable to a denial of service, caused by an uncaught exception in the BACnet communication function implementation. By sending a specially-crafted BACnet protocol packet, a remote attacker could exploit this vulnerability to cause a denial of service.

## Impact

- Denial of Service

## Indicators Of Compromise

CVE

- CVE-2021-41545

## Affected Vendors

- Siemens

## Affected Products

- Siemens Desigo DXR2
- Siemens Desigo PXC3
- Siemens Desigo PXC4
- Siemens Desigo PXC5

## Remediation

Refer to Siemens Security Advisory for patch, upgrade or suggested workaround information

[Siemens Security Advisory](#)