Area Classification AC-SR1: Solvent Room

Per IS/IEC 60079-10-1 · Rev 1 · 2023 · FICTIONAL DEMO DOCUMENT

2. Classification

The solvent room is classified Zone 1, gas group IIB, temperature class T4 (toluene). All electrical equipment installed in the room must carry a valid Ex certificate for Zone 1, gas group IIB or IIC, and temperature class T4 or cooler (T5, T6).

3. Mechanical equipment (plant standard PS-MECH-11)

Fans handling the room atmosphere shall have spark-resistant impellers (aluminium, bronze or other non-sparking material). Mild-steel impellers are not permitted.