SOP-R201-07: Reactor R-201 Batch Hold and Utility Interruptions

Rev 4 · Approved by Plant Head · Effective 01-Jun-2024 · FICTIONAL DEMO DOCUMENT

3. Batch hold

During batch hold the reactor contents must stay between 55 °C and 65 °C. The jacket is heated with steam from Boiler B-1 under TIC-201 control.

4.1 Planned utility interruptions

No utility serving R-201 may be interrupted during batch hold without plant-head approval.

4.2 Boiler B-1 shutdown during batch hold

Boiler B-1 may be shut down for a maximum of 20 minutes while an R-201 batch is in hold. Beyond 20 minutes the batch cools below 55 °C and unreacted reagent starts to build up, which can run away when heating resumes. The operator shall monitor TI-201 every 5 minutes and restart B-1 before 20 minutes. If B-1 cannot be restarted, stop reagent dosing and inform the plant head immediately.