# SOP-SD1-03: Spray Dryer Alarm Management

Rev 2 · 2024 · FICTIONAL DEMO DOCUMENT

### *5.1 Alarm bypass*

Bypassing or muting TAH-301 is a change to a safety function. It requires a written bypass permit approved by the plant head, a named person watching inlet temperature locally, and must be removed before the next batch is charged.