

PaxScan® 3030CB / 4030CB

Systems & Service Guide



Abstract

The *PaxScan® 3030CB / 4030CB Systems & Service Guide* (P/N 20099) provides reference information and procedures for using the Varian PaxScan 3030CB / 4030CB digital imaging subsystem with a basic image processing workstation and communications interface software.

Technical Support

If you cannot find information in this user guide, you can contact us in several ways:

■ United States

Varian X-ray Products	+ 1 800 432 4422 Phone
1678 So. Pioneer Rd	+ 1 801 972 5000 Phone
Salt Lake City, Ut 84104	+ 1 801 973 5023 Fax

■ Europe

Varian X-Ray Products	+ 31 0 575 566 093 Phone
Zutphensestraat 160A	+ 31 0 575 566 538 Fax
6971 ET Brummen	
The Netherlands	

■ East Asia

Varian X-Ray Products	+ 81 03 5652 4711 Phone
4th MY ARK Nihonbashi Bldg.	+ 81 03 5652 4713 Fax
10-16 Tomizawa-cho	
Nihonbashi, Chuo-ku	
Tokyo 103-0006, Japan	

■ China

Varian X-Ray Products	+ 86 10 8518 2160 Phone
Oriental Plaza Tower W1, Suite 1004	+ 86 10 8518 2165 Fax
1 East Chang an Avenue	
Beijing 100738, P.R.China	

You can find more information about Varian Imaging Products on our Website:
<http://www.varian.com>. Click Products and then Imaging Products.

Notice

Information in this user guide is subject to change without notice and does not represent a commitment on the part of Varian to update information. Varian is not liable for errors contained in this guide or for any damages incurred in connection with furnishing or use of this material.

This document contains proprietary information protected by copyright. No part of this document may be reproduced, translated, or transmitted without the express written permission of Varian Medical Systems, Inc.

The PaxScan® 3030CB / 4030CB is a Class 1 system per the Standard for Medical Electrical Equipment, UL 60601-1. Classified by the Canadian Standard for Medical Electrical Equipment, C22.2, No. 601.1-M90.

CE Mark

Varian Medical Systems imaging products are designed and manufactured to meet the Low Voltage Directive 73/23/EEC and EMC 93/42/EEC. The product carries the CE mark through MDD compliance.

Trademarks

PaxScan®, and ViVA™ are trademarks of Varian Medical Systems, Inc. Microsoft® is a registered trademark and Windows™ is a trademark of Microsoft Corporation.

© 2008 Varian Medical Systems, Inc.
All rights reserved. Printed in the United States of America.

CHAPTER SUMMARY

Introduction	1
System Overview	2
Getting Started	3
Calibration Procedures	4
PaxScan Application Software	5
ViVA Help	6
System Configuration	7
Command Processor Hardware Specifications	8
Safety	9
Maintenance	10
Troubleshooting	11
Technical Support	12
Appendix A - Glossary of Terms	A
Appendix B- Command Processor and Computer Interface	B
Appendix C - Calibration Procedure for 3030CB / 4030CB High DR modes	C
Appendix D- Multiple Gain Ranging	D

CHAPTER 1	INTRODUCTION	11
CHAPTER 2	SYSTEM OVERVIEW	13
	Receptor.....	15
	Amorphous Silicon: Features and Benefits	16
	Properties of Amorphous Silicon.....	16
	Command Processor	18
	Offset and Gain Variations	19
	Internal Power Supply	19
	Modes of Operation	20
	Default Mode	21
	Image Processing	21
CHAPTER 3	GETTING STARTED.....	23
	Shipment Contents	23
	Connecting the Cables	24
	Mechanical Mounting	26
	Receptor Mounting	26
	Command Processor	26
	Power On Sequence	27
	Establishing Connection	28
	Basic Offset Calibration	28
	Basic Gain Calibration	29
	Image Acquisition	30
	Fluoroscopy - Normal	30
CHAPTER 4	CALIBRATION PROCEDURES	33
	Offset Calibration	34
	Gain Calibration	34
	Fluoroscopic Mode Gain Calibration	36
	Defective Pixel Maps	40
	Analog Offset Calibration	40
	Verification of Analog Offset Calibration	42
CHAPTER 5	PAXSCAN APPLICATION SOFTWARE	43
	Software Programming Interfaces	43
	Ethernet Interface and High Level Serial Interface	43
	Interface Files	44
	Initial Connection to the Command Processor	44
CHAPTER 6	ViVA Help	45
	Setup	46
	System Requirements	46
	Installation	46
	Version	46
	View Menu & User Interface	46
	Image Window Types	47
	Image Layout	48
	Full Overlay	48
	Status Bar	48
	Message Option	48
	Image Information	50
	Toolbars	51
	File Menu & Image Files	51
	Saving Images	51
	Opening Images	52
	Pixel Data Format & 3030CB / 4030CB Receptors	55
	Edit Menu & Preferences	56

Edit Toolbars & Image Manipulation	58
Cursor Functions	58
Mouse and Key Shortcuts	59
Context Menus	59
Window/Level Scroll	61
Auto & Invert W/L	61
Edit W/L Dialog	62
Acquisition Menu/Toolbar	65
Communication Link	65
Image Acquisition	66
Offset & Gain Calibration	67
Gain Ratio Calibration	68
Extended Gain Calibration	69
System Settings	70
Mode Settings	71
Rad AutoSave	73
Hardware Handshaking	73
Video Menu/Toolbar	74
Rad Modes	74
Recording Sequences	74
Playing Sequences	76
More Video Options: Video Menu	76
Analysis Menu: Image Statistics	79
ROI Basic	79
ROI Dialog	80
RoiList Commands	82
Tool Menu	83
Receptor	83
Command Processor	84
Defects	85
Image Operations	92
Cone Beam	95

CHAPTER 7	SYSTEM CONFIGURATION	97
	Configure Utility Application	97
	Usage	98
	Main Screen	99
	Receptor Configuration Settings	100
	Mode Selection	102
	Mode Setup	103
	System Configuration: Hostdown Utility Application	105
	System Configuration: ViVA Application	108

CHAPTER 8	COMMAND PROCESSOR HARDWARE SPECIFICATIONS	111
	Hardware Components	111
	Command Processor Hardware Configuration	112
	Motherboard	112
	PCU	112
	External Synchronization: Hardware Handshaking	112
	16-bit Video Output Signals	117
	Logic Levels	117
	Frame Timing	118
	User Synchronization Mode	123
	Pulsed X-ray Beam Applications	124
	Timing Information	124
	Internal Power Supply Specifications	124
	Control and Monitoring	125
	Mechanical Specifications	125
	Command Processor Specifications	126

CHAPTER 9	SAFETY	129
	Receptor Module	129
	Receptor Mounting.....	129
	Command Processor	130
	Rack Mounting the Command Processor	130
	Environmental Conditions	130
	Cooling Requirements	131
	Electro-Magnetic Compatibility	132
	Electro-Magnetic Interference	132
	Electrical Shock Protection	132
	X-Ray Leakage with Pb Barrier	132
	Safety Agency Approvals	133
CHAPTER 10	MAINTENANCE	135
	Preventative Maintenance	135
	Calibration Schedule	135
	Receptor Module	135
	Repairs	136
	Cleaning, Disinfection and Sterilization	136
CHAPTER 11	TROUBLESHOOTING	137
	HyperTerminal	137
	Problems and Solutions	139
CHAPTER 12	TECHNICAL SUPPORT.....	141
	How To Reach Us	141
	PaxScan 3030CB / 4030CB Problem Report	142

Figures

PaxScan 3030CB / 4030CB Digital Imaging Subsystem	11
PaxScan Imager Configuration	14
Internal Configuration of the Receptor	15
Sensor Structure	15
Offset and Gain Correction Algorithm	19
Command Processor I/O	24
ViVA - Open Ethernet Link	29
ViVA - Fluoroscopic Acquisition - Normal	30
ViVA - Retrieve Image	31
Selecting Fluoroscopic Mode Gain Calibration	36
Gain Calibration - Fluoroscopy	37
Gain Fluoro - Frame Accumulation	37
Offset Calibration: Dark Field Accumulation	38
Dark Field Accumulation in Progress	38
Imager Analyzing	39
Fluoroscopic Gain Calibration Complete	39
Analog Offset Settings	41
Analog Offset Calibration Progress	41
Ethernet and High Level Serial Interface Architecture	43
ViVA Screen View	47
Message Options	49
Image Information: Image Tab	50
Image Information: System Tab	50
Image Information: Video Tab	51
File Format: Any Specification Dialog	54
Preferences Dialog Box	56
Context Menu for Thumbview	60
Context Menu for Imageview (Normal Mode)	60
Context Menu for Imageview in Defect Map Editor Mode	60
Edit Window/Level Dialog	62
Gray Level Mappings for Linear, PseudoFilm and Atan/S-curve Functions	64
Gamma Curve Adjustment Dialog	64
Acquisition Menu	65
Acquisition Toolbar without link open	65
Acquisition Toolbar with link open	66
Image Info: User Input	66
Gain Calibration Dialog	68
Acquisition menu - dual read modes	68
Acquisition menu - dynamic gain modes	69
Extended Gain Calibration dialog	69
System Settings - No Link Open	70
System Settings - Link Open	71
Mode Settings - Fluoroscopy Modes	72
Mode Settings - Radiography Modes	72
Video Toolbar	77
Allocate Buffer Dialog Box	75

Video Menu	76
Sequence Subset Info	76
Set AVI Quality	77
Region of Interest Statistics Dialog Box	80
Analog Offset Settings	83
Defect Map Editor Screenshot	86
Defect Threshold Tool	89
Defect Map Conversion Warning	89
Find Noisy Pixels Dialog Box	90
Image Arithmetic Dialog	92
Pixel Editor Dialog	93
Optimize Auto Level Parameter Dialog	93
Extract from Image Information Dialog	95
Usage Dialog Box	98
Main Screen Dialog Box	99
Open Dialog Box	99
Receptor Configuration Settings	100
DCDS Line Length Dialog Box	102
Mode Selection Dialog Box	103
Mode Setup Dialog Box	103
Hostdown Main Screen	106
Auto Download File Set	107
ViVA Transmit Files Selection	109
Command Processor Hardware Interconnection	112
Generic Opto-Coupler Interface	113
Frame Timing	118
Vsync Timing Diagram	119
User Sync Fluoro Overall Timing	120
Detailed View of One Hsync and Data Valid	120
Full Resolution Overall Video Timing with User Sync	121
Full Resolution Detailed Video Timing	121
LVDS and CameraLink Connector Pin Assignments	122
LVDS Signal Termination Scheme	123
Timing for Systems with Pulsed X-ray Beam Delivery	124
Receptor	125
Command Processor	126
HyperTerminal Window	137
ViVA Window	137
Com Port Configuration	138

Tables

Command Processor Component Boards	18
PaxScan 4030CB Standard Modes	20
PaxScan 3030CB Standard Modes	21
Cable Connections	25
Power On Sequence	27
Basic Offset Calibration	29
Gain Calibration: All Modes	30
Gain Calibration: All Modes	36
Analog Gain Settings - Target Values and Tolerance	41
Cursors	58
Shortcut Key Combinations	59
Region of Interest Statistical Information	81
Receptor Settings Data Description	101
Mode Selections	104
System Configuration Software Package Files	105
Pin Assignments of the External Synchronization Port	113
Default Hardware Handshaking Interface	114
Default Hardware Handshaking Signals	115
Video Interface Signals	117
Typical LVDS Levels	117
Recommended LVDS Parts	118
PixClk Timing Specifications	119
Vsync/Hsync/Data Valid Timing Specifications	119
Frame Rate vs. Vertical Blank Time	123
Internal Power Supply Specification	125
Serial Port One (P1)	126
Serial Port Two (P2)	127
Ethernet Connector (P3)	127
Environmental Conditions	130
Troubleshooting	139

Figure 1-1 PaxScan 3030CB / 4030CB Digital Imaging Subsystem



Designed and manufactured by Varian Medical Systems, the PaxScan family of digital X-ray imagers uses amorphous silicon flat panel detectors (FPDs) for X-ray imaging. They are designed for incorporation into a complete X-ray system by a qualified equipment manufacturer.

The PaxScan 3030CB / 4030CB is the world's first 12"x16" multi-modality, digital X-ray flat panel imager for cone-beam medical imaging applications. It is available with a cesium iodide scintillator.

Each PaxScan 3030CB / 4030CB system comes complete with Windows®-based software for control of operating modes, real-time image acquisition, correction, transfer, off-line processing, and display.

PaxScan 3030CB / 4030CB imagers replace image intensifiers and TV cameras in fluoroscopic X-ray applications. There are many possible readout modes since the frame rate, sensitivity, field-of-view and resolution are all programmable. In a typical medical application, the 3030CB / 4030CB would be configured to have multiple fluoroscopy modes. The PaxScan 3030CB / 4030CB has the ability to switch between multiple imaging modes in real-time.

This manual describes the hardware, software and mechanical interfaces used in integrating the PaxScan 3030CB / 4030CB imager into a complete imaging system.

Chapter 2 System Overview

The PaxScan 3030CB / 4030CB is a real-time, fluoroscopic digital X-ray imaging subsystem incorporating a large area amorphous silicon TFT/photodiode sensor array with a cesium iodide scintillator.

The PaxScan 3030CB / 4030CB will acquire images at usual video frame rates over a wide range of dose. The 3030CB / 4030CB is designed for diagnostic X-ray tube energies ranging from 40 kVp to 150 kVp.

Designed as a subsystem, it cannot be used as a stand-alone device. It must be incorporated into a complete X-ray system by a qualified equipment manufacturer.

In This Chapter

Topic	Page
Receptor	2-15
Command Processor	2-18
Internal Power Supply	2-19
Modes of Operation	2-20



Important: The PaxScan 3030CB / 4030CB is designed for maximum access to the patient, with a minimum possible border on the active imaging area. No part of the PaxScan 3030CB / 4030CB is intended to be attached to a patient and/or to contact the patient.

The imaging system has three main components. The Receptor, which houses the solid-state, flat panel sensor; the Command Processor, and the Power Supply. The Command Processor is the interface between the Receptor and the imaging system.

In medical applications, the function of the Receptor is to absorb the X-rays that pass through the patient’s anatomy, and to convert those X-rays into a digital image.

The Command Processor and Power Supply will typically be mounted in an equipment enclosure and will not be in view or reach of the operator or patient. The Receptor is mounted into the OEM’s mounting structure, such as a C-Arm, and will often be completely covered by the mounting and a contrast-enhancing screen.

During operation, the C-Arm is often draped or bagged to ensure cleanliness and sterilization, and is manipulated such that the Receptor’s input window is located near, but on the opposite side of the patient, from the X-ray source.



Important: It is possible that during normal usage the Receptor could inadvertently contact the patient. The closeness of the Receptor to the patient is dependent upon the operator and the technique being performed.




Note: PaxScan imagers are intended for continuous use.

Figure 2-1 shows the configuration of the Receptor in the context of the overall imaging system. The Receptor measures 18 x 14 x 1.6 inches. The receptor thickness increases to 2.6 inches where the snap-on box is located.



Note: The Receptor can be located up to 40 meters from the Command Processor. A bi-directional fiber-optic link is used to pass all data and mode control signals to the Receptor. The 24V/3A power for the Receptor is provided on a separate copper cable with quick disconnect connectors.

Figure 2-1 PaxScan Imager Configuration



The imager operation is controlled using software commands via Ethernet, or one of Serial ports. The set of possible imager control operations is supplied to systems integrators in a C++ library of callable functions, in the form of a Win32 DLL. The communications interface is at the level of IP sockets. Control of the imager is platform-independent.



Note: The Command Processor has a set of I/O signals that can be used for hardware handshaking and synchronization of critical tasks.

The primary output of the Command Processor is corrected 16-bit digital video or standard camera link video. Raw data from the Receptor are corrected for offset and gain variations on a pixel-by-pixel basis.

The amorphous silicon panel has a finite number of dead pixels and lines, which are corrected in the Command Processor through interpolation of the nearest neighbors. The Command Processor also provides a recursive filter to smooth frame-to-frame noise.

The Power Supply provides all the DC power necessary for both the Command Processor and the Receptor. The Power Supply connects to any standard wall outlet and is connected to the Command Processor through a 50-pin D sub-miniature connector. The Command Processor and Power Supply each have a footprint of 10.2 x 11 inches, and when stacked for rack mounting occupy a height of 5.2 inches.

Receptor

The Receptor is based on amorphous silicon (a-Si) technology, which is very similar to that used in flat panel liquid crystal displays. Because X-rays cannot be easily focused, it is a requirement that the detector be as large as the area to be imaged.

The PaxScan 3030CB / 4030CB a-Si devices are fabricated onto a glass substrate in the same manner as TFTs in active matrix flat panel displays. The glass substrate is mounted on a base plate, which also holds the readout and drive electronics for the Receptor.


2



Note: In CCD-based systems, a large X-ray conversion screen emitting visible radiation is coupled to the camera through a mirror and lens. The drawback to such a system is the substantial loss in signal due to the relatively small solid angle in which light is collected. The larger the area to be imaged, the greater the loss


Varian's amorphous silicon panels allow optimal coupling between the X-ray conversion screen and the photo-detector.

Figure 2-2 Internal Configuration of the Receptor



The core of the detector is an array of amorphous silicon p-i-n photodiodes and thin film transistors (TFTs), which are arranged as shown below.

Figure 2-3 Sensor Structure



On top of the amorphous silicon (a-Si) array is an X-ray scintillator, which converts the X-ray photons to visible radiation. This scintillator is typically a thallium-doped Cesium Iodide deposited directly on the a-Si array. These X-ray conversion screens emit nearly 550 nm, which corresponds to the peak quantum efficiency of the photodiodes.

Amorphous Silicon: Features and Benefits

Amorphous silicon devices have been shown to be extremely radiation hard. This feature makes a-Si technology attractive for both diagnostic energy imaging (40 to 150 kVp) as well as mega voltage energy imaging, such as might be done in radiation therapy and high energy non-destructive test (NDT) applications, where the dose rate from the source typically exceeds 100 cGy/min.

Amorphous silicon devices have a number of additional features that make them well-suited to X-ray sensor applications:

- a-Si can be deposited over a large area onto glass substrates
- A low dark current of the pin diodes
- Wide dynamic range
- A low leakage current of a-Si TFT
- Capable of tolerating > 10,000 Gy (1Mrad) total dose in the active area.
- Can image a wide range of X-ray energies in diagnostic imaging and non-destructive test (NDT)
- Very low pixel-to-pixel crosstalk



Note: A typical dark current for the photodiodes is on the order of 2pA/mm². The OFF current of a TFT is less than 0.1pA for temperatures below 50°C. Such low dark currents equip the devices for use as charge integrating detectors, allowing frame rates on the order of many seconds per frame.

The large intrinsic dynamic range of the amorphous silicon pixel comes from the large charge capacity of the photodiodes. For a 194 μm pixel, the charge capacity is over 0.7 pF, which gives over 50 million electrons for a 5V reverse bias.

Properties of Amorphous Silicon

The same lack of long-range order in the amorphous silicon (a-Si) material that makes it radiation hard, also means that charge does not move easily in amorphous silicon. Since the electron mobility in a-Si is less than 1 cm²/V·sec, it is not practical to build extensive readout electronics into the a-Si plate.

As a consequence, every row and column connection must be brought out to the edge of the array where it is connected to conventional integrated circuits. This poses a number of unique challenges when compared to CCD or CMOS active pixel sensors where much of the sensitive readout electronics can be built into the detector.

The first challenge is simply the mechanical connection to the thousands of signals, which come out to the edge of the array. The second and more difficult challenge is that the architecture forces the readout circuit to operate in the presence of the large parasitic resistance and capacitance of the a-Si array. The dominant noise sources in the imager arise from these parasitics.

In the same way that the a-Si sensor technology is leveraging the huge investment that has been made in displays, the interconnect technology used in flat panel displays is also available for sensors. Typically, the row selection and readout electronics are put in TAB (tape automated bonding) packages. These flexible packages are heat sealed to a conductive landing pattern on the glass using a z-axis conducting epoxy. The chip is mounted somewhere in the middle of the package. At the other end of the package the signal traces are either soldered or heat sealed to a printed circuit board.



Note: The advantage of a TAB package over a simple flexible circuit interconnect, is the dramatic reduction in the number of pins required at the PCB end of the package.

The readout chips are heat sealed at the glass to 128 columns, where the landing pattern has a pitch of 100 μm . The readout chip multiplexes these 128 inputs down to one output, so on the PCB end of the package only 30 pins at a pitch of 20 thousandths of an inch are necessary to carry the power, control signals and output signal. Another advantage of the TAB package is that the electronics can be wrapped around to the side or the backside of the array, as shown in Figure 2-2 for one of the gate driver chips.

The top and bottom halves of the-Si array are read in parallel, a single row at a time progressively. The parallel scanning feature of the 3030CB / 4030CB is enabled by the use of split datalines and two sided readout electronics. This feature offers lower electronic noise, faster scanning and an increased time window for pulsed X-ray beam delivery.

Referring to Figure 2-3, the gate driver chips select which row in the image is accessed, by applying a positive voltage to a line of TFT gates. With the TFTs ON, charge collected on individual photodiodes in the selected row is then discharged onto the corresponding dataline. Each dataline is held at a constant potential by a charge integrating amplifier.



Note: In the PaxScan 3030CB / 4030CB, there are 1,536 rows and 2,048 columns at a pixel pitch of 194 μm ; therefore, 4,048 charge integrating amplifiers on an effective pitch less than 194 μm are required to readout the imager.

A second generation, custom 128-channel readout chip, the VENUS 4, has been designed in a BiCMOS process for this purpose. The VENUS chips capture the charge on each dataline, converting the signals to voltage levels, which are then multiplexed out to 14-bit analog-to-digital converters (ADCs).

To summarize the signal conversion chain:

- X-rays are converted to visible photons by the scintillator.
- The visible photons are absorbed by the pin photodiodes and converted to electron-hole pairs, which collect on the capacitance of the photodiodes.
- The pin photodiodes are discharged when the pixel's TFT is turned ON. The charge is collected by an integrating amplifier and converted to a voltage.
- The signal voltage has a programmable gain applied, dependent upon operating conditions.
- The output voltage is converted to digital data by an ADC.

Command Processor

The Command Processor provides all hardware and software interfaces for the PaxScan 3030CB / 4030CB. It consists of an embedded computer, image correction hardware, and external hardware interface connections.

Table 2-1 Command Processor Component Boards

Component Board	Description
CPU/Motherboard	<ul style="list-style-type: none">■ PM/PPC 440-based CPU board■ RJ-45 Ethernet port■ Two serial ports■ System DRAM■ Flash memory
Image Processor (IPCU)	<ul style="list-style-type: none">■ Hardware-based image correction■ Offset/gain correction■ Defective pixel correction■ Correlated line noise reduction■ Recursive filtering



Note: The software application, *Executive*, running on the CPU/Motherboard initializes all system components upon startup, handles all software interfaces (Ethernet, Serial), and interprets signals which arrive over the hardware interfaces. The *Executive* also handles frame-by-frame control of image acquisition and calibration. Real-time correction of images, on the other hand, is provided by the IPCU. The *Executive* is a stand-alone software application, independent of ViVA.

Figure 2-4 illustrates the internal configuration of the Command Processor. The Command Processor receives commands over the Serial or Ethernet ports, configures the imager for the appropriate operating mode, and responds to hardware I/O signals.

At the heart of the Command Processor is a PowerPC 440GP CPU, which runs the VxWorks real-time operating system (RTOS). Using an RTOS allows the imager to respond to events on a frame-by-frame basis.

The Command Processor contains three banks of memory:

- DRAM associated with the PowerPC 440GP CPU
- High Speed Synchronous DDR (SDRAM), used in the image processing section
- Non-volatile flash which stores the run-time application as well as the offset and gain correction values used on system start-up.

Offset and Gain Variations

The image processing unit (IPU) corrects for offset and gain variations as well as defective pixels, on a pixel-by-pixel basis. Background and gain variations are due to non-uniformity in the dark current on the array as well as intrinsic differences between the readout amplifiers.

Defective pixels originate on the array. To correct for this phenomenon, the IPU uses data from the nearest neighbors to estimate and replace the defective pixel's value. The offset and gain correction algorithm can be reduced to the following formula:

Figure 2-5 Offset and Gain Correction Algorithm

$$image_data = gain_median * \left(\frac{(raw_image_data) - (offset_data)}{(gain_data) - (offset_data)} \right)$$

The offset_data represent an image taken with no illumination, i.e. a dark field. The gain_data represent an image taken with no object in the X-ray path, i.e. a flat field, and the gain_median is derived from the central part of the offset-corrected flat field. To minimize the error introduced by the correction data, the offset data and gain data are determined by averaging up to 1,024 frames.

For calibration, two images must be collected: a dark field image and a flat field image. This type of correction has the added advantage of removing the spatial non-uniformity of the X-ray beam profile. It is expected that the frequency of gain data recalibration will be relatively low. Please refer to Chapter 4 for calibration procedures.

Internal Power Supply

The internal power supply provides a 24V supply for the Receptor. Typically the current draw is 3A on the 24V supply. The 3030CB / 4030CB Command Processor has a user replaceable fuse on the power inlet



WARNING: All regulatory approvals, including UL and CE mark, are contingent on the use of the Two-Output Power Supply provided by Varian Medical Systems. If substitutions are made, these approvals are void and the image quality cannot be guaranteed.

Modes of Operation

The PaxScan 3030CB / 4030CB supports a number of modes of operation, as defined in Table 2-2. Between each mode is a trade off of resolution, or field of view, for frame rate, or noise. The sensitivity of the imager is optimized to match the X-ray dose used in each mode.



Note: The system may be in only one mode at a given moment.

The operational states of the imager can be categorized as follows:

- **Offset calibration:** (OEM-initiated, or handled automatically by the software Executive)
- **Gain calibration:** (always OEM-initiated)
- **Analog offset calibration:** (always OEM-initiated)
- **Continuous acquisition:** (fluoroscopy-type)

Each operating mode employs all types of calibration. The purpose of each mode is to configure the detector to achieve optimal performance during specific imaging procedures. Modes are defined by a combination of factors, such as pixel binning, frame rates, analog gain and field-of-view. Each mode requires a unique set of calibration data. Calibration is discussed in more detail in Chapter 4.



Note: Not every mode will be available with every system. The OEM should work with PaxScan technical support for configuration of the mode(s) which best suit the customer's intended application.

All the modes shown in Table 2-2 and Table 2-3 are of the continuous acquisition type, which employs accumulation-type acquisition.

Table 2-2 4030CB Standard Modes

Mode	Max Frame Rate (Hz)	Pixel Binning	Image Area	Frame Size	Active Frame Size	Gain/ Capacitor
High-Sense Fluoro	30	2 x 2	Full Field	1,024 x 768	1014 x 758	4/0.5 pF
Normal Fluoro Full-Resolution	30	2 x 2	Full Field	1,024 x 768	1014 x 758	2/0.5 pF
High-Sense Full-Resolution	7.5	1 x 1	Full Field	2,048 x 1536	2,028 x 1,516	2/0.5 pF
High-Dose Full-Resolution	7.5	1 x 1	Full Field	2,048 x 1,536	2,028 x 1,516	2/4 pF

Table 2-3 3030CB Standard Modes

Mode	Max Frame Rate (Hz)	Pixel Binning	Image Area	Frame Size	Active Frame Size	Gain/Capacitor
High-Sense Fluoro	30	2 x 2	Full Field	768 x 768	758 x 758	4/0.5 pF
Normal Fluoro Full-Resolution	30	2 x 2	Full Field	768 x 768	758 x 758	2/0.5 pF
High-Sense Full-Resolution	7.5	1 x 1	Full Field	1,536 x 1536	1,516 x 1,516	2/0.5 pF
High-Dose Full-Resolution	7.5	1 x 1	Full Field	1,536 x 1,536	1,516 x 1,516	2/4 pF

Default Mode

The first imaging mode is the normal default mode, although this can be configured to meet the customer's specific application requirements. The default mode will be invoked automatically under the following conditions:

- Upon system power-up
- Upon receipt of a reset state command, via Ethernet or Serial interfaces

Image Processing

The Command Processor performs offset and gain correction for each pixel. This eliminates fixed pattern noise in the image and makes dose response of each pixel uniform. The Command Processor also provides several other forms of image processing that are commonly required in fluoroscopy and digital radiography.



Note: Cone-Beam imaging applications do not support Offset, Gain and defect corrections. For cone beam See Appendix C.

Recursive Filter

A temporal (recursive) filter is used to reduce noise in low dose fluoroscopic applications, at the expense of increased image lag. The intrinsic lag of the a-Si panel is roughly 4% in the first frame, but can remain at the 1% level for seconds. The recursive filter combines a weighted average of the prior image frames with the current input frame. The recursive filter algorithm is:

$$output_frame = (1 - \alpha) * new_frame + \alpha * old_frame$$

where α can take on values between 0 and 0.99. Recursive filtering introduces a controlled amount of lag into the video output for the purpose of noise reduction. This is a common technique in fluoroscopy, where the signal levels are very low and there is significant noise introduced by the statistics of the X-ray beam itself.

Defective Pixel Replacement

The IPU uses nearest neighbor averaging to replace defective pixels. This can be done successfully for single defective rows, for single and double defective columns, and for combinations of a number of defective single pixels.

Saturation Threshold

The offset and gain calibration implemented in the PaxScan 3030CB / 4030CB will fail once the detector has reached saturation, since the response to increasing dose is not linear. In images with large straight-through radiation, this can lead to a stripe-like pattern in the saturated regions of the image. This effect can be minimized by an appropriate choice of gamma function, or LUT, used for the display. Alternatively, the PaxScan 3030CB / 4030CB has a saturation thresholding function at the input of the image processing section. Pixels above a threshold value are set to a fixed, programmable value and no corrections are applied.



Note: In some applications, the unattenuated dose to the Receptor panel can far exceed the saturation point. In these situations, an additional image artifact may also be seen. This image artifact is a level shift between the upper and lower sections of the image. The dose at which the artifact appears will depend on the beam energy and filtration.

Chapter 3 Getting Started

This chapter describes the major components and functions of the PaxScan 3030CB / 4030CB. The hardware interface connections and an overview of the software used for image calibration and acquisition is provided.

In This Chapter

Topic	Page
Shipment Contents	3-23
Connecting the Cables	3-24
Mechanical Mounting	3-26
Power On Sequence	3-27
Establishing Connection	3-28
Basic Offset Calibration	3-28
Basic Gain Calibration	3-29
Image Acquisition	3-30

Shipment Contents

Immediately upon receipt, inspect the shipment and its contents against the Delivery Note enclosed with the shipment for evidence of damage or missing components. Save all shipping containers in case a return is warranted. If there is any discrepancy, please call the PaxScan Service Center at (800) 432-4422, or (801) 972-5000.

Varian Part Number	Component
18990/20786	PaxScan 3030CB / 4030CB Imager System with:
16272	CsI LN High Bright Receptor
14447	Fiber-optic Command Processor with ABS (LVDS)
11614	30 meter (100 ft.) 24V Receptor power cable
11615	30 meter (100 ft.) fiber-optic data cable
20099	PaxScan 3030CB / 4030CB Systems & Service Guide
11616	USA style Mains power cable, 110 VAC

Options:

17041	RoadRunner R3-PCI-DIF Frame Grabber
7550	Digital Video Cable to R3 Board
16541	7m Integrated fiber and 24V cable
17232	30m Integrated fiber and 24V cable
11229	Lead cap/primary barrier
45004101	1.8 m RJ45 to RJ45 Ethernet crossover cable
45004301	1.8 m Serial (straight type) 9-pin male-to-male cable
19333	5 m Serial (straight type) 9-pin male to female cable
660	Power cable mains, 220 VAC
18104	5 m Unterminated mains cable, 220 VAC
18061	5 m External sync 50-pin MDR/D-Sub cable
18105	40 m Receptor grounding cable

Connecting the Cables

Figure 3-1 Command Processor I/O



Table 3-1 Cable Connections

Step	Action
1.	Connect the power cable from the Command Processor power input port to the wall outlet.
2.	Connect the 11615-series fiber-optic cable from the command processor to the receptor.
3.	Connect the 11614-series 24V cable from the Receptor to the power supply.



Note: The fiber-optic cable connectors should be treated carefully. Do not over-stress the strain relief section. Do not exceed the 5 cm minimum bend radius for the fiber-optic cable.

3

4. Connect the Ethernet cable from the Command Processor Ethernet port to an Ethernet port on the host computer.



Note: If the Ethernet connection is point-to-point between only the Command Processor and host computer, an RJ45 to RJ45 crossover cable must be used. This is shipped with the PaxScan 3030CB / 4030CB. 16-bit still images can be captured by the Command Processor and transferred to the host computer over this Ethernet cable.

5. If available, connect a digital video data cable from the 16 bit digital video output to an image capture board in the host computer.
6. Connect either the camera link cable or LVDS digital video cable depending upon your application from the Command Processor to the host computer.
7. Connect the serial cable from the host computer's COM 1 port to the Command Processor serial 1 port.



Note: The serial cable must be the straight-through type, not the crossover type typically used between computers.



Note: The serial connection is used for diagnostics and loading new software into the Command Processor. This connection is often used during normal operation to monitor communications between the Command Processor and the host computer.

Mechanical Mounting



WARNING: If the PaxScan 3030CB / 4030CB Receptor is to be used as a primary barrier to X-rays, the X-rays must impinge only on the entrance window of the Receptor. The PaxScan 3030CB/ 4030CB Receptor lead cap will not stop X-rays that do not hit the entrance window of the Receptor.



WARNING: The equipment is not suitable for use in the presence of a flammable anaesthetic mixture with air, oxygen or nitrous oxide.

Receptor Mounting

The Receptor should be mounted onto other pieces of equipment using the holes provided. The Receptor has an optional lead cap which can be used as a primary barrier to X-rays. As noted above, this barrier is only effective if the X-ray beam is collimated in such a way that X-rays impinge on the active surface of the Receptor. See Figure 8-14 for more information



Important: The temperature at the back surface of the Receptor should not exceed 35°C when the unit is installed. This may necessitate air flow over the back surface of the Receptor. Humidity levels should be between 10-90%, with higher limits for storage.



WARNING: The Receptor is not sealed against dripping moisture.

Command Processor

The Command Processor can be rack mounted in a standard 3U (5.2" high) slot using optional rack mounting intended for a 19" wide rack. See Figure 8-15 and 8-16 for more information.



Important: The following precautions should be observed when rack mounting the Command Processor:

- **Elevated operating ambient temperature:** If installed in a closed or multi-unit rack assembly, the operating ambient temperature of the rack environment may be greater than room ambient. Equipment should be installed in an environment compatible with the maximum rated ambient temperature.
- **Reduced air flow:** Install the equipment so that the amount of air flow required for safe operation is not compromised. Cooling air clearance is 10 cm (4 inches) minimum from each surface.

- **Mechanical loading:** The equipment should be loaded evenly into the rack to avoid any hazardous conditions.
- **Circuit overload:** Consideration should be given to the connection to avoid overloading of circuits on the over-current protection and supply wiring.
- **Reliable Grounding:** Reliable grounding should be maintained. Particular attention should be given to the supply connection, other than the direct connection to the branch circuit. The use of surge protectors are advised.

Power On Sequence

The PaxScan 3030CB / 4030CB requires no action or intervention from the operator or the host system after power on, or before power off. The PaxScan will be fully operational and ready to receive a **Start Acquiring Image** signal or command data within approximately three minutes after power on. Actual startup time depends on the number of modes loaded and the system configuration.

When startup is complete and if the system is configured accordingly, a default mode test pattern will be sent to the video outputs. Full specification is achieved within two hours after power up.



Note: The PaxScan 3030CB / 4030CB does not require any special warnings prior to power down. No loss of data or setup information will result from unexpected shutdown.

Table 3-2 Power On Sequence

Step	Action
1.	Turn on the host computer and allow it to boot up and login.
2.	Turn on the Command Processor.

The Command Processor must boot up before connection to the viewing application can occur. A successful boot up can be identified in one of four ways:

1. The LEDs **Power**, **Frame**, and **Run** are illuminated on the front panel of the Command Processor.
2. The default set-up is to display a test pattern out the digital video port of the Command Processor, if connected to a digital system.
3. The IP address is displayed over the serial port.
4. Panel_Ready becomes asserted on Hard Handshaking Port.

Once *any* of the four indicators are received, the Receptor is ready to acquire or view images.

Establishing Connection

ViVA™ is the viewing application used to control the Command Processor. Varian Image Viewing and Acquisition (ViVA) is a non-commercial GUI program for controlling the PaxScan 3030CB / 4030CB "out of the box." It currently runs only under Windows 2000.

ViVA sends control commands to the Command Processor over a 10BaseT Ethernet connection. Some of ViVA's functions include acquiring images from the Receptor, viewing images, and saving images to the hard disk. ViVA may also be used with a serial interface, but not for retrieving images.



Note: In order for ViVA to establish an Ethernet connection with the Command Processor, the *client* IP address and *server* IP address parameters must be configured. If your system configuration has not been factory-set, please see Appendix B, *Command Processor* and *Computer Interface*, to configure your system.



Note: For additional assistance operating ViVA, use the *ViVA Online Help* file, or see *Operation*, Chapter 6 of this guide.

Basic Offset Calibration

Prior to acquiring images, an offset calibration must be performed for *each* mode you intend to use.

- After the panel has been powered up for thirty minutes, calibration should be performed every ten minutes, and as needed for clean images thereafter.
- An offset calibration should be performed any time the panel is inactive for more than five minutes, or if the image seems to be degraded.

Standard calibration defaults:

- During idle periods of operation, auto offset calibration will occur every five minutes.
- Post-exposure offset is every two minutes.
- During continuous operation, an offset should be performed every five to thirty minutes, depending on image quality and application time constraints.




Note: Cone-Beam modes not supported. For cone beam See Appendix C.

Table 3-3 Basic Offset Calibration

Step	Action	Results
1.	Start	Invoke ViVA .
2.	Open Link	Select Ethernet or Serial Connection from the Acquisition Mode drop-down menu.
3.	Select Mode	Select the desired mode from the Acquisition Mode drop-down menu.
4.	Begin Offset	Click Offset Calibration button, or select offset calibration from the acquisition pull down menu. With any calibration selection, an Accumulating Dark Frames window appears.
5.	Acquire Images	Click on Acquire Image to begin acquisition.

3

Figure 3-2 ViVA - Open Ethernet Link



Basic Gain Calibration

The general procedure for Gain calibration for all modes, is as follows, detailed instructions on performing gain calibrations are covered in Chapter 4.



Note: Cone-Beam modes not supported. For cone beam See Appendix C.

Table 3-4 Gain Calibration: All Modes

Step	Action	Results
1.	Warm Up	To ensure proper warm up, the PaxScan 3030CB / 4030CB Receptor must be operational for at least two hours prior to Gain calibration.
2.	Radiation	<p>A uniform flat field with no object in the path of the X-ray beam. The radiation must be at a level and technique representative of the typical radiation dose for the Receptor during typical procedures.</p> <p><i>Note: The exact level of the radiation during calibration will not influence the calibration as long as the signal level is not saturated.</i></p>
3.	Offset	<p>Software automatically performs a new Offset Calibration calibration following the acquisition of the flat field image.</p> <p><i>Note: X-rays must be disabled.</i></p>
4.	Repeat	The above procedure must be repeated for each of the stored modes.


Image Acquisition

Once Offset and Gain Calibration is performed, you are ready to acquire images.

Fluoroscopy - Normal

To acquire an image, click **Acquire Image**. The following window will appear:


Figure 3-3 ViVA-Fluoroscopic Acquisition - Normal



This window indicates that the Receptor is actively acquiring “live” images. Click **Stop**. The last frame or accumulated frames will be captured and stored in the Command Processor memory.

To retrieve the last image stored in the Command Processor to ViVA, click **Retrieve Image**. This will grab an image out of the Command Processor memory and transfer it to the host computer. The thumbnail image will be displayed in ViVA’s image gallery. The image can now be viewed by dragging it into the main window, and/or saved to disk.

Figure 3-4 ViVA-Retrieve Image



Chapter 4 Calibration Procedures

The IPU in the Command Processor FPGA corrects for Gain, Offset and Analog variations between individual pixels as well as globally across the image.

This non-uniformity compensation requires that a Gain reference image and an Offset reference image be resident in the Command Processor’s high speed SDRAM memory prior to imaging procedures.



Note: Cone-Beam modes do not support Offset, Gain and Defect Corrections. For cone beam See Appendix C.

In This Chapter

Topic	Page
Offset Calibration	4-34
Gain Calibration	4-34
Fluoroscopic Mode Gain Calibration	4-36
Defective Pixel Maps	4-40
Analog Offset Calibration	4-40



Note: References to the OEM computer is as *Client*, while the PaxScan 3030CB / 4030CB Command Processor is referred to as the *Server*.



Note: After Gain calibration is complete, an Offset calibration automatically follows.



Note: The Command Processor will not apply the Offset and Gain correction to pixels identified as being saturated. This feature of the non-uniformity correction avoids inverse compensation artifacts in regions where the image is saturated and where non-uniformities are no longer present.

Offset calibration compensates for fixed pattern pixel intensity variations in the image, associated with the dark current (Receptor) and electronic offsets introduced by the readout ASIC and the Analog Board.

The Offset reference image is an average of a series of frames acquired with no illumination, referred to as dark fields. The Gain reference image is an average of a series of frames acquired with uniform X-ray illumination, referred to as flat fields, across the active area.

The larger the number of frames used in creating the Gain and Offset reference images, the lower the amount of noise contributed to the image by the non-uniformity correction. The Analog offset calibration reduces DC offsets created by variations in electronic components, providing more dynamic range.

It is possible to download the Offset and Gain reference images to the Command Processor (Server) via the Ethernet interface. The current Offset and Gain reference images can also be uploaded to the Client computer, via the Ethernet interface.

Offset Calibration

The request to perform Offset calibration can be initiated by the client system, via a software command across the Ethernet interface, or the Command Processor can handle the calibration procedure autonomously. It performs all calculations of correction factors internally and stores the relevant data in memory, without requiring action from the main system or the operator.

Some important points concerning Offset correction:

- Offset calibration should not occur while the X-ray is activated.
- The X-ray-to-digital conversion factor does not change as a result of calibration.
- A different offset reference image is necessary for each operating mode, therefore it is important to update the offset data for each of the operating modes.
- If the **Prepare** signal on the Command Processor's external synchronization port is asserted, the PaxScan 3030CB / 4030CB is able to abandon an ongoing offset calibration with no loss in pre-calibration image quality.
- After abandoning an offset calibration, the PaxScan 3030CB / 4030CB will be ready to acquire images within four frames. The *ready to acquire* condition is communicated via the **PanelReady** signal on the synchronization interface.



Note: It is recommended that a delay of at least 20 seconds be allowed after an X-ray exposure, before commencing with offset calibration. Since there is some inherent lag in the detector, this delay avoids introduction of a latent image into the offset reference image.



Important: Since the offset characteristics of the detector vary during normal operation, the offset reference image must be updated at least every two to five minutes while the PaxScan 3030CB / 4030CB is warming up, and at least every 15 minutes once it has reached its steady state temperature, typically after about two hours of operation.

Gain Calibration

To compensate for non-uniformities in the Receptor, a gain reference image (flat field) is used by the Image Processing Unit as required to correct all images in real-time. This flat field image must be captured by the Command Processor prior to acquiring images, and stored in non-volatile memory. The process of capturing the flat field image is known as Gain calibration.



Note: Gain calibration should take place at regular intervals, typically once every three months, or whenever the X-ray source has been moved relative to the Receptor.

Gain calibration is based upon the linear response of the Receptor to dose. Normalization is achieved by applying the flat field image acquired in the Gain calibration to all images passing through the Image Processing Unit. Normalization will fail with pixels that are responding to dose in a non-linear manner. Pixels responding to dose in a non-linear manner are usually caused by the saturation of the Receptor, or a low signal-to-noise ratio. These non-linear pixels will be marked defective during the manufacturing process and will be corrected by the Image Processing Unit.



Note: It is critical that the flat field image be acquired within a range that is large enough to be higher than background noise created by the X-ray source and readout electronics of the Receptor, but lower than the saturation point of the Receptor.

4

Flat field images acquired near or exceeding the saturation point will cause normalization failures with all images acquired until a Gain calibration with the correct dose is performed. Varian recommends that flat field images be acquired with a median count of 2000 - 4000 +/-500. This range will ensure that Gain calibration will meet both the upper and lower dose requirements under all modes of operation.

To reduce the effects of noise, the average of each pixel in the flat field image is calculated by accumulating a number of frames into an internal buffer, then dividing the sum of each pixel by the number of frames acquired.



Note: The larger the number of calibration frames used to capture the flat field image, the more precise the calibration will be.

The number of calibration frames used during Gain and Offset calibrations can be adjusted under the Mode Settings pull down menu. For more detailed information, refer to ViVA in the *Operations* section of this Guide.

Varian recommends accumulating 128 frames in fluoroscopic modes, and 32 frames in full-resolution modes. For low frame rates, such as one frame per second, this may be too long a period. In such cases, it may be necessary to lower the number of calibration frames to a more tolerable time period, not going below eight frames.

After completion of the calibration procedure, the following information will be viewable with ViVA via the Ethernet interface, upon request from the *client*:

- The median pixel value of the Gain image
- Gain and Offset reference images
- The defect map image
- The median pixel value of the Dark Field image.



Note: Always use pulsed.



Important: The PaxScan 3030CB / 4030CB imaging system requires a warm-up of two hours prior to Gain calibration.

The general procedure for Gain calibration for all modes, is as follows:


Table 4-1 Gain Calibration: All Modes

Step	Action	Results
1.	Warm Up	To ensure proper warm up, the PaxScan 3030CB / 4030CB Receptor must be operational for at least two hours prior to Gain calibration.
2.	Radiation	A uniform flat field with no object in the path of the X-ray beam. The radiation should be at a level technique and filtration representative of the typical radiation dose for the Receptor during typical procedures. <i>Note: The exact level of the radiation during calibration will not influence the calibration as long as the signal level is not saturated.</i>
3.	Offset Calibration	Software automatically performs a new Offset calibration following the acquisition of the Flat Field image. <i>Note: X-rays must be disabled.</i>
4.	Repeat	The above procedure must be repeated for each of the stored modes.

Fluoroscopic Mode Gain Calibration


1. Select Acquisition > Gain Calibration from the ViVA menu bar.

Figure 4-1 Selecting Fluoroscopic Mode Gain Calibration



The following window appears:


Figure 4-2 Gain Calibration - Fluoroscopy



4

The imager will now begin acquiring Flat Field images. Progress of the accumulation can be seen in the following figures. Follow instructions in the dialog box.


Figure 4-3 Gain Fluoro - Frame Accumulation



2. After the number of acquired frames equals the number of calibration frames selected, the imager will be ready to collect Dark Field images. Follow instructions in the new dialog box:


3. The system will pause to allow lag to decay prior to performing an Offset calibration. The following window appears:

Figure 4-4 Offset Calibration: Dark Field Accumulation




4. As dark field accumulation progresses, the following window is displayed:

Figure 4-5 Dark Field Accumulation in Progress



5. After acquiring the specified amount of dark images, the following window will appear indicating that the imager is now calculating the gain data.


Figure 4-6 Imager Analyzing



4

6. When Gain Calibration has completed the following window will be displayed with the Gain Calibration statistics updated.

Figure 4-7 Fluoroscopic Gain Calibration Complete



Gain median count should be between 3000 +/- 1000.

- If the median value is higher than 4,000, the dose used needs to be decreased and the gain calibration repeated.
- If the median value is lower than 2000, the dose needs to be increased, and the gain calibration repeated.

Defective Pixel Maps

The defective pixel map is determined during Gain calibration, using information from both the Offset and Gain reference images. The map of defects is stored in the Command Processor's internal long term (flash) memory. Using the defect map, the pixel correction algorithm uses nearest neighbor averaging to replace all defects in each video frame.

Important: Points of note about defect correction:



- The pixel defect map is the combination of two defect maps:
 - The first map, *base*, is determined at the factory and does not normally change.
 - The second defect map, *aux*, is newly determined during each Gain calibration.
- Both types of maps are bit-wise ORed, then supplied to the image correction algorithm.
- After correction, no defective pixels should be visible in Flat Field images.
- It is possible to upload both defect maps from the PaxScan 3030CB / 4030CB to the *client* computer, via the Ethernet interface. It is also possible to replace the base map, resident in the Command Processor, with a map downloaded from the *client* computer, via the Ethernet interface.

Analog Offset Calibration

Analog Offset calibrations are determined during imaging system configuration at the factory, or if a new mode configuration file is loaded.

Analog Offset calibration reduces non-uniform pixel offsets created by differences in the readout components located in the Receptor. By reducing the non-uniformity in the Receptor electronics, the overall dynamic range of the system can be optimized.

To initiate an Analog Offset calibration, the client computer must send a software command, via the Ethernet interface or Serial interface, to the Command Processor. The Command Processor will then initiate the Analog Offset, perform all necessary calculations, and store resulting offsets in non-volatile memory.

1. Select Analog Offset Calibration from the Tools->Receptor pull down menu and the following window will appear.

Figure 4-8 Analog Offset Settings



Note: Analog Offset Calibration is not available for Cone-Beam modes. For cone beam See Appendix C.

2. Set Target Value and Tolerance based on Analog Gain Setting (see table below).

Table 4-2 Analog Offset Settings - Target Values & Tolerance

Analog Gain	Target Value	Tolerance
1	1500	10
2	2000	15
4	2000	20

3. Press Calibrate and the system will begin the calibration progress. ViVA will report the progress of the calibration by indicating the number of Iterations completed.

Figure 4-9 Analog Offset Calibration Progress

Once that target value has been reached the calibration will complete and the following window will appear prompting you if you like to perform a Gain Calibration. After each Analog Offset Calibration the mode must have the Gain Calibration performed again. If Yes is selected the system will launch the gain calibration process. If No is selected the analog offset calibration will be exited.

Verification of Analog Offset Calibration

1. Disable all image corrections via **Acquisition->System Settings**.
2. Acquire image.
3. Retrieve image.
4. Click **Edit W/L** button.
5. From Edit Values section, select **Bottom\Top**.
6. Set Top field based on the Analog Gain setting of the mode.
 - If Analog Gain is set to 1, then set Top Field to 751 and Bottom Field to 750.
 - If Analog Gain is set to 2, then set Top Field to 1001 and Bottom Field to 1000.
 - If Analog Gain is set to 4, then set Top Field to 1001 and Bottom Field to 1000.



Note: To get analog gain setting select Acquisition->Mode Settings.

7. Image should appear all white, with the exception of defects.
8. If step 7 fails, repeat analog offset calibration procedure.



- Important:**
- Analog Offset calibration requires no X-rays during the calibration procedure.
 - It is recommended that the system be powered **On** for at least two hours prior to performing an Analog Offset calibration.
 - A different Analog Offset calibration is required for each mode.
 - It is recommended that a delay of 60 seconds be allowed after an X-ray exposure, before performing an Analog Offset calibration.
 - An Offset and Gain calibration must be performed after completing the Analog Offset calibration.
 - The Receptor configuration file will be modified in the Command Processor. This new file should be uploaded to the Client computer.
 - Verify Analog Offset calibration.

In This Chapter

Topic	Page
Software Programming Interfaces	5-43

Software Programming Interfaces

There are three interfaces which can be used to control the PaxScan 3030CB / 4030CB imaging system. Each are included in the CD-ROM provided with each system. They are:

- **Ethernet Interface:** A “sockets”-based interface which provides full access to PaxScan 3030CB / 4030CB functions. The Windows® side of the interface is implemented as a Win32 DLL. The programmer does not need to do any sockets programming, but can simply make synchronous function calls to the DLL.
- **High Level Serial Interface:** Provides all the same functions as the Ethernet Interface, with the exception of four functions which implement uploading and downloading of image and configuration files. It also uses exactly the same Win32 DLL as the Ethernet Interface. This serial interface is implemented on top of the AIA Standard Serial Interface outlined below.
- **AIA Standard Serial Interface:** Provides good functionality, but with the added responsibility for the programmer to completely implement one side of the interface. The commands themselves are character-based, and are sufficiently simple that they can be used to control the PaxScan 3030CB / 4030CB from an ASCII terminal, or terminal emulator program. Devices with limited computing power might choose to use this interface.




Note: This section provides a general overview. Each of these are explained more fully on the CD-ROM provided with your system, or in the *PaxScan Communications Manual*.

Ethernet Interface and High Level Serial Interface

These two interfaces will be treated together, because from the programmer’s perspective, they are implemented in an identical fashion. Figure 5-1 shows the architecture of a system using these interfaces.

Figure 5-1 Ethernet and High Level Serial Interface Architecture





Note: Although the DLL provides both Ethernet and Serial connectivity, only one interface may be used at a given moment.

The implementation of the interface ensures that all commands are executed synchronously. Only one command is active at a time. This helps make the system more robust and efficient. It also provides a function call paradigm, not a message-passing one, for the programmer.

Interface Files

Three files are provided to the customer for implementation of each interface:

- **vip_comm.lib:** a library file that should be included in the project if the programmer is using the Microsoft® Visual C++ environment.
- **vip_comm.h:** a C-style include file which has been used successfully in different build environments.
- **vip_comm.dll:** allows the programmer to create a library file in other development environments.



Note: All functions have an *int* return type, representing the success or failure of the call, with a non-zero value indicating an error condition. Definitions of errors and other required constants are given in the *PaxScan Communications Manual*.



Note: To avoid namespace conflicts, the name of each function begins with **vip_**, and the name of each constant with **VIP_**.

Initial Connection to the Command Processor

The programmer initiates a connection to the Command Processor by following these steps:

1. Type **vip_open_link(...)**. This connection type, Ethernet or Serial, is indicated in the first call.
2. A connection is terminated by calling **vip_close_link(...)**.

Other commands, as defined in the *PaxScan Communications Manual*, can be used to instruct the PaxScan 3030CB / 4030CB to perform a wide variety of operations. An example of the most commonly used commands can be viewed in the Software Interface Code section of the *PaxScan Communications Manual*. This sample code is also available in the Vip_Comm directory of the PaxScan Software release folder.

More complete examples of how the interface functions are used are outlined in the *PaxScan Communications Manual*.

The ViVA software application is a Windows-based program designed to be used with PaxScan products to perform basic tasks. ViVA can be used to control axquisitions with PaxScan products and also display and manipulate images on a Windows PC that is not connected to a PaxScan system. ViVA targets medical images ans exclusively displays 16-bit image formats.

This ViVA Help documentation is designed to assist users with use of the ViVA.

In This Help Document

Topic	Page
Setup	6-46
View Menu & User Interface	6-46
File Menus & Image Files	6-51
Edit Menu & Preferences	6-56
Edit Toolbar & Image Manipulation	6-58
Acquisition Menu/Toolbar	6-65
Video Menu/Toolbar	6-74
Analysis Menu: Image Statistics	6-78
Tools Menu	6-82



Note: In this section primary ViVA commands from menus or toolbars are in bold type. For increased clarity in places a menu and menu item may be specified with a vertical separator (e.g. **File|Close**). Commands and controls found in dialog boxes are generally in ***bold italic*** type. References to sections of this chapter are in **bold underline**.

ViVA uses a number of common terms and notations that have special meanings:

- Menu items ending with three periods (e.g. **File|Open...**) indicate that executing the commands will require further input from the user in a dialog box. Menu items without the periods normally require no further involvement by the user and will be executed immediately.
- In a dialog box, a ***Cancel*** button implies closure of the dialog box without executing data on the dialog box. The ***Apply*** button implies execution of data on the dialog box that updates data and/or the Command Processor. The ***OK*** button performs the same tasks as the ***Apply*** button if they have not been executed, then closes the dialog box.

Setup

System Requirements

ViVA will run on Intel-based PCs using Windows XP. Generally, acceptable performance in image viewing and manipulation can be obtained with any Pentium CPU system. The number of open images is limited by the combination of physical and virtual memory. The quality of the video card, hardware, firmware, and driver software also impacts the perceived speed of operation.

When used with a frame grabber card, system requirements are more demanding; the following is provided for guidance. A minimum system specification includes a Pentium III processor running at 1GHz or better with at least 512MB RAM and preferably 1GB. It is also strongly suggested that you check the frame grabber manufacturer's recommendations regarding specific hardware. The intended use of the system may dictate larger amounts of RAM since capturing video sequences generally requires at least enough memory to store the largest expected sequence + an additional 128MB.

Installation

The *Setup.exe* in the root directory of the PaxScan CD provides an automated installation process for ViVA and any dependent files. *Setup.exe* is automatically started when the CD is inserted into a CD drive unless the *Auto-Run* CD option is turned off. To start *Setup.exe* manually, use the *Run* command under the Windows *Start* button to execute *X:/Setup.exe*, where *X* is the drive letter of the CD drive that contains the PaxScan CD. *Setup.exe* will create a shortcut of ViVA on the desktop.

To uninstall ViVA, run the *Add/Remove* application in the Control Panel and remove the entry PaxScan.



Note: Running this automatic uninstall program will also remove all other PaxScan components such as Command Processor files and Hostdown files that were previously installed onto the hard drive.

To run ViVA, locate and double click the shortcut of ViVA on the desktop.

Version

ViVA version information is available from the **Help|About ViVA...** command. This dialog will also show information about any dlls in use. If a link to a Command Processor(CP) is open, the dialog will also allow information on the CP software and firmware versions to be obtained.

View Menu & User Interface


Various commands described below allow customization of the image and toolbar layout. These settings are stored in the *viva.ini* file when the program exits and ViVA will launch with the same preferences selected when next used. The *viva.ini* file is automatically created with default settings by ViVA when it launches if none exists already.

Image Window Types

ViVA does not use the standard Windows MDI (*Multiple Document Interface*) arrangement of multiple, overlapping, moveable and resizable windows. Instead, the application offers two other types of windows for displaying images: a scrolling image gallery, *ThumbView* or *Thumbview*, and fixed frame *Imageview* windows.

A screen shot of the ViVA user interface is shown in figure 1.

Figure 6-1 ViVA Screen View



Most image manipulation operations can only be performed on an *Imageview* and not on a *Thumbview*. In addition to the image file name, the *Imageview* window also displays information about magnification (zoom), window/leveling, image size, and, for the pixel under the mouse cursor, (x, y, value) data.

The size of the *Imageview* windows is adjusted automatically to fit the size of the main window of the application. The arrangement and number of windows can be selected using the **View** menu.

Newly opened or acquired images appear in miniature in a *ThumbView* window which holds all the active and opened images. Images retrieved from a receptor are also automatically displayed to an image pane. The *Thumbview* window can be positioned horizontally along any selectable from the **View** menu.

Images can be moved from the *Thumbview* by dragging and dropping to one of the larger *Imageview* windows. There may be up to 16 of these, and the preferred layout may be configured from the **View** menu.

When an image is dragged from the *Thumbview* to one or more *Imageview* windows, the separate views of the image are logically linked. Only one copy of the pixel data is stored in memory for use by all views of that image.

A *Thumbview* or *Imageview* can be selected by clicking on the view with the mouse pointer. The currently selected *Imageview* is normally indicated with a bright green selection rectangle. Other linked views of the same image shown in the selected view are indicated with a bright blue selection rectangle. Many menu items including **File|Close** or **File|Save As...** are applicable to the selected image.

Image Layout

Under the **View** menu, there are a number of options controlling the layout:

- **Thumbview Position** allows the user to place the *Thumbview* along any edge, while **Show Thumbview** allows it to be shown or hidden.
- **Single-Image Layout**, **Two-Across Layout** and **Four-Image Layout** allow the user to choose from among common formats. **Number Images Across** and **Number Images Down** allow greater flexibility in selecting other multi-image layouts.
- **Show Border** allows the user to hide or show certain borders that are normally shown.
 - ☐ **Image** refers to the green border around the image itself.
 - ☐ **Select** refers to the colored border around the image pane (applies to *Imageview* only).
 - ☐ **Pane** refers to the Windows style setting that by default creates a bevelled look at the pane edge.

Full Overlay

Certain information appears in the corners of each thumb or image pane. This is referred to as the overlay, and the more detailed information in the lower corners may be shown or hidden using the **View|Full Overlay** command. This can be useful when displaying a large number of images.

Status Bar

The **View|Status Bar** command allows the user to display or hide the status bar on the bottom of the main window. The status bar displays a short description of some pull-down menu commands when highlighted by the cursor. Alternatively, the status bar displays the currently selected mode (Fluoroscopy, Radiography...) when the cursor is placed in other sections of the application.

Message Options

Message boxes are displayed during ViVA operation. These are normally classified as one of three types:



Information or Info – the message box contains information that may be useful in the current context. The title of the message box is '*ViVA Message Box*'.



Data Loss Warning or DataLoss – a warning that an operation risks loss of data. For example if an attempt is made to close an image which has not been saved. The title of the message box is '*ViVA Message Box - Data Loss Warning*'.



Error – An error has occurred which could be a system error or internal ViVA error. This may result in an operation being aborted. The title of the message box is *'ViVA Message Box - Error'*.



Note: The message box style may allow the user to continue the operation (**OK** button) or cancel the operation (**Cancel** button). In some cases (Info or DataLoss) the message may also be posed as a question with **YES/NO** buttons. In such cases the icon will be a question mark. However, the message box classification remains as *Info* or *DataLoss* as indicated by the dialog title.



Certain *Info* messages that are routinely displayed before completion of a command allow the user to elect not to display the same message again. Once this election is made, the user preference is stored in the *viva.ini* file and remembered upon future ViVA launches.

The **View|Message Options...** command displays a dialog, shown in figure 2, which permits a number of modifications as to which messages are displayed:

SHOW all 'DontShowAgain' Messages resets all messages back to on.

KEEP Messages as they are now is the default and no changes are made.

HIDE 'Info' Messages (until ViVA closes) hides all Info messages until ViVA closes only.

HIDE 'Warning/Info' Messages (until ViVA closes) hides all DataLoss and Info messages until ViVA closes only.

The lower two options should not normally be selected but may be useful in certain situations where some repetitive series of operations is being carried out.

Figure 6-2 Message Options




Image Information

When images are retrieved from the CP, a header containing information on current settings is automatically generated. The **View|Image Information** command displays the information contained in this header in a series of tab-enabled dialog boxes which are illustrated in the following figures:

Figure 6-3 Image Information: Image Tab

The screenshot shows the 'VIVA - Image Information' dialog box with the 'Image' tab selected. The dialog contains several input fields for image metadata. The 'Image Name' field is filled with 'Video1_frame1.seq'. The 'Date / Time Retrieved' field shows '07NOV2005, 13:43:28'. The 'Header Version' is 'Rev K.04', 'Maximum Pixel Value' is '32767', and 'User Image Type' is 'NOT AVAILABLE'. The 'Width x Height' is '1024 x 768' and 'Hdr. Status Code' is 'OK'. There is a large text area for 'Comments'. Below this is a section for 'Technique info' with fields for 'Tube Voltage', 'Current (*time)', 'SID', 'Dose', and 'Filtration'. At the bottom are buttons for 'Save VivHdr as Text', 'OK', 'Apply', and 'Cancel'.


Image Name:	Video1_frame1.seq	Date / Time Retrieved:	07NOV2005, 13:43:28
Header Version:	Rev K.04	Maximum Pixel Value:	32767
Width x Height:	1024 x 768	User Image Type:	NOT AVAILABLE
Hdr. Status Code:	OK		
Comments:			
Technique info			
Tube Voltage:		Current (*time):	
Dose:		Filtration:	
SID:			

Figure 6-4 Image Information: System Tab

The screenshot shows the 'VIVA - Image Information' dialog box with the 'System' tab selected. This tab contains various system configuration settings. On the left, there are checkboxes for 'Offset Correction' (TRUE), 'Gain Correction' (TRUE), 'Defect Correction' (TRUE), and 'Line Noise Correction' (FALSE). Below these are fields for 'Low Noise/Fast Scan' (Low Noise (DCDS on)), 'Offset Calibration Shift' (0), 'Pixel Data Format' (Unsigned 16-bit), 'Pixel Scale Factor' (n/a), and 'Recursive Filter (%)' (0). On the right, there are fields for 'System S/W Version' (Rev K.04-34 Jul 28 2005), 'Receptor Serial #' (Latest Version), 'Receptor Type' (PaxScan Cone Beam 4030), 'Binning (ColsxRows)' (2x2), 'Frame Rate' (30.00), 'Analog Gain Value' (2.00), 'Cone Beam Mode Type' (n/a), 'Cone Beam Gain Ratio' (n/a), and 'Vista Enabled' (FALSE). At the bottom are buttons for 'Save VivHdr as Text', 'OK', 'Apply', and 'Cancel'.

Offset Correction:	TRUE	System S/W Version:	Rev K.04-34 Jul 28 2005
Gain Correction:	TRUE	Receptor Serial #:	Latest Version
Defect Correction:	TRUE	Receptor Type:	PaxScan Cone Beam 4030
Line Noise Correction:	FALSE	Binning (ColsxRows):	2x2
Low Noise/Fast Scan:	Low Noise (DCDS on)	Frame Rate:	30.00
Offset Calibration Shift:	0	Analog Gain Value:	2.00
Pixel Data Format:	Unsigned 16-bit	Cone Beam Mode Type:	n/a
Pixel Scale Factor:	n/a	Cone Beam Gain Ratio:	n/a
Recursive Filter (%):	0	Vista Enabled:	FALSE

Figure 6-5 Image Information: Video Tab



This tab is absent if video is not enabled.

6

Toolbars

There are three basic toolbars used in ViVA. They are standard Windows toolbars which may be docked to floating, and the configuration in use when ViVA closes is stored in the viva.ini file for the next launch. The **Image Edit** toolbar is oriented vertically and may only be docked along the left or right edges of the main ViVA window; it defaults at the left. The **Acquisition** toolbar is oriented horizontally, may be docked top or bottom and by default docks along the top edge of the main ViVA window. The **Video** toolbar maybe docked along any edge, defaulting to the right. In addition a **Defect Map Editor** toolbar replaces the **Acquisition** toolbar when the defect map editor is open.

File Menu & Image Files

ViVA can open, close, save, copy and print images. This section describes these operations.

Saving Images

Choosing **File|Save As...** will display a standard Windows file/save dialog box. The user can choose to save an image in the formats discussed above in the supported file formats described below.

Saving Individual Images

The following file formats are supported for saving individual images:

- *ViVA (.viv)*: uncompressed 16-bit unsigned data together with a custom 2,048 byte header containing both optional user-entered information as well as automatically retrieved settings in effect at the time an image was obtained. This is the default.
- *Raw (.raw)*: uncompressed 16-bit unsigned data are saved without any header or other information than the pixel values. ViVA only supports certain predefined image sizes for this format.
- *Bitmap (.bmp)*: uncompressed 8-bit window-leveled Windows bitmap. the image is saved using the currently applied window/level and gray-mapping.
- *JPEG (.jpg)*: compressed 8-bit window-leveled JPEG. The user is asked to supply a quality factor in the range 1-10 where 10 gives the highest quality and largest file size. The image is saved using the currently applied window/level and gray-mapping.
- *Internal Varian Format (.asi)*: uncompressed 16-bit unsigned data together with a custom 512 byte header. Similar to the .viv header but provided primarily to allow images to be exported to other Varian products.
- *Tiff 16-bit (.tif)*: uncompressed 16-bit unsigned data which may be opened by tiff readers that support 16-bit data. Note that ViVA, by default, scales the pixel values to utilize more fully the 16-bit range. This generally results in a more satisfactory experience when opened by readers that do not perform any automated window/leveling. This scaling may be turned off in the **Preferences** dialog. Note that ViVA does not support opening tiff images in general, but will open 16-bit tiff images it has saved, restoring the correct pixel scaling. Tiff images may be accessed from the open file dialog using the 'Any Files' filter or when applicable the most recently used files under the **File** menu.



Note: For the special 2MSBs are exponent pixel data format (see **Pixel Data Format & 3030CB / 4030CB Receptors**), a warning will be given that the image will first be converted to a scaled image.

- *Tiff 8-bit (.tif)*: uncompressed 8-bit unsigned data which may be opened by typical tiff readers. The image is saved using the currently applied window/level and gray-mapping.

Saving Video Sequences

The following file formats are supported for saving video sequences:

- *Video Sequence (.seq)*: uncompressed 16-bit unsigned data together with the same 2048 byte header as the .viv format.
- *AVI Sequence (.avi)*: compressed 8-bit window-leveled AVI. As for .jpg a quality factor in range 1-10 should be entered.

Opening Images

Images can be opened for display and manipulation using the menu option **File|Open....** The opened image will appear in the *Thumb View*; and may be dragged to an *Image View* as required.

The opened image is first displayed with an automatic window-leveling setting which is intended to show image features across a broad range of contrast.


If an image is successfully opened, the path and file name of the image is saved as the latest entry onto the most recently used file list which can be used as a shortcut to open the file.

ViVA supports opening a number of file formats, some of which have specific purposes, and may not be useful to most users. Except as note only formats having 16-bit unsigned data are supported generally.

File|Open... supports:

- *ViVA (.viv)*: 16-bit unsigned data with 2048 byte header.
- *Raw (.raw)*: since there is no header information, only particular predefined image sizes can be opened in .raw format.
- *Img (.img)*: similar to .viv with 1024 byte header but only image dimensional data are read.
- *Video Sequence (.seq)*: 16-bit unsigned data with 2048 byte header. Differs from .viv only by having more than one frame.
- *CT 16-bit signed (.slice)*: This data format is signed with no header. Only the predefined image sizes used for the .raw format are supported.
- *CT 16-bit unsigned (.prj)*: 16-bit unsigned data with 72 byte header. Image information from the header is displayed as the image opens.
- *HNB compressed 16-bit unsigned (.hnb)*: 16-bit unsigned data in a compressed format. There is a 512 byte header, but only image dimensional data are read.
- *HNC compressed 16-bit unsigned (.hnc)*: Similar to .hnb.
- *HND compressed 32-bit unsigned (.hnd)*: hnd images are imported but it is assumed that only 17 bits are used. As described in **3030CB / 4030CB extensions**, ViVA supports a custom format designed to allow integer values up 17-bits to be handled.
- *Any Files: (*.*)*: With limited scope, this allows generic file types to be opened for viewing; **File|Open...** permits opening any file which has uncompressed 16-bit unsigned data residing in a contiguous block (assumes Little Endian/Intel byte arrangement). Additional information may be present provided its disposition within the file is known. The user is asked for 3 fields of information: header size, image width and image height. These are automatically initialized with best guess values based upon the predefined .raw image size which minimizes the header size. When the user changes one of the image dimension fields the other field is automatically adjusted the first time but not subsequent times. This is to permit the possibility of trailing information after the pixel block in the file. i.e. the header and image dimension fields are not forced to define the file size. Header and trailer information is ignored and cannot be accessed by the **Image Information** command. The dialog box illustrated in the following figure will be displayed when opening a file with *Any Files* as the specified filter.

Figure 6-6 File Format: Any Specification Dialog



Closing Images

To close individual images, select **File|Close**. If close is selected for a *Thumbview*, that view and any associated image view windows will be closed as well. If an *Imageview* is selected when Close is chosen, only that view of the image will be closed, leaving the *Thumbview* of the image and any other *Image View* windows open.

To close all currently open images, choose **File|Close All**. This selection will close all open images in both the *Thumbnail View* and *Image View* windows.

Please see *Image Window Types* for a description of window types (Thumbnail View and Image View windows) and *Supported File Formats* for supported image file types.



Note: Unsaved images have an asterisk (*) appended to the name; if you attempt to close an unsaved image, you will be prompted before closing it. . Saving as a 8-bit format does not clear the asterisk (*).

Printing Images

To print an image, choose **File|Print...** which will print the currently selected image from either the *Thumbview* or the *Imageview*.

Choose **File|Preview...** to display a print preview of an image. This selection will provide a screen display of a print copy of the currently selected image from either the *Thumbview* or the *Imageview*. This option is intended to show the layout of a printout for an image, not the quality of the printout.

The printer setup can be accessed through **File|Print Setup...** This selection will allow the user to select printer and paper options.

Copying Images

Select **Edit|Copy** to copy the image currently selected onto the clipboard memory.



Note: This function always copies the whole image using the current window-level settings, not just the section of the image being displayed in the *Imageview*.

Pixel Data Format & 3030CB / 4030CB Receptors

A 'Cone Beam Mode Type' is displayed for 3030CB / 4030CB receptors (*System* tab, figure 4). This may be one of: 'n/a' (i.e. a normal mode with pixel data format 16-bit unsigned), *DUAL_READ* or *DYNAMIC_GAIN*. This information field is stored in the *viv* header, and refers to the original mode type used to acquire the image.

The current pixel data format is listed in the *System* tab (see figure 4). Prior to the 3030CB / 4030CB receptor this has always been 'Unsigned 16-bit'. Pixel information is still stored as 16-bit values, but may not be interpreted necessarily as simple unsigned integers. The 3030CB / 4030CB still provides 14-bit data, but it is capable of operating in dual gain modes. In dynamic gain modes the 15th bit specifies lo(0) or hi(1) gain. In addition since the ratio of the gains normally exceeds 4, the range of values in an image cannot be represented as 16-bit integers. A new corrected pixel data format is used for 3030CB / 4030CB corrected images.

The pixel data format field which is stored in the *.viv* image header determines the pixel data format which may be one of the following:

- 16-bit unsigned integer – normal format for all receptors except 3030CB / 4030CB (specifically dual read or dynamic gain mode images).
- 2 MSBs are exponent – the only corrected format currently supported for 3030CB / 4030CB. Here the 2 most significant bits are interpreted as forming an exponent (value $n=0,1,2,3$) for the other 14 bits. The pixel value is calculated as:

$$pix = mant * 2^n$$

where *pix* is the pixel value (0-131,064), *mant* is the 14-bit value formed by the 14 LSBs and *n* is the exponent formed by the 2 MSBs.

- *CB raw DUAL_READ* – a raw uncorrected image obtained using a dual read mode where each pixel value is represented twice – for lo and hi gains.
- *CB raw DYNAMIC_GAIN* – a raw uncorrected image obtained using a dynamic gain mode where each pixel value is represented only once and the gain is determined from the 15th bit as mentioned above.
- *Unsgnd 16-bit, Split – Hi* – a raw uncorrected image obtained using a dual gain mode, but only the hi gain pixel values are present.
- *Unsgnd 16-bit, Split – Lo* – a raw uncorrected image obtained using a dual gain mode, but only the lo gain pixel values are present.

Displaying images in non-standard formats

Images in the *2MSBs format* are displayed correctly by ViVA which interprets the values as defined above. Other formats are displayed as if they are 16-bit unsigned data format. This is actually only 'wrong' for the *CB raw DYNAMIC_GAIN* format, in which case those pixels obtained in hi gain are displayed as the 14-bit value + 16384.




Note: Many ViVA arithmetic operations are handled correctly for these formats including the *2MSBs format*, but NOT the *CB raw DYNAMIC_GAIN*. When operations are not available for a particular format the menu item is disabled (grayed).

Edit Menu & Preferences

The *Preferences* dialog can be displayed via the **Edit|Preferences**. This dialog box, shown in the following figure, contains certain settings which are maintained between different launches of ViVA.

Figure 6-7 Preferences Dialog Box



These settings are saved in the text file *viva.ini*, in the same directory as the application executable *viva.exe*. The available settings following the groupings in the dialog are as follows:

Connection Attributes

The *Host Computer* and *Cmd Processor* (Command Processor) IP addresses may be set. Some validity checks are done on IP addresses. The previous seven IP addresses are kept in the list box for rapid reselection.

Connection at Startup

Depending upon the selection here, ViVA will attempt to automatically link to the receptor at launch.

Gray Levels

User preferences for the display of pixel values in fluoroscopy and radiography modes. By default large pixel values are white in the image and small values black.

As referred to above under **Saving Images**, pixel values are scaled by default when saving as tiff images. This selection allows the user to turn this feature off if required.

White Area Blanking

Activate and select white area blanking threshold and replacement values. More information is given on **White Area Blanking** in the description of the **Edit W/L** dialog in the **Edit Toolbar** section below.



Note: Certain selections such as White Area Blanking and Window/Level Mapping, appear to be duplicated in the **Edit W/L** dialog. The distinction is in applicability. Choices made in the **Preferences** dialog apply to all images opened *subsequently*. Choices made in the **Edit W/L** dialog applies to the currently selected image only.

6

Window/Level Mapping

Here you may choose how the pixel values are mapped to gray levels in the display. Options are **Linear**, **PseudoFilm**, **Non-Linear (A-tan / S-curve)** or **GammaCurve**.

When **GammaCurve** is selected the **Set Gamma Curve Default** button is active and allows you to customize the gamma curve as approximated by a multi-linear mapping function.

These settings are saved and used whenever an image is opened from a file or retrieved from the CP. They are not applied to any images already open.



Note: More information is given on **Window/Level Mapping** in the description of the **Edit W/L** dialog in the **Edit Toolbar** section below.

Save Between Sessions

Certain settings may be saved between sessions (ViVA launches) including **Main Window Size/Position**.

If **Use Saved System Settings** is checked, then options such as **Offset Corrections** and **Gain Corrections** will be set from the settings saved in the *viva.ini* file. If unchecked, existing system settings in the Command Processor will be used.

The **Recently Used File List** determines the maximum number of file paths saved for rapid access from the **File** menu, and may be set up to a limit of 16.

The **Thumbview Size** in screen pixels may be adjusted.

The **Pane Overfill Option** allows the user to specify how the magnification is chosen when an image is first displayed in an image pane. By default this is set to 100% meaning that the whole image is always displayed and the maximum magnification is chosen subject to this requirement. Setting this value to a smaller % may result in a larger magnification being chosen, at a cost of some portion of the image not being displayed.

Edit Toolbar & Image Manipulation

The **Image Edit** (left-vertical) toolbar provides controls for cursor selection, window/level adjustment as well as a button for display of ROI statistics.

Cursor Functions

This section describes the five-cursor types currently implemented in the ViVA **Image Edit** toolbar.

For all the cursor types, the (x, y, value) for a pixel is displayed in the bottom corner of an *Imageview* window. The image pixel corresponds to the point under the active spot on the cursor. The different cursor types are described in Table 1 below.

Table 6-1 Cursors






Click	Result
	Standard Selection: Used for view selection (click on the view) and for drag and drop of images between views.
	<p>Zoom: Allows the user to zoom in on an image by clicking the left mouse button on the view. If the magnified image is larger than the view window in either direction, the point on which the user clicks will jump to the center of the window. To zoom out, click the right mouse button (for a context menu click and hold the right mouse button for approximately one second).</p> <p>This same functionality is available when the standard selection cursor is in use and the user holds down the <i>Shift</i> key while clicking.</p> <p>ViVA only zooms in factors of two. This maintains the most direct relationship between the image pixels and the screen pixels. The range of magnification is from 1/128x to 32x.</p>
	Magic Window: Clicking and holding down the left mouse button on an Imageview window will display a moveable window in which the same image is viewed at twice the underlying resolution.
	<p>Pan: When this cursor is selected, clicking and dragging with the left mouse button on an Imageview window will cause the image to move around (i.e., pan) within the window.</p> <p>This same functionality is available when the standard selection cursor is in use and the user holds down the <i>Control</i> key while clicking the right mouse button.</p>






Table 6-1 Cursors

Click	Result
	<p>Region of Interest: The cursor can be used to specify a region on an image for statistical calculations. The options in the Analysis menu and the ROI Stats... button on the Image Edit toolbar also become active. If a region had been previously specified, it is displayed again on the image.</p> <p>Note: When this cursor is <i>not</i> selected, the ROI Stats... button becomes Img Stats..., and statistics for the whole image can be displayed by clicking it.</p>

Mouse and Key Shortcuts

Shortcut keys or “hot” keys provided in ViVA are summarized in the following table.

Table 6-2 Shortcut Key Combinations

Operation	Cursor	Key Combination
Selection/drag and drop	Any	Left mouse click
Zoom in/out		Shift + left/right click
Pan		Ctrl + left click
Specify a region of interest and show statistical information.		Ctrl + drag with left mouse button
Specify a region of interest constrained to be square.		Shift + drag with left mouse button
Change window/level using the mouse. Moving the mouse left/right results in decrease/increase of the window. Moving the mouse down/up results in decrease/increase of the level.		Ctrl+Shift + left mouse button down

6

Context Menus

ViVA provides three context menus that apply on three different types of images: *Thumbview* images, *Imageview* images normally (**Acquisition** toolbar present), and *Imageview* images in **Defect Map Editor** mode.

To activate a context menu of an image, point the mouse cursor at the image and click right mouse button. When the **Zoom** cursor is selected, hold the button for about one second. The contents of the menus are shown in the following figures:

Figure 6-8 Context Menu for Thumbview




Figure 6-9 Context Menu for Imageview (Normal Mode)



Figure 6-10 Context Menu for Imageview in Defect Map Editor Mode





Note: When the **Zoom** cursor is active the right mouse button is also used to zoom out; the shortcut menu can be displayed by holding the right mouse button for about a second.

Nearly all context menu items are duplicated and described elsewhere.

Window/Level Scroll Bars

ViVA displays 16-bit images to displays which are commonly 8-bit. The window/level controls select the range of pixel values of interest to the observer and how pixel values are mapped to the more limited number of gray levels which is discussed further below.

Window and level can be changed in several ways using controls on the **Image Edit** toolbar. Window/Level control is the only form of image manipulation that can be applied to Thumbview windows. Window/Level settings are maintained during drag and drop operations.

There are two scroll bars in the Image Edit toolbar that can be used to change window and level. By default the left scroll bar controls the window and the right the level. Optionally (using the **Edit W/L** dialog), they may be set to control the bottom (left scroll bar) and top (right scroll bar) of the window. When bottom/top are being controlled by the scroll bars, holding down the *Shift* key while manipulating either scroll bar causes the scroll bar buttons to move up and down together, which corresponds to changing the level while keeping the window fixed.

When an image opens ViVA performs a number of operations. It uses an algorithm to attempt to determine the most likely window and level settings that will work well for the image. It also sets the range of the scroll bars so as to allow access to all pixel values in the image. In some cases it may be desirable to reduce the range and increase the sensitivity of the scroll bars.

The range of the scroll bars may be modified for finer control where needed by the two buttons beneath the scroll bars. Both buttons operate on both scroll bars as follows:



Decreases the range of both scroll bars by a factor of 2.



Increases the range of both scroll bars by a factor of 2.

The center point of each scroll bar's range will, where possible, track the current setting.

Auto & Invert W/L

Auto W/L button




Clicking this button applies the same automatic window/level algorithm that is used when images are opened or acquired. It has the effect of resetting any changes to window/level that have been made manually, and also resetting the scroll ranges to their initial values.

Edit W/L Dialog



Clicking **EWL (Edit W/L)** button opens a dialog box which allows the user to adjust a number of settings relating to the selected image. There are some exceptions as noted below where settings are remembered for future images also. The dialog is shown in the following figure.

Figure 6-11 Edit Window/Level Dialog



Edit Values

As noted above most of the settings in this dialog apply only to the selected image. The exception to this is how the scroll bars are used. They may be used either as **Bottom/Top** or **Window/Level**. The relationship between bottom(bot)/top and window(win)/level(lev) is:

$$\text{win} = \text{top} - \text{bot}$$

$$\text{lev} = \frac{(\text{top} + \text{bot})}{2}$$

If required, actual values for the bottom/top or window/level may be typed into the appropriate edit box and applied to the selected image only.

The check box ‘**Turn off Auto W/L..**’ turns off the automated window/level feature in ViVA and simply opens all future images with the current values of window and level.

Window/Level Mapping

All possible pixel values are mapped to a gray level—typically 0-255—and are stored in a lookup table (LUT). When an image is displayed the appropriate gray level is selected from the LUT for each pixel. By default the relationship between pixel values and gray levels is linear; however, other options also exist and all are described next:

- **Linear:** A linear relationship exists between the gray level (gry) and the pixel value (pix); i.e.

$$\text{gry} = \text{mxgry} * \left(\frac{\text{pix} - \text{bot}}{\text{top} - \text{bot}} \right)$$

If this equation yields a value of gry greater than the maximum number of gray levels (mxgry = 255 typically) then the value of gry is held at mxgry; negative values are clipped at zero.

- **PseudoFilm:** This is intended to simulate a film response and can be tailored by the user if desired. The relationship is:

$$\text{gry} = \text{mxgry} * (1 - \exp((-X)/Y))$$

There are two user defined values which control the behavior of this equation.

Presently these are only settable by manually editing the viva.ini file. They are: “PseudoFilmConstant”(pfc) and “PseudoFilmScalePcnt”(pfs*100) found in the [GammaSettings] section. In the above equation, the exponential numerator is given by:

$$X = \text{pix} - \text{pfs} * \text{bot}$$

and the denominator by:

$$Y = \text{pfc} + \text{pfs} * (\text{top} - \text{bot})$$

Any negative values (for pixel values below bot) are replaced by zero. The main control is exerted by the denominator Y. The default is to set pfs=0.67 (67 in the viva.ini file) and pfc=0. In this case window/level settings behave normally. Setting pfs=0 and putting in a value for pfc, e.g.500, will result in a fixed response curve independent of the window/level settings. Intermediate behavior may be obtained by setting both parameters to non-zero values. If both parameters are set to zero then the default values are applied.


- **Non-Linear (ATan/S-curve):** This is based upon the trigonometric arctangent function. For each pixel value we calculate a value gval given by:

$$\text{gval} = 0.5 + (1/\pi) \left(a \tan \left(2 * \frac{(\text{pic} - \text{lev})}{\text{win}} \right) \right)$$

The values of gval obtained from this equation always lie within the range 0-1, but the actual range is generally smaller depending on the values of win and lev. A linear transformation is applied to gval such that the maximum range of possible pixel values produces the maximum range of possible gray levels.


The above three responses are illustrated in the following figure for particular values of window and level settings.

Figure 6-12 Gray Level Mappings for Linear, PseudoFilm and Atan/S-curve



- **GammaCurve:** One additional gray level mapping option is available. This allows the user to graphically set the desired curve as approximated by multiple linear sections. Clicking on the button “Set Gamma Curve” opens a dialog box where the gamma curve can be set by dragging markers along lead lines. The larger (red) markers are interpreted as bottom and top.

Figure 6-13 Gamma Curve Adjustment Dialog



White Area Blanking

When only a relatively small part of the image is of interest and a substantial part of it was non-absorbing to X-rays, resulting in an expansive white area, white level blanking may be useful.

When activated, the white level blanking function allows the user to specify a threshold value above which lookup table values are replaced with the replacement value. The result is an overall image in which the surrounding white areas do not detract from the region of interest. The net effect of the threshold and replacement values will depend on which window/level mapping is selected, as well as the bottom/top values. Changes made will be applied only to the selected image.

Acquisition Menu/Toolbar

Communication Link

ViVA may be used to control a number of receptors. Its original mission was to control receptors which use a separate Command Processor (CP) box, and communication is then via the CP by means of the ethernet link. The following discussion makes this assumption though in some cases where there is no CP, communication may occur differently. Whatever the physical attributes of the receptor, the open link command has the effect of establishing communication between ViVA and the receptor, and performing any necessary initialization actions.

The functions in the **Acquisition** menu are designed to control the PaxScan Command Processor and to obtain data from it. This menu is shown in the following figure as it would appear with no link open:

Figure 6-14 Acquisition Menu

System Settings...	F1
Mode Settings...	F2
Offset Calibration	F3
Gain Calibration	F4
Extended Gain Calibration	
Acquire Image	F5
Reset State	F6
Retrieve Image	F7
Transmit Image	F8
Open Ethernet Link	F9
Check Ethernet Link	F11
Reset Link	F12
RadAutoSave	
Hardware Handshaking	

6

A subset of these functions is placed on the **Acquisition** toolbar for quick access. Before any acquisition activity a link must be opened which establishes communication over the ethernet link to the receptor. Only one instance of ViVA can link to the Command Processor at any given time.



Note: Before attempting to open a link to a Command Processor system ensure that IP address settings in the Preferences dialog have been set as appropriate.

The **Acquisition** toolbar as it appears with no link open is shown in the following figure:

Figure 6-15 Acquisition Toolbar without link open



The dropdown box called *Acquisition Mode* serves dual purposes. When no link to a receptor is open, the dropdown box may be used to send the open link command as indicated in the figure; alternatively the open link command may be selected from the **Acquisition** menu. When a link is open it appears as follows where the mode name in use appears in the dropdown box:

Figure 6-16 Acquisition Toolbar with link open



When a link is open, the **Acquisition** Mode dropdown box may be used to select a mode if the receptor configuration provides multiple modes. The buttons are shown enabled with the link open which is typical, but note that the **Transmit Image** button is only enabled when an image is selected.

The Open/Close link options in the **Acquisition** menu are dynamically labeled so that only the appropriate options are displayed and functional. For example, after an Ethernet link is open:

■ **Open Ethernet Link** is changed to **Close Ethernet Link**

To check the status of the communication link between ViVA and the Command Processor, choose **Acquisition|Check Ethernet Link**. To terminate the communication link, choose **Acquisition|Close Ethernet Link**.

The Command Processor can be reset to a known state by choosing the **Acquisition|Reset State** option. The system will return to the default operating mode, which is the first mode in the **Acquisition Mode** selection list.



Note: If the connection is lost and the system is not in synchronization with the Command Processor, choose **Acquisition|Reset Link** to permit the restart of communication without terminating ViVA. This command will close all links and clears all information obtained from the Command Processor. Choosing **Acquisition|Open Ethernet Link** will establish another link.

Image Acquisition

To initiate image acquisition, select **Acquisition|Acquire Image** from either the toolbar or menu. Once the acquisition is complete, the user may capture an image from the selecting **Acquisition|Retrieve Image** from either the toolbar or menu. In Radiography modes, the image is retrieved automatically. The dialog shown below opens which allows the user to input comments and other technique information:

Figure 6-17 Image Info: User Input

VIVA - Image Info: User Input

Image Name: Retrieved-Image-02

Comments:

Technique info

Tube voltage: kVp Tube current (time): mA

SID: cm Filtration:

Dose: mR/min

☐ Do not display this dialog box for future image retrievals
(Use "View | Reset User Message" to reset this option)

Cancel Apply OK

This information may also be entered or edited later using the **View|Image Information** command.



Note: This dialog may be turned off for future image retrievals if required by checking the '**Do not display..**' check box and then clicking 'OK'.

Previously retrieved images may be sent to the output buffer of the Command Processor, where it takes the place of the last image acquired. First, select the required image by clicking on it in the ViVA interface, then select **Acquisition|Transmit Image**.

Offset & Gain Calibration

Correcting for non-uniform pixel response is essential to obtaining good quality images. Offset calibration must be performed whenever the CP is powered up and generally it is desirable to perform offset calibrations regularly during use for optimum results. Gain calibrations need not be performed nearly so often, and the last gain calibration for each mode is stored by the CP when powered down.

To initiate Offset or Gain calibration, choose **Acquisition|Offset Calibration** or **Acquisition|Gain Calibration** from the menu; offset calibrations may also be initiated from the toolbar.

6

Offset calibrations are completely automated, and require no further user intervention to complete. Gain calibrations require X-ray exposure with no object in the beam. Simply follow the on-screen prompts, and expose when prompted to do so. Rad modes allow the user to expose multiple times to allow statistical averaging of the gain image.

Offset & Gain Calibration with 3030CB / 4030CB Receptors

3030CB / 4030CB receptors provide dual gain modes. Calibration is accordingly more complicated. Offset calibrations remain autonomous, but for dynamic gain modes multiple calibrations occur; a second 'forced low-gain' calibration is performed in addition to the normal one (which always occurs at high gain for all pixels in the absence of X-rays). For dual read modes, a single calibration provides offsets in both gain settings.

Gain calibration requires the same offset operations as above for dark field acquisition followed by flat-field acquisition with x-ray settings appropriate for each gain.



Note: Gain calibration should always be done at count levels low enough to avoid any possible saturation, but high enough to achieve good statistical measurement of pixel response. For 14-bit receptors an offset-corrected value in the range 1600-4000 is suggested.

The onscreen prompts guide you through the process with onscreen prompts such as that in the following dialog:

Figure 6-18 Gain calibration dialog

Gain Calibration - 4030 CB - 2x2 Dual Gain

Set x-ray exposure level for HI_GAIN calibration then press 'Start'

Calibration Statistics

	HI_GAIN	LO_GAIN
Gain Median:	0	0
Gain Sigma:	0	0
Gain Scaling:	N/A	N/A
Offset Median:	0	0
Date/Time:	01-JAN-81, 00:00	

Start Finish Cancel

Gain Ratio Calibration

The **Acquisition|Gain Ratio Calibration** command invokes an additional calibration which is available only in dual read modes which requires a single X-ray exposure adjusted not to saturate at either gain. This allows calculation of the gain ratio.

Figure 6-19 Acquisition menu – dual read modes

System Settings...	F1
Mode Settings...	F2
Offset Calibration	F3
Gain Calibration	F4
Gain Ratio Calibration	
Acquire Image	F5
Reset State	F6
Retrieve Image	F7
Transmit Image	F8
Close Ethernet Link	F9
Check Ethernet Link	F11
Reset Link	F12
RadAutoSave	
Hardware Handshaking	

Extended Gain Calibration

The **Acquisition|Extended Gain Calibration** command invokes an additional calibration which is available only in dynamic gain modes which requires multiple exposures at differing X-ray levels.

Figure 6-20 Acquisition menu – dynamic gain modes

System Settings...	F1
Mode Settings...	F2
Offset Calibration	F3
Gain Calibration	F4
Extended Gain Calibration	
Acquire Image	F5
Reset State	F6
Retrieve Image	F7
Transmit Image	F8
Close Ethernet Link	F9
Check Ethernet Link	F11
Reset Link	F12
RadAutoSave	
Hardware Handshaking	

6

This command brings up the following dialog:

Figure 6-21 Extended Gain Calibration dialog

Extended Gain Calibration

Gain Ratio

Current Value: 7.600

Calibration Statistics - Xray Level 2

	DYN_GAIN	FRC_LO_GAIN
Median:	0	0
Sigma:	0.000	0.000
Zero Pix Count:	0	0
Date/Time:	31-DEC-1969, 16:00	

Acquire LO_GAIN flat field --- Xray intensity should be set so that all pixels switch to LO_GAIN.

Acquisition Settings

# of cycles: 2	<input type="radio"/> Offset	DONE
# of frames: 32	<input type="radio"/> Xray 1	
	<input checked="" type="radio"/> Xray 2	REQUIRED
	<input type="radio"/> Xray 3	REQUIRED

Acquire

Calibrate

Cancel


This calibration is similar to other gain calibrations except for the multi-dose level requirement. It provides prompts as to the X-ray level required depending on the button selection in *Acquisition Settings*. As acquisitions are done it steps through the different Offset and X-ray levels but the user may choose to do the acquisitions in another order just by clicking the appropriate button at any time. All levels except X-ray1 are required before the *Calibrate* button is enabled. X-ray1 is used only for the gain ratio determination which is needed infrequently.

This calibration actually involves switching between normal and forced lo-gain states for each Xray level. It may be more accurate to acquire data by switching back and forth several times, and the *# of cycles* field allows this parameter to be set. calibration statistics when available are show for the selected Offset or X-ray level.

System Settings

The **Acquisition|System Settings...** command operates slightly differently in K.04 ViVA with 3030CB / 4030CB support. Normally this command is not enabled when no link is open. For 3030CB / 4030CB systems, however, it is enabled and brings up the following dialog:

Figure 6-22 System Settings – No Link Open




The image shows a 'System Settings' dialog box. At the top, there is a label 'Imager Serial Number:' followed by a dropdown menu showing '1234_VivaHelp'. To the right of the dropdown are two buttons: 'New...' and 'Remove'. Below this, there are two main sections. The left section is titled 'Receptor Information' and contains two sub-sections. The first is 'Receptor Size:' with two input fields labeled 'X' and 'Y', containing the values '1536' and '2048' respectively. The second is 'Pixel Value Range:' with a single input field containing '0 - 131071'. The right section is titled 'Image Corrections' and contains three checked checkboxes: 'Offset Corrections', 'Gain Corrections', and 'Pixel Defect Map'. At the bottom of the dialog are three buttons: 'Cancel', 'Apply', and 'OK'.

The dropdown box labelled 'Imager Serial Number' allows a selection to be made among available receptors in the IMAGERs directory. However, if the receptor configuration loaded into the Command Processor has a serial number set, then this selection is overridden and the one that will be used is the one in the receptor configuration file.

When there is an open communication link to the Command Processor, the **Acquisition|System Settings...** command is active; it brings up the following dialog:

Figure 6-23 System Settings – Link Open



6

On the left side of the dialog box, unchangeable information about the system is displayed. On the right side are **Image Corrections** settings. These check boxes allow the user to select which image correction algorithms are applied in the Command Processor.



Note: If the Command Processor has an optional ABS video board, the dialog box will include the **ABS Board** group not displayed in Figure 19, which includes an additional correction algorithm and vertical/horizontal reversal check boxes.

Mode Settings

With an open communication link, the **Acquisition|Mode Settings...** command is active; it brings up the Mode Settings dialog.

At the top of the dialog box is a selection list for the operational mode. The rest of the settings shown in the dialog box apply only to the selected mode. The Mode Settings dialogs are shown in the following two figures:

Figure 6-24 Mode Settings – Fluoroscopy modes

VIVA - Mode Settings

Current Mode: 4030 CB - Fluoroscopy

Information Acquisition Type: Fluoro/Continuous Frame Size (horizontal x vertical): 1024 x 768 Binning Mode (horizontal x vertical): 2 x 2 Analog Gain: 2.000 <input type="checkbox"/> User Sync Frame Rate: 30.000 fps Max Allowed Frame Rate: 30.000 fps Low Noise/Fast Scan: Low Noise (DCDS on)		Acquisition/Display <input type="checkbox"/> Last Image Hold Recursive Filter Percent (0 - 99%): 0 Scaling Type: <input type="checkbox"/> Up <input type="checkbox"/> Down Target Value (100 - 16000): 2000	
Calibration Setup <input type="checkbox"/> Automatic Offset Calibration Number of Calibration Frames (1 - 1,024): 128 Minimum Delay (20 - 3,600 seconds): 300 Post Exposure Delay (1 - 360 seconds): 120 Offset Calibration Shift: 0		Gain Settings Pixel Saturation Value: 16383 Pixel Replacement Value: 16382	

OK Apply Cancel

Figure 6-25 Mode Settings – Radiography modes

VIVA - Mode Settings

Current Mode: 4030A V95 - Radiography

Information Acquisition Type: Rad/Accumulation Frame Size (horizontal x vertical): 2048 x 1536 Binning Mode (horizontal x vertical): 1 x 1 Analog Gain: 1.000 <input type="checkbox"/> User Sync Frame Rate: 7.500 fps Max Allowed Frame Rate: 7.500 fps Low Noise/Fast Scan: Low Noise (DCDS on)		Acquisition/Display Acquire with valid x-rays for all frames Frames to Accumulate (1 - 255): 1 Scaling Type: <input type="checkbox"/> Up <input type="checkbox"/> Down Target Value (100 - 16000): 8000	
Calibration Setup <input type="checkbox"/> Automatic Offset Calibration Number of Calibration Frames (1 - 1,024): 4 Minimum Delay (20 - 3,600 seconds): 300 Post Exposure Delay (1 - 360 seconds): 120 Offset Calibration Shift: 100		Gain Settings Pixel Saturation Value: 16383 Pixel Replacement Value: 16382	

OK Apply Cancel

Information

Informational settings are not changeable except for the frame rate and user sync.

Calibration Setup

The user may specify the number of frames used during calibration and the settings for the optional automatic offset calibration. In addition provision is made for an offset calibration shift to be applied during offset calibrations. This will add a fixed offset to every pixel in the whole image if changed from the zero default.

Acquisition/Display

This group shows different settings depending on whether a mode with fluoroscopy (continuous) acquisition or radiography (accumulation) acquisition type is selected.

For a fluoroscopy mode: the user can set the recursive filter fraction.

For a radiography mode: the user can choose between letting the system automatically sense X-rays start manually. Acquisition modes subdivide further by whether the user wishes to have a predetermined number of frames accumulated (summed) or control stop manually. The **Scaling Type** option allows the final image to be scaled to bring median pixel values near the target value. When **Up** is checked scale factors greater than 1 are allowed; when **Down** is checked scale factors less than 1 are allowed. If both scaling options are selected, the resultant image may be scaled up or down, and if neither is checked no scaling occurs.

6

Gain Settings

These allow the user to set a **Pixel Saturation Value** above which pixel values will be replaced by the **Pixel Replacement Value**.

Rad AutoSave

This command allows the user to set up a file path and “base” name which is used when making Rad mode acquisitions. Each time Acquire Image is pressed the image is automatically retrieved and saved. For example if the base name is “radauto” the first acquisition might result in a file “radauto__001.viv”.

Hardware Handshaking

When the hardware configuration permits an X-ray valid signal to be sent to the command processor, this menu item should be checked so that ViVA does not attempt to send the corresponding software handshaking calls.

Video Menu/Toolbar

ViVA K.04 supports operation with only *Bitflow* frame grabber cards. Currently the *R3-PCI-DIF* is supported for use with the standard (CP1) Command Processor. A camera link card is also supported for use with CP1B. During installation an option is given to install the Bitflow support software.

Rad Modes

Most of this *Video Menu/Toolbar* section is applicable only to Fluoro modes of operation. ViVA automatically takes advantage of the frame grabber where available to speed retrieval of rad images immediately after acquisition into a new thumb pane; this is faster and more convenient than retrieval over the ethernet connection. The **Record Sequence** command will remain inactive in Rad modes. All rad acquisitions must be initiated using **Acquire Image**.

Recording Sequences




Note: This and following sections are applicable to Fluoro modes only.

Once the frame grabber and its associated driver/software libraries are properly installed, ViVA can record sequences in any Fluoro mode.

The **Video** toolbar is by default docked at right side of the ViVA window. The following figure shows the **Video** toolbar with annotations to show what each button does:


Figure 6-26 Video Toolbar



Many of the buttons also have duplicate commands in the **Video** menu. With the frame grabber installed and a Command Processor link established, the **Record Sequence** button becomes active (on a color monitor it will be green with a red border).

ViVA uses two 'grab' image buffers to which the frame grabber has Direct Memory Access (DMA). ViVA also sets up a number of 'sequence' or 'copy' buffers to which data are copied during the live data acquisition. The length of the sequence that can be recorded depends upon how many sequence buffers are allocated which in turn is limited by the physical memory (RAM) present on the computer. By default, while recording, ViVA will copy frames continuously into the sequence buffers in a circular manner overwriting the first frame once the last buffer is filled. The first time after each launch that the **Record Sequence** button or menu item **Video|Record Sequence** is selected, a dialog box will appear. This dialog can also be opened at any time from **Video|Allocate Buffers...**, and is shown in the following figure:

Figure 6-27 Allocate Buffers Dialog Box



6

The *Number of Frame Buffers* which as mentioned above determines the length of sequence that can be captured. The number that can be allocated is limited by available memory.

Once acquisition begins, frames are displayed in a *Thumb View* pane which can be dragged and manipulated like a normal image pane. However, the overlay showing certain image information is not available during capture. The acquisition may be stopped by the **Stop Sequence** command from either the toolbar or menu.



Note: During recording ViVA will apply its automatic window/leveling routine only if the overall image brightness changes significantly. If you want to avoid any automatic window/leveling activity, set the levels you want using **Edit W/L...** in the **Image Edit** toolbar. ViVA will not change them again as long as the pane remains open.

Playing Sequences

Once a sequence is in memory, it may be played back by the **Play Sequence** menu or toolbar item. When playing back the playback speed defaults to the recorded speed but may be varied using the up/down arrow buttons. These vary the speed by factors of 2. The actual speed obtained may be limited if it is not possible to repaint the screen quickly enough. This will be influenced by various factors such as the processor speed, screen resolution, pane size and number of panes displaying the video. The sequence may also be stepped one frame at a time from the toolbar.

More Video Options: Video Menu

Some of the items in the **Video** menu have already been discussed. This section will describe the remaining selections. The **Video** menu is shown in the following figure as it would appear with a sequence already loaded in memory, a link to a command processor open and a frame grabber card properly installed:


Figure 6-28 Video Menu



Load Video Sequence...

This command allows a saved video sequence (.seq file) to be loaded into memory. A dialog - as shown in the following - will open to allow a subset of the entire file to be opened as required:

Figure 6-29 Sequence Subset Info






Note: Depending on the amount of RAM on the computer and the length of the sequence file, the segment you can open may be limited to less than the whole file.

The **File|Open...** command may be used instead of **Video|Load Video Sequence...**; the only difference is that in the latter case the only file filter available is *.seq*.

Save Video Sequence...

This command is equivalent to **File|Save As...**, and allows a sequence in memory to be saved. The first dialog to open is similar to that in Figure 25, allowing a subset of the entire sequence to be selected if required. Subsequently a file save dialog will open, and the sequence may be saved as either a *.seq* file or as a *.avi* file. The *.seq* saves the image data in an uncompressed 16-bit format with the same header as is used for *.viv* files. The *.avi* format is a standard format that can be played for example on *Microsoft Windows Media Player*. If the *.avi* file filter is chosen another dialog will open as shown below:

Figure 6-30 Set AVI Quality



6

Files stored as *.avi* store the data in a lossy compressed 8 bit format using the window/level selected. The AVI quality setting determines how much compression is applied, trading file size for quality. The frame rate is also selectable in case the user would like to play back the AVI at a different speed from that recorded.

Get Frame from Sequence...

This command simply gets an individual frame and displays it in a new *Thumb View* pane.

Capture first N frames

This option allows the user to turn off the feature whereby frames are recorded in circular fashion - overwriting the first frames captured when all the sequence buffers are filled. When this item is checked, capture stops after all the buffers are filled. The 'N' may be replaced by the actual number of buffers allocated in the menu as is the case in Figure 6-27.

Test Image Mode

This allows a test pattern or other image to be retrieved from the command processor; all frames captured are the same. You can for example use **Transmit Image** in the **Acquisition** toolbar to transmit a test pattern for subsequent capture via the frame grabber. After changing modes or powering up the command processor you should, in Test Image Mode, perform the following steps:

1. Press **Acquire Image** in the **Acquisition** toolbar followed by **Stop** in the *Fluoroscopic Acquisition* dialog.
2. **Transmit Image** as required.
3. Press **Record Sequence** and then **Stop Sequence** to capture the image via the frame grabber.



Note: **Test Image Mode** must be used with care. Since it disables commands to run the command processor it is also possible for the command processor and ViVA to get out of synchronization with respect to which mode is operating. If you have **Test Image Mode** selected, you must run the command processor using **Acquire Image** in the **Acquisition** toolbar before running video if you have just powered up or changed modes.

Disable Display During Capture

As indicated this option disables the display update during capture. It will rarely be found useful since ViVA already gives priority to the activity of copying data to the sequence buffers over refreshing the display.

Allocate Buffers...

This dialog is discussed above under **Recording Sequences**.

Initialize Video

This command will not typically be found useful since ViVA automatically initializes the Video if a frame grabber installation exists. However, frame grabbers do not generally permit more than one process (application) to take control at a time. If another application is using the frame grabber when ViVA launches, ViVA will not be able to initialize the video and this menu item will be active provided a link to a command processor exists. This could be useful if you want to switch operation between applications.

Dispose Video

This command causes ViVA to relinquish control of the frame grabber and allows another application to use it.

Reset Video

This command simply combines the **Dispose Video** and **Initialize Video** commands. It may be useful if the frame grabber operation becomes unstable.

Analysis Menu: Image Statistics

ROI Basic

The Analysis menu allows the user to obtain statistical information on a specific region of an image called the *Region Of Interest (ROI)*. Generally the commands relating to the ROI are not active unless the **ROI cursor** is selected (see Table 2).

Except for 2520M receptors, the Edit Toolbar contains a button at the top which is labeled either 'Img Stats...' or 'ROI Stats...'. It will be 'Img Stats' unless the **ROI cursor** is active and an ROI drawn. This button allows statistics for the whole image to be displayed at any time.

An ROI may be selected by clicking the left mouse button anywhere in an image pane and holding while a rectangle is defined. The ROI shows as a blue rectangle overlay which persists after the mouse button is released until a difference cursor is selected or new ROI drawn. Even when not displayed, the last ROI coordinates are remembered and displayed if the **ROI cursor** is reselected. If you attempt to drag outside the image, the rectangle changes to red and snaps to the image border if the mouse is released.



Note: If you hold the **Shift** key while dragging, the ROI will be square.

6

Basic Menu Commands

Analysis|Select Whole Image allows the user to select the whole active image as a region of interest.

Analysis|Clear ROI allows the user to clear the selected ROI.

Analysis|Show ROI Statistics... allows the user to display statistical information. Alternatively this command may be invoked from the **ROI Stats...** button on the **Edit** toolbar or the **ROI Stats...** menu item of the Context Menu for *Image View*. Any of these will result in the dialog shown in the following figure:

Figure 6-31 Region of Interest Statistics Dialog Box

Field Number	Field Description	Value	Checkbox
01	Region of Interest (ROI)	[352, 353] to [487, 430]	<input type="checkbox"/>
02	Width and Height of ROI	136 x 78	<input type="checkbox"/>
03	Center of ROI	[419.50, 391.50]	<input type="checkbox"/>
04	Number of Pixels in ROI	10,608	<input type="checkbox"/>
05	Number of Defective Pixels in ROI	0 (00.00%)	<input type="checkbox"/>
06	Percent of ROI/Image	01.35%	<input type="checkbox"/>
07	Signal/Noise Ratio in ROI	3.831	<input type="checkbox"/>
08	Maximum Pixel Value in ROI	713 @ (361, 382)	<input type="checkbox"/>
09	Minimum Pixel Value in ROI	149 @ (482, 430)	<input type="checkbox"/>
10	Total of Pixel Values in ROI	5884755	<input type="checkbox"/>
11	Average of Pixel Values in ROI	554.747	<input checked="" type="checkbox"/>
12	Standard Deviation in ROI	144.793	<input checked="" type="checkbox"/>
13	Standard Deviation of Row Means	117.552	<input type="checkbox"/>
14	Standard Deviation of Col. Means	49.645	<input type="checkbox"/>

<<<Check boxes select fields that will be output if you use the RoiList Feature>>>

Buttons: Histogram, Image, Text, Print, Apply, Close



Note: The user can also immediately obtain this information after drawing a region by holding down a **Ctrl** key while dragging the mouse. The **Ctrl** key must be pressed and held down before dragging to specify a region of interest.

ROI Dialog

The region of interest may be redefined by entering two new diagonal points of a new region directly into the field **01** edit boxes. The **Apply** button causes recalculation of all statistical information using the current two points specifying a region.

There are four buttons which provide for additional output:

- The **Histogram** button performs a histogram analysis of the pixels in the ROI and puts the output into a tab-delimited text file. (Tab-delimited text files may be conveniently imported into *Microsoft Excel* using the file open text filter and accepting defaults.)
- The **Image** button allows the ROI to be saved in an image format.
- The **Text** button allows saving the ROI pixel values to a text file formatted in rows and columns as in the ROI. Again it is tab-delimited for convenient import to *Microsoft Excel*.
- The **Print** button simply outputs the statistical information from the dialog to a printer.

The statistical information provided on this dialog box is explained in the following table:

Table 6-3 Region of Interest Statistical Information

	Name	Format	Description
01.	Region of Interest (ROI)	(x_0, y_0) to (x_1, y_1)	Two diagonally disposed points that define the ROI rectangle.
02.	Width and Height of Region	integer x integer	Width and height dimensions of the ROI.
03.	Center of ROI	(x, y)	Center location of the ROI.
04.	Number of Pixels in ROI	integer	Number of pixels found in ROI.
05.	Number of Defective Pixels in ROI	integer	Number of defective pixels found in the ROI. These are pixels with the 65535 value that ViVA interprets as defective.
06.	Percent of ROI/Image	real	Percent of the region over the whole image.
07.	Signal/Noise Ratio in ROI	real	Defined by formula average/standard deviation.
08.	Maximum Pixel Value in ROI	integer @ (x, y)	Maximum pixel value first found in the ROI.
09.	Minimum Pixel Value in ROI	integer @ (x, y)	Minimum pixel value first found in the ROI.
10.	Total of Pixel Values in ROI	integer	Total of all pixel values found in the ROI.
11.	Average of Pixel Values in ROI	real	Average of pixel values found in the ROI.
12.	Standard Deviation in ROI	real	Standard deviation of pixel values in the ROI.
13.	Standard Deviation of Row Means	real	Standard deviation of the mean values of the rows.
14.	Standard Deviation of Column Means	real	Standard deviation of the mean values of the columns.



Note: The coordinates (x, y) of a point and the dimension width by height are limited by the size of an image. Specifically, ranges of a pair (x, y) are from 0 to $(\text{width} - 1)$ and 0 to $(\text{height} - 1)$, respectively. Pixel values are in range from 0 to maximum pixel value.

RoiList Commands

The *RoiList* commands greatly extend the usefulness of the ROI analysis feature. This feature allows you to set up multiple ROIs and then apply to multiple images. When an ROI is selected you may add it to the *RoiList* by selecting **Analysis|Add ROI to RoiList**. This saves the ROI coordinates and causes the ROI to be displayed as a cyan rectangle. By redrawing the ROI and adding to the *RoiList*, you can select multiple ROIs.



Note: The active ROI is the one in blue and is not necessarily a member of the *RoiList* until you add it. The ROI statistics dialog will always refer to the active ROI.

When an *RoiList* has been established by selecting **Analysis|Add ROI to RoiList** one or more times, it can be applied in a batch-like manner to multiple images. To apply the *RoiList*, select **Analysis|Apply RoiList...**. This will first open a file save dialog box for the output file - again tab-delimited text. If the active image is an individual image - as opposed to a video sequence - another file dialog box will then open. This dialog allows you to select multiple image files. All the images selected must be *.viv* or *.raw* and must have the same image dimensions as the image in the selected image pane. Statistical information will be determined for all the ROIs in the *RoiList* and for each image selected in the file dialog and output to the text file.

The *ROIList* may be saved to and retrieved from a text file (which can be edited if required) using the commands **Analysis|Save RoiList to File...** and **Analysis|Load RoiList from File...**

Notes on ROIList Use:

- If the selected image is a video pane and not an individual image pane, then instead of the second file dialog box you will be asked to select a video segment for processing.
- The actual image in the image pane is not necessarily processed. Only the image files or the video segment selected are processed.
- The output will by default consist of two fields for each ROI: **11. Average of Pixel Values in ROI** and **12. Standard Deviation in ROI**. Notice that in Figure 31 these two fields have checks in the adjacent check boxes. You can select any or all of the fields to be output using the check boxes. (**01. Region of Interest** has no check box but this information is always written to the text file.)
- The status of the check boxes is remembered when the ROI dialog is closed and this defines the fields that are output. ViVA will remember which fields were last selected even between launches.
- The *RoiList* itself is more volatile than the check box information. *RoiList* information is actually specific to each image pane. It will, however, generally be remembered even if you close the image in the image pane. If you attempt to drag an image to the pane that has different dimensions than the one for which the *RoiList* was defined, a message box will warn you that this action forces a *RoiList* reset. All *RoiList* information is lost when ViVA closes (but not the check box information).
- The *RoiList* may be reset at any time by **Analysis|Reset RoiList**.

Tools Menu

The Tools menu is consists of a number of sub-menus each with multiple commands; these will generally consist of the following which are described in detail below:

- **Receptor**
- **Command Processor**
- **Defects**
- **Image Operations**
- **Cone Beam**



CAUTION: Many of the commands in this section are intended for Engineering use and should be used only by experienced users or under the direction of Varian Medical Systems technical staff.

Receptor

6

Analog Offset Calibration

The **Analog Offset Calibration...** command allows the user to change analog offset settings and perform an analog offset calibration. When selected, this option will display an Analog Offset Settings dialog box as shown in the following figure:

Figure 6-32 Analog Offset Settings

VIVA - Analog Offset Settings

4030A V95 - Fluoroscopy

Calibration Parameters:

Target Value (200 - 16,383)	2000
Tolerance (5 - 100)	20
Median Percentage (1 - 100%)	1
Fractional Iterations Delta (0.125 - 0.750)	0.333
Number of Iterations (2 - 25)	10

System Info

Receptor Serial Number:	Not Available
Elapsed Time from Last Calibration:	Not Available

OK Apply Calibrate Cancel

The **Apply** or **OK** button only updates the setting information from the Edit boxes at the Command Processor without performing a calibration. The **Calibrate** button initiates an analog offset calibration. An analog offset calibration runs autonomously; it is an iterative process, and if the target range is reached for all ASICs before completing the limiting number of iterations, it terminates early.



Note: After an analog offset calibration is done, it is essential to perform a gain calibration before images can be properly corrected.

DCDS Enable

The **Set DCDS Off** command allows DCDS to be temporarily disabled which is useful in connection with performing analog offset calibrations. DCDS will turn on again automatically when the mode is changed, or when Offset/Gain calibration is performed.

Command Processor

Display Test Pattern

If ViVA has an open connection to the Command Processor, choosing the **Display Test Pattern** option causes the Command Processor to display a test pattern consisting of eight horizontal bars of equal height, with linear steps in intensity from zero at the top of the image, to 3,584 counts at the bottom. The image size indicated relates to the currently selected mode.

Write ABS MailBox

The Write ABS MailBox... command should only be used under the direction of Varian Medical Systems technical staff.

Transmit Files

The **Transmit Files...** command allows the user to transmit new files to the Command Processor. Currently, ViVA can transmit the following file types:

- System Software file
- Global Control Firmware file
- Receptor Firmware file
- Receptor Configuration Data file
- Base Defect Map Image file
- Gain Calibrated Image file
- Offset Calibrated Image file

The file type to be transmitted should be checked, then browse to the file itself, and click 'Transmit'.

Retrieve Files

The **Retrieve Files...** command allows the user to retrieve a file from the Command Processor. It operates similarly to the Transmit Files function.

Debug Verbosity

Debug Verbosity can be toggled on/off. Turning this option on causes the Command Processor to print debug information over a serial port which can be captured with Hyperterminal for example. Having debug verbosity set to *Off* (default) will improve system performance. In addition ViVA will write a file 'CmdTestLog.txt' to the ViVA directory; it is written when Debug Verbosity is turned off, and any previous file overwritten. It contains a log of calls made by ViVA while Debug Verbosity was on including parameters and return values.

Reset

The **Reset** command sends a command to the Command Processor to re-boot and the link from ViVA is also reset.

Enable IPU

This is a rarely needed, only for specialized receptor configurations.


Defects

Defect Map Editor

The Defect Map Editor is invoked by choosing **Tools|Defects|Defect Map Editor...** This will switch ViVA from image viewing mode to image editing mode. The **Acquisition** toolbar is replaced by the **Defect Map Editor** toolbar.

The Status Bar displays the current mode in the Command Processor. All images in *Image View* are closed and Image Layout is set to Two-Image Layout. ViVA then retrieves the Base Defect Map image and the Auxiliary Defect Map image from the Command Processor and displays them in the *Thumb View* and the *Image View*. The Base Defect Map image is placed in the right pane, and the Auxiliary Defect Map image is placed in the left pane.

Figure 6-33 Defect Map Editor Screenshot



Note: By default, ViVA displays good pixels in black and defective pixels in white.

Pixel Editing

On the leftmost side of the *Defect Map Editor* toolbar is the pixel list which contains all edited pixels as they are marked from good to defective. The list contains only manually-edited pixels. Defective pixels found on the retrieved or open image are not included in the list.

- *With the shortcut menu:* Right click to bring up the shortcut menu. Select **Mark Pixel Defect**. If the pixel is already defective, the word *Defect* will be replaced by the word *Good* in the menu item.
- *With mouse actions:* To mark a good pixel as defective or a defective pixel as good, simply point the cursor at the pixel and click the left button. When a good pixel is marked as defective, the pixel is placed on the pixel list and when a defective pixel is marked as good, the pixel is deleted from the pixel list.



Note: Editing the defect map by direct mouse actions requires that the active cursor be the **Standard Selection**.



- *With keyboard actions:* Similar to the mouse actions, the **Arrow** keys and the **Enter** key can be used to edit a pixel. Use the arrow keys or the mouse to point at a desired pixel. Press **Enter** toggle to the pixel from good to defective, or defective to good.

■ *With the pixel list:*

- ☐ To add a pixel onto the pixel list, select **<Pixel>**, type the coordinates of the pixel in the point form (x,y), then press the *Tab* key to end the addition.
- ☐ To delete a pixel, select the desired pixel, press the *Backspace* key and press the *Tab* key to end the deletion.
- ☐ To change the coordinates of a pixel, select the pixel, edit the x and y coordinates, and press the *Tab* key to end the change.

Row Segment Editing

The second dropdown list in the *Defect Map Editor* toolbar is the row segment list. It contains defective row segments marked in the defect map editor. As with individual pixels, row segments found on the retrieved or open image are not included in the list.

- *With the shortcut menu:* Right click to bring up the shortcut menu. Select **Mark Row Defect**. If the row is already defective, the word *Defect* will be replaced by the word *Good* in the menu item.
- *With mouse actions:* To mark a good row segment as defective or a defective row segment as good, simply point the cursor at the row and then click on the left button while holding down the *Shift* key. When a row segment is marked as defective, the segment is placed on the row segment list and when a defective row segment is marked as good; the segment is deleted from the row segment list.
- *With keyboard actions:* Similar to the mouse actions, the arrow keys and the *Enter* key can be used to edit a row. Use the *Arrow* keys or the mouse to point at a desired row. Then press *Enter* while holding down the *Shift* key to toggle the whole row from good to defective or defective to good.
- *With the row segment list:*
 - ☐ To add a row segment to the row segment list, select **<Row Segment>**, type in the coordinates in the row segment format (x₁,y) to (x₂,y) and press the *Tab* key to end the addition.
 - ☐ To delete a row segment, select the desired row segment, press the *Backspace* key and press the *Tab* key to end the deletion.
 - ☐ To change the coordinates of a row segment, select the row segment, edit the x and y coordinates and press the *Tab* key to end the change.



Note: *ASIC*-wide defects represent a special case of row defects. Some additional commands allow *ASIC*-wide defects to be conveniently marked. From the keyboard press *Shift/A* or from the shortcut menu select **Mark Asic Segment Defect**. *ASIC*-wide defects are listed in the row segment list box.

Column Segment Editing

The third dropdown list in the **Defect Map Editor** toolbar is the column segment list. It contains defective column segments marked in the defect map editor. As with individual pixels and rows, column segments found on the retrieved or open image are not included in the list.

- *With the shortcut menu:* Right click to bring up the shortcut menu. Select **Mark Column Defect**. If the column is already defective, the word *Defect* will be replaced by the word *Good* in the menu item.
- *With mouse actions:* To mark a good column segment as defective or a defective column segment as good, simply point the cursor at the column and click the left button while holding down the *Control* key. When a column segment is marked as defective, the segment is placed on the column segment list and when a defective column segment is marked as good, the segment is deleted from the column segment list.
- *With keyboard actions:* Similar to the mouse actions, the *Arrow* keys and the *Enter* key can be used to edit a row. Use the arrow keys or the mouse to point at a desired row. Press *Enter* while holding down the *Control* key to toggle the whole column from good to defective, or defective to good.
- *With the column segment list:*
 - ☐ To add a column segment onto the column segment list, select **<Column Segment>**, type in the coordinates in the column segment format (x,y₁) to (x,y₂) and press the *Tab* key to end the addition.
 - ☐ To delete a column segment, select the desired column segment, press the *Backspace* key and press the *Tab* key to end the deletion.
 - ☐ To change the coordinates of a column segment, select the column segment, edit the x and y coordinates, then the *Tab* key to end the change.



Note: On the 4030A receptor, because of the split readout, column defects only extend to the midway point of the imager. If the cursor is in the top half of the image, the column defect will be restricted to the top half; or if the cursor is in the bottom half, the column defect will be restricted to the bottom half.

OR Image

To add all defective pixels on the *Auxiliary Defect Map* image on the left *Image View* pane to the *Base Defect Map* image on the right of the *Image View* pane, click **OR Image**. This command is useful when there is an existing image with defective pixels that can be added onto the *Base Defect Map* image. The user simply opens an image as usual, then drags and drops the thumbnail view of the image onto the left pane before adding the two images.

Retrieve

To retrieve a new Base Defect Map image and an Auxiliary Defect Map image, click **Retrieve**. This command deletes any previous changes to the defect maps and allows the user to start editing again without terminating Defect Map Editor mode.

Transmit

To transmit the Base Defect Map image to the Command Processor, click **Transmit**. This moves the image on the right *Image View* pane to the Command Processor and overwrites the current Base Defect Map image with the new one.


Close

To close the Defect Map Editor and switch back to standard ViVA viewing mode, click **Close** on the **Defect Map Editor** toolbar. All images in the *Thumb View* and the *Image View* remain unchanged. The **Defect Map Editor** toolbar is replaced by the **Acquisition** toolbar.

Defect Map Threshold Tool

A simple but effect method for generating a defect map is to set upper and lower thresholds for defects in an acquired flat field image. The Defect Map Threshold Tool is invoked by **Tools|Defects|Defect Map Threshold tool...** This brings up the following dialog box:

Figure 6-34 Defect Threshold Tool



6


The threshold tool operates on the active image - which might be a flat field image - and generates a new *Thumb View* image as its output. The new image will consist of zero pixel values everywhere except where a defective pixel is determined; the value for defective pixels is determined by the **Defect Pixel Value** in the dialog box or 1 for K.01 ViVA. Defective pixels are inferred to be those which have values below the **Lower Threshold** or above the **Upper Threshold**.



Note: It is generally necessary to transmit defect images generated using the Threshold Tool via the Defect Map Editor and NOT by **Tools|Command Processor|Transmit Files...**

ViVA uses the value 65535 as the defective pixel value internally but converts to 1 for transmittal to the Command Processor. When you drag and drop in the Defect Map Editor, ViVA checks the image and if it detects that it consists of only 0 and 1 will convert the 1's to 65535. The following message box is shown when this occurs:

Figure 6-35 Defect Map Conversion Warning




Find Noisy Pixels

The purpose of the **Find Noisy Pixel...** command is to identify pixels that may not appear defective for each and every frame, but over a number of frames fluctuate significantly in intensity. The noisy pixel routine collects a number of frames and attempts to identify noisy pixels statistically as those having a relatively high standard deviation (SD) also referred to as *sigma*. The SD is calculated for each individual pixel or binned grouping, according to the mode. The SD is formed on a temporal, not spatial, basis as would be the case in ROI calculations.

Noisy pixel detection is invoked by **Tools|Defects|Find Noisy Pixels....** Parameters are selected in the top section of the dialog box entitled **Acquisition**, which is shown below:

Figure 6-36 Find Noisy Pixels Dialog



Acquisition

Each cycle will involve the acquisition of the specified number of frames, and the retrieval of the last. This allows the user to spread the actual frames used in the computation out over a larger number of frames, which could be useful if the fluctuations are clustered rather than random.

One frame is retrieved for each cycle.



Note: In order to compute the SD effectively, it is suggested that at least ten cycles be specified. For initial familiarization purposes, five will be adequate. The acquisition may take some time, particularly in modes where no binning is used and will be essentially proportional to the number of cycles. The user may choose to save each individually-retrieved frame to a disk file via the check box. This feature will probably not normally be selected.

To begin acquisition, click **Acquire Noisy Pixel Data**. The user is given the opportunity to save to disk the SD image formed. The SD image is actually the calculated standard deviation scaled by ten to improve precision. A *Thumb View* of the SD image is displayed.

Set Threshold and Display

When acquisition is complete, a threshold can be selected above which pixels are considered defective. Changing the value of the threshold will normally result in a corresponding change in the indicated number of pixels above the threshold. The displayed number is updated whenever the threshold is changed and focus shifted away from the **Set SD Threshold** edit box; e.g., when finished typing, press the *Tab* key.

When the required threshold has been selected, a defect map can be created by pressing **Display Noisy Pixels**.



Note: If this button is clicked when no acquisition is current (i.e. no acquisition done since the dialog box opened), the user is given an opportunity to select a previously acquired SD image from a disk file.

Identifying Noisy Pixels

One method to identify noisy pixels requires the following:

- Exiting the dialog box and inspect the acquired SD image
- Magnify some part of it and look for a featureless (normal) region
- Use the ROI facility to evaluate the average SD and the standard deviation of the SD itself in this region
- Repeat in other areas to get good numbers for the average normal SD and its distribution, as indicated in the standard deviation box of the ROI dialog.

A good choice for the threshold will likely be $\sim 6x$ the standard deviation of this distribution plus the average.



Note: This procedure is roughly that carried out by clicking the **AutoSet** button.

Updating the Base Defect Map

When the required threshold is identified, the **Noisy Pixel** dialog box can be reopened. Data of interest are reactivated by pressing the **Display Noisy Pixels** button, and selecting the appropriate file. Set the threshold and click **Display Noisy Pixels** again to ensure the defect map is created at the required threshold setting.

When the defect map is correct, download it to the Command Processor by clicking **OR With Aux Defect Map** or **OR With Base Defect Map**. This results in the logical OR operation being performed with either the existing auxiliary defect map or the existing base defect map; the result is always a new base defect map




Note: If the threshold value is changed without creating a new map, and then one of the OR buttons clicked, a new map is automatically created prior to updating the base defect map. The result is downloaded to the Command Processor.

Image Operations

Add/Subtract

The **Add/Subtract...** images command allows the user to perform an arithmetic subtraction or addition of two images. This command opens the following dialog box:

Figure 6-37 Image Arithmetic Dialog



Images must be saved files in *.viv* or *.raw* format or *.seq*. ViVA obtains a resultant image by performing a subtraction or an addition on a pixel of a source image and the corresponding pixel of a base image, plus an offset factor. These two images must be the same dimensions. A scale factor may also be applied in the calculation as set in the dialog.

If the option **Use Auto Offset Factor** is checked, ViVA will use the smallest offset that prevents any negative pixel values.




Note: The file names of the forms “Subtracted-Image-*n*” or “Added-Image-*n*” where *n* is a positive integer, are used as temporary files during an image arithmetic operation. Do not name or store any file in these forms under the directory where the executable *viva.exe* is located.

If the source images are single image files, the resultant image is displayed as a new *Thumb View* image. If the source files are *.seq* files then the result is saved to a new file. The *Resultant Image* status box indicates how and where the result is located.

Pixel Editor

This tool may be useful to manually retouch images where there are a small number of pixel defects. The command **Tools|Image Operations|Pixel Editor...** brings up the following dialog:

Figure 6-38 Pixel Editor Dialog



The X and Y coordinates of the pixel to be replaced must be entered into the edit boxes. The *Average Pixels at Displacement* edit box determines how the replacement value is calculated. For example if this value is 1, the 8 nearest neighbors are averaged. For a value 2, the 16 next-nearest neighbors are averaged etc.


Add Offset to Pixels

The **Tools|Image Operations|Add Offset to Pixels...** command simply asks the user to specify an offset value that will be added uniformly to all pixels.

Optimize Auto Level

The **Tools|Image Operations|Optimize Auto Level...** command allows customization of the algorithm used in the **Auto W/L (Image Edit toolbar)** command. To use this effectively it is suggested that a number of varied images be opened. The command opens the following dialog:

Figure 6-39 Optimize Auto Level Parameter Dialog



Briefly the algorithm works by dividing the image into regions and attempting to determine which are likely to be of greatest interest. The regions determined to be of greatest interest are used to form a histogram. The bottom and top of the window are then set at points which truncate a specified % of the histogram area at the low and high ends. The parameters in the dialog box have the following significance:

- *# of regions* - is the total number of regions the image is divided into.
- *# used for histogram* - is the number used finally in determining the window and level settings.
- *# of border regions ignored* - specifies how many regions around the image periphery are precluded from consideration.
- *# of hi/lo regions ignored* - specifies the number of the brightest and darkest regions that are also ignored.
- *% of histogram lo truncated* - the bottom of the window is chosen such that the specified % of the histogram area is below that point.
- *% of histogram hi truncated* - the top of the window is chosen such that the specified % of the the histogram area is above that point.

When **Apply** is clicked, all open images are updated. If **Set defaults** is checked when **Apply** is clicked, then the settings are saved as the future values applied when images are opened or **Auto W/L** executed.



Note: Only certain discrete values are permitted for the parameters and they are interdependent. Changing one parameter may change others.

Apply Recursive Filter

The **Tools|Image Operations|Apply Rec Filter...** command is applicable for video sequences and applies a recursive filter. In this case each pixel value is replaced according to:

$$\text{Pix}[i, n] = a * \text{Pix}[i, n-1] + b * \text{Pix}[i, n]$$

Here the $\text{Pix}[i, n]$ is the i 'th pixel in the n 'th frame. a is the **Rec filter %** expressed as a fraction and $b = 1 - a$.

The dialog box permits setting two values of the **Rec filter %** which are used according to whether movement is detected or not. Movement on an arbitrary scale is calculated based upon pixel differences and compared to the user's threshold value. If the threshold is set to 200, the movement detection mechanism is turned off and only the **Rec filter %** in the top edit box is used. The routine performs a preliminary calculation to determine how many frames incorporate movement and the user is given a chance to adjust the threshold before the recursive filter is actually applied.

Median Filter

The **Tools|Image Operations|Median Filter** command results in the application of a median filter to the selected image. Each pixel (except border pixels) is replaced by the median value of the set of 9 pixels – a 3x3 kernel – for which the pixel in question is the center pixel.



Note: This operation occurs for the selected image and the actual pixel values are modified. It is non-reversible, and an image should be saved before performing this operation if there is any possibility the original pixel information may be needed.

Cone Beam

Generate Scaled Image

The **Tools|Cone Beam|Generate Scaled Image** function is available when the pixel data format of the selected image is *2MSBs are exponent*. It operates on the pixel values in memory, and cannot be reversed. The result of the operation is an image in which all pixel values are reduced by a factor of 2, and the pixel data format is *Unsigned 16-bit*. The *Pixel Scale Factor* is then indicated as 2 in the *System* tab of the *Image Information* dialog. See extract from this dialog in the following figure:

Figure 6-40 Extract from Image Information Dialog

Pixel Data Format:	Unsigned 16-bit	Cone Beam Mode Type:	DUAL_READ
Pixel Scale Factor:	2.000	Cone Beam Gain Ratio:	4.560

6

Correct Image

The **Tools|Cone Beam|Correct Image** function is enabled when the selected image was acquired using a dual read or dynamic gain mode with all corrections turned off or 'Real-Time Video' corrections disabled if it is a video sequence. The selected image will be corrected using the existing calibration provided:

- the image has not been saved and re-opened
- the acquisition mode for the image is currently selected
- the selected image is displayed in a n image pane (not a thumb pane)

The currently selected corrections will be applied.

Real-Time Video Corrections

The **Tools|Cone Beam|Real-Time Video Corrections** function is checked by default. It results in corrections being applied in real-time. If it is unchecked, corrections will not be applied in real-time, and corrections may optionally be applied after acquisition is complete. This setting acts as an override of the corrections settings. If post-acquisition corrections is the preferred operating mode then it is more convenient to use this feature then continually turn corrections on/off in the *System Settings* dialog.



Note: Computer systems vary and it may not be possible on a given system for corrections to be performed in real-time. Dynamic gain modes are particularly demanding of system resources, and it is quite likely that real-time corrections will not be possible when a dynamic gain mode is selected.



Important: The following information details operations which should only be performed by experienced imaging personnel. Please contact PaxScan Technical Support for more information.

In This Chapter

Topic	Page
Configure Utility Application	7-97
Usage	7-98
Main Screen	7-99
Receptor Configuration Settings	7-100
Mode Selection	7-102
Mode Setup	7-103

Configure Utility Application



WARNING: Use of this application program is strictly only for the purpose of viewing the factory - installed configuration file settings. Failure to do otherwise without prior permission from Varian Medical Systems will void the Varian Medical Systems standard warranty

The purpose of the Configure Application is to provide an interface for building the necessary configuration files for the PaxScan Command Processor. There are two required configuration files, one for system configuration and one for receptor configuration.

The system configuration file includes information that pertains to the entire system, such as the version information, etc.

The receptor configuration file includes information needed to examine or if required correctly configure the receptor for acquisition. Frame rate, binning, recursive filter percentage, etc. are examples of the data within the receptor configuration file.

More specific information about the data contained within the configuration files will be discussed later in this document.

The Configure Application is designed to guide the user through a sequential set of steps which will result in the successful creation of a configuration file. Thus, there are several dialog boxes which require input such that configuration file creation will not be completed until all the necessary information is provided. In general, for all dialog boxes, the data items which are gray are not modifiable while all non-gray data items are modifiable.

There are also several dialog boxes which cannot be revisited in the same instance of the application, i.e. once “OK” is selected, the ability to return to that window may not exist, so you will have to cancel and restart the application to change that data.


In general, if the Cancel button of any dialog box is selected, the configuration file is not considered complete.

This Help document is setup to guide the user through the sequential usage of the Configure Application; thus, the document is ordered according to the appearance of the dialog boxes in the application.

Usage

The first dialog box encountered determines how the Configure Application will be used. The application can be used in customer mode, manufacturing mode or engineering mode. This dialog box cannot be revisited within the same instance of the Configure Application so the type of usage chosen will be the same throughout that instance of the application. The Usage dialog box can be seen below.

Figure 7-1 Usage Dialog Box



The purpose of the customer mode is to provide the ability to quickly create configuration files for customers. The customer usage provides default values for all parameters.


The manufacturing usage is designed to customize configuration files for shipment. Default values are not provided in the manufacturing mode, instead, all configuration information must be entered by manufacturing based on the draft sheet or the configuration file created in the field, using the “Customer Configuration” mode.

The engineering mode is designed for experimentation and test purposes only. Engineering mode should only be used by VIP engineers, others may use this mode at their own peril. Engineering mode will not be discussed within this document.

Main Screen

The purpose of the Main Screen is to create a new file or open/edit an existing file and/or save a file. The Main Screen dialog box can be viewed below.

Figure 7-2 Main Screen Dialog Box




7

The "New..." buttons will create a new file. Selecting "New..." for System Configuration will display the System Settings dialog box. The Receptor Configuration "New..." button will display the Receptor Configuration Settings Dialog Box. Both of those dialog boxes will be discussed later.

The "Open..." buttons will display an Open dialog box as shown below. The Open dialog box allows the user to open files as in any other application, i.e. by double clicking on the file, or highlighting the file and then selecting the "Open" button. If a file is opened which is not the correct format, default values will be used.

Figure 7-3 Open Dialog Box



The “Save As...” buttons behave like the “Open...” buttons except the files will be saved to disk rather than opened. Existing files can be overwritten, if “Yes” is selected when asked if you want to overwrite the existing file.

The “Edit...” button requires that data has been entered either through opening an existing file or through creating a new file. If a file has been opened with the “Open...” button, selecting the “Edit...” button will result in the same dialog boxes, but the data will represent the data contained in the opened file.

Note that the “File” field is not modifiable. This field will update to contain the name of the file which was most recently opened or most recently saved.

Receptor Configuration Settings

The Receptor Configuration Settings dialog box (seen below) allows the user to configure the receptor specific values for the receptor configuration file.

Figure 7-5 Receptor Configuration Settings

The Receptor Configuration Settings dialog box allows the user to create modes which will cause mode specific dialog boxes to be displayed. Those dialog boxes will be discussed later.

The dialog box will not disappear until all required data is entered or Cancel is selected. The data items are defined in the following table.

Table 7-2 Receptor Settings Data Description

Data Item	Description
System Software Version	The current version of software installed on the system.
Receptor Serial Number	The serial number of the receptor, as entered by Manufacturing.
Output Configuration	Defines the 16-bit video output as LVDS.
Max Pixel Value	Defines 12-bit or 14-bit data acquisition mode.
Corrections:	The corrections allow the user to define how the system corrections are configured for system start-up.
Offset Calibration	Whether or not offset corrections are enabled at system start-up.
Gain Calibration	Whether or not gain corrections are enabled at system start-up.
Pixel Corrections	Whether or not pixel corrections are enabled at system start-up.
BLC	Whether or not black level clamping (BLC) is enabled at system start-up.
Receptor Type	The type of receptor installed with the system.
Mode Settings	Allows the user to define the modes for the system.
Insert...	This button allows the user to insert a new mode. This button serves as the add and insert function. If no row in the table is selected the new mode will be stored in the next available slot. If a row is selected, the new mode will be inserted above the selected row. Modes can be added until the maximum number of modes is reached. This number is based on the size and number of modes created.
Edit...	This button allows the user to edit a mode. To edit a mode, select the row in the table which corresponds to the mode that needs to be edited. If no modes exist (i.e. through the Insert command or a file open operation), an “error” will be displayed.
Delete...	This button allows the user to delete a mode. To delete a mode, select the row in the table which corresponds to the mode that needs to be deleted.

Table 7-2 Receptor Settings Data Description

Data Item	Description
Up Arrow	This button allows the user to move a mode to a higher position in the list. To move a mode, select the row of the desired mode, then select the up arrow. The selected mode will be moved one row higher in the table unless the mode is on the first row.
Down Arrow	This button allows the user to move a mode to a lower position in the list. To move a mode, select the row of the desired mode, then select the down arrow. The selected mode will be moved one row lower in the table unless the mode is on the last row.


The Receptor Type must be selected before enabling a mode. If not, a message box will appear instructing the user to select a Receptor Type before continuing.

Please note that if a mode is not completely configured, i.e. the Cancel button on one of the mode configuration dialog boxes is selected during creation of the mode (i.e. while performing a “New” operation), the mode will be deleted in the Receptor Configuration Settings dialog box.

Mode Selection

The Mode Selection Dialog Box allows the user to choose the mode type. When “Insert...” is selected, if the receptor has the DCDS feature, the following dialog box will appear to allow the user to select the line length desired.

Figure 7-6 DCDS Line Length Dialog Box



The mode types will vary depending on the receptor type and line length as appropriate. Once a mode type is selected, the Mode Setup dialog box will be displayed. The following dialog box is an example of the Mode Selection dialog box.

Figure 7-7 Mode Selection Dialog Box



Note: The gray box at the top left is not modifiable and only provides a reminder as to which mode the user has enabled.

Mode Setup

The Mode Setup dialog box allows the user to select specific details that pertain to how the system should configure a particular mode. The data that appears in the Mode Setup dialog box will depend on the type of mode selected, the receptor type and the line length as appropriate. The following dialog box is an example of the Mode Setup dialog box.

7

Figure 7-8 Mode Setup Dialog Box

The following table describes the data items in the Mode Setup dialog box.

Table 7-3 Mode Selections

Data Item	Description
Mode #	Number of the selected mode. Information only, not modifiable.
Mode Name	A high level description of the mode type that has been selected for configuring. Information only, not modifiable.
Receptor Type	The type of receptor that was selected. Information only, not modifiable.
DCDS Enable	Whether or not DCDS corrections are enabled for the mode selected. Information only, not modifiable.
Frame Rate	The frame rate for the mode.
Gain	The gain value applied to signals before digital-to-analog conversion.
Binning	The number of receptor pixels which are binned to make one image pixel.
Frame Synchronization	<p>Defines how frames will be synchronized.</p> <ul style="list-style-type: none"> ■ Free Running - The frame start sync pulse and all internal clocks are created from internal circuits. ■ Line Sync - The frame start pulse and internal clocks are generated internally, but the AC line frequency is used as a reference. This option is not available for certain mode/receptor combinations. ■ User Sync - Frame start pulse is supplied from the user, all internal clocks are then generated based on the user supplied frame start pulse.
Calibration Information:	Information for how a calibration should be performed.
Number of Calibration Frames	The number of frames to accumulate during a calibration.
Offset Threshold Value for Defects	Threshold value used during offset calibrations to bound values.
Gain Scaling	If Disable is selected, gain scaling will be off, else if enable is selected, gain scaling will be on.
Auto Calibration Information:	Auto offset calibration data, enabled or disabled. If disabled, the other data does not need to be entered.
Min Delay	The minimum time delay between auto-offset calibrations.
Post-Exposure Delay	The amount of time delay required after an exposure.

Table 7-3 Mode Selections

Data Item	Description
Pixel Information:	Information pertaining to how pixels will be rounded.
Recursive Filter	The fractional contribution to each output frame by the data already in the recursive filter buffer.
Pixel Saturation Threshold Value	The value at which a pixel is considered to be saturated.
Pixel Saturation Replacement Value	The value with which to replace a pixel that is determined to be saturated.

System Configuration: Hostdown Utility Application

Updates via Serial Link

The Hostdown Utility Application is used for any software program update, change or revision. The system configuration software package used to configure the PaxScan 3030CB / 4030CB Command Processor consists of the following:

7

Table 7-4 System Configuration Software Package Files

Filename	Description
System Software	Embedded operating system, which runs on the motherboard and controls the operation and interfacing of all other Command Processor hardware.
Global Control Firmware	Firmware which programs FPGAs on the Global Control Board.
3030CB / 4030CB Receptor Firmware	Firmware which programs FPGAs on the digital board in the Receptor.
Receptor Config Data	Configuration file which defines the modes of operation for the Receptor.

Hostdown Target Commands

Once **Hostdown** has made a connection to the Command Processor, one of two basic functions can be performed:

- The IP address of the Command Processor can be changed by choosing **Change Target's IP Address...** from the Target Commands menu.
- Downloading of system software, firmware files, and can be done by selecting **Download to Target...** from the Target Commands menu.

Using the **Download to Target** command, the user can manually download any one of these files, or use the Automated Download feature to download all the required files.




Note: Hostdown is also designed to support batch file downloading using the **Auto Download File Set** feature shown in Figure 7-10.


There are several types of configuration files which reside permanently in the flash memory of the Command Processor. The files listed above can be replaced by downloading new versions over a serial link using the utility application **hostdown.exe**, by following these next steps.

1. **Power Off** the Command Processor.
2. Connect your computer COM port to the Command Processor's serial 1 port.
3. On client computer, run the **Hostdown.exe** program located in the `command_processor` directory in the PaxScan 3030CB / 4030CB Software release folder.
4. Click **Hostdown**. The following screen appears:

Figure 7-9 Hostdown Main Screen




5. From the menu bar choose **Configure->Communications Port->COM X**. COMX should be any free COM port on the client computer.
6. Click **Connect**. The following window will appear:



7. Once this window appears, turn Command Processor power On. The following window will open when a connection is established:




8. Click **Ok**. The following window appears:



9. From the menu choose **Target Command->Download To Target....** The following screen appears:

Figure 7-10 Auto Download File Set



7

10. Click on the active pull-down menu to select *AutoDownload Set for 3030CB / 4030CB Receptors*.
11. When download is complete, exit **Hostdown** and restart the Command Processor. Allow the Command Processor to boot-up completely, then cycle power and allow the Command Processor to boot-up again.



Note: The Command Processor must be **reset twice** in order for the firmware to be loaded properly.

System Configuration: ViVA Application

While the Hostdown Utility application may be used for any software upgrade, the ViVA application allows upgrades without power cycling the Command Processor.

ViVA may be used as an engineering tool to modify small subsets of software files, or to change the Receptor mode configuration from 15 to 30 frames per second for example. It is simply a matter of convenience. With the Hostdown Utility application, you must power down the Command Processor, and power back up.

However, for ViVA to work properly the system must fully boot for ViVA to establish communication. If the Command Processor doesn't boot, then Hostdown must be used to download any files to flash.

Upgrades over the Ethernet Connection

The Command Processor uses flash memory to store various configuration files. Some of these files can be updated through the ViVA software over the Ethernet connection. The following files can be updated over the Ethernet Link:

- Receptor Configuration Data File
- Base Defect Image File (Defective Pixel Map)
- Gain Calibration File
- Offset Calibration File
- Firmware Files
- Configuration Files

The basic procedure for performing the update is very similar for each file. This example illustrates how to download the Base Defect Image File.

1. Connect to the Command Processor with ViVA
2. From the ViVA menu bar, select **Tools>CommandProcessor>Transmit Files**. The following window will open:

Figure 7-11 ViVA Transmit Files Selection

3. Select a file for download by clicking on the checkbox next to the file description.
4. Click the **Browse** button and select the new defect map file. This file is provided on the CD-ROM shipped with the Receptor. The file will be labeled with a filename that corresponds to the mode it was generated in.
5. In the second field, select a mode that corresponds to the mode-specific defect map to be downloaded. Click **OK** to transmit the file. The Transmit Files window will close and ViVA will transmit the defect map to the Command Processor flash memory.



Note: The defect map for each mode must be transmitted one at a time.

6. Steps 2-5 may be repeated for all modes loaded in the Command Processor flash memory.



Note: The Receptor configuration data file determines the numbers of modes loaded into memory.



Note: There is a customized defective pixel map associated with each mode loaded in memory. This means that a defective pixel map should be updated anytime a Receptor configuration data file is updated.

This section outlines the hardware specifications needed to operate the PaxScan 3030CB / 4030CB imaging system.

In This Chapter

Topic	Page
Hardware Components	8-111
Command Processor Hardware Configuration	8-112
Pulsed X-ray Beam Applications	8-124
Internal Power Supply Specifications	8-124
Command Processor Specifications	8-126

Hardware Components

The PaxScan 3030CB / 4030CB digital imaging system consists of the following components:


- Receptor
- Command Processor
 - ☐ external synchronization
 - ☐ 16-bit video
 - ☐ Fiber Optic Link (Receptor)

Command Processor Hardware Configuration

Motherboard

The Motherboard is a MIPS-based computer. The Motherboard contains flash memory into which the system software is loaded. The system software contains the operating system and the software program responsible for the control and communication of all Command Processor hardware.

Figure 8-2 Command Processor Hardware Interconnection



The operational modes of the Receptor are also stored in flash memory. The Receptor Configuration file defines the operational modes of the Receptor. The Receptor Configuration file can be created with the Configuration application.

IPCU


The IPCU card receives high speed serial data from the Receptor. The data is re-framed and passed to the IPU for image processing.

- The IPCU card outputs an LVDS 16-bit digital video signal.
- The IPCU card receives power from the internal Power Supply link and passively filters all supply voltages, which are distributed to the Motherboard, IPU, and to the Receptor.
- The IPCU card provides customer interfacing through an external synchronization port, capable of handling both input and output. The specifications for this port are outlined in the *System Overview* chapter of this guide.
- The image processing unit (IPU) is responsible for real-time image processing on the raw data received from the Global Control card.

External Synchronization: Hardware Handshaking

The External Synchronization port provides mode control and verification on a frame-by-frame basis. The default handshaking protocol outlined in Table 8-3, is used primarily to verify that the PaxScan 3030CB / 4030CB is functional, and that valid data are being output. This port is used to input hardware signals that initiate frame acquisitions. All I/O on this port is performed through opto-couplers. Each signal is sent or received as a differential pair. The general concept of the opto-coupler interface is illustrated in Figure 8-3.

Figure 8-3 Generic Opto-Coupler Interface



The output pulls the signal line low with an open collector driver. The receiver side must provide an additional resistor to limit the current. The grounds of the two systems are not connected, and the interface should operate correctly for large common mode differences.

The pin assignments for the external synchronization port are shown in Table 8-1.

Table 8-1 Pin Assignments of the External Synchronization Port

Pin #	Assignment	Pin #	Assignment
1	OptPOut[0]	26	OptPIn[0]
2	OptMOut[0]	27	OptMIn[0]
3	OptPOut[1]	28	OptPIn[1]
4	OptMOut[1]	29	OptMIn[1]
5	OptPOut[2]	30	OptPIn[2]
6	OptMOut[2]	31	OptMIn[2]
7	OptPOut[3]	32	OptPIn[3]
8	OptMOut[3]	33	OptMIn[3]
9	OptPOut[4]	34	OptPIn[4]
10	OptMOut[4]	35	OptMIn[4]
11	OptPOut[5]	36	OptPIn[5]
12	OptMOut[5]	37	OptMIn[5]
13	OptPOut[6]	38	OptPIn[6]
14	OptMOut[6]	39	OptMIn[6]
15	OptPOut[7]	40	OptPIn[7]
16	OptMOut[7]	41	OptMIn[7]
17	GND	42	OptPIn[8]
18	OptPOut[8]	43	OptMIn[8]

Table 8-1 Pin Assignments of the External Synchronization Port

Pin #	Assignment	Pin #	Assignment
19	OptMOut[8]	44	OptPIn[9]
20	OptPOut[9]	45	OptMIn[9]
21	OptMOut[9]	46	OptPIn[10]
22	OptPOut[10]	47	OptMIn[10]
23	OptMOut[10]	48	OptPIn[11]
24	OptPOut[11]	49	OptMIn[11]
25	OptMOut[11]	50	GND



Note: Pins 1 – 25 are outputs, pins 26 – 50 are inputs, and shield is at GND. The connector is a 50 pin D-subminiature, AMP 747193-2.

Table 8-2 Default Hardware Handshaking Interface

Signal	Assignment	Pin #
Prepare	OptPIn[0]	26
	OptMIn[0]	27
Valid_Xray	OptPin[1]	28
	OptMin[1]	29
Valid_Frame	OptPOut[0]	1
	OptMOut[0]	2
Panel_Ready	OptPOut[2]	5
	OptMOut[2]	6
Reset <i>not currently implemented</i>	OptPIn[2]	30
	OptMIn[2]	31
Radiation_Warning <i>not currently implemented</i>	OptPIn[3]	32
	OptMIn[3]	33
Panel_Healthy	OptPOut[3]	7
	OptMOut[3]	8
Mode_Control_Bit0 <i>not currently implemented</i>	OptPIn[4]	34
	OptMIn[4]	35

Table 8-2 Default Hardware Handshaking Interface

Signal	Assignment	Pin #
Mode_Control_Bit1	OptPIn[5]	36
<i>not currently implemented</i>	OptMIn[5]	37
Mode_Control_Bit2	OptPIn[6]	38
	OptMIn[6]	39
User_Vsync	OptPIn[11]	48
	OptMIn[11]	49
Valid_RAD_Frame	OptPOut[5]	11
<i>not currently implemented</i>	OptMOut[5]	12
Expose_Ok	OptPOut[4]	9
	OptMOut[4]	10

Table 8-3 Default Hardware Handshaking Signals

Event Causing Interrupt	Interpretation
Prepare	<p>Signal from the OEM Controller.</p> <p>Prepare = True indicates that production of X-rays is imminent.</p> <p>Prepare = False indicates that production of X-rays is no longer imminent.</p>
PanelReady	<p>Signal from the PaxScan 3030CB / 4030CB.</p> <p>Prepare = True indicates an exposure is about to begin. PaxScan 3030CB / 4030CB should respond with PanelReady = True within three frames.</p> <p>PanelReady = False after three frames indicates an error condition.</p>
ValidXRays	<p>Signal from the OEM Controller. Indicates X-rays are at the proper intensity. <i>This signal is asynchronous.</i></p> <p>ValidXRays = True indicates that X-rays have begun to be produced at the intended X-ray intensity.</p> <p>ValidXRays = False indicates that X-rays are no longer being produced at the intended intensity.</p>

Table 8-3 Default Hardware Handshaking Signals

Event Causing Interrupt	Interpretation
PanelHealthy	<p>A signal from the PaxScan 3030CB / 4030CB.</p> <p>PanelHealthy = True indicates normal functioning. This signal should be true within 30 seconds after startup.</p>
ValidRADFrame <i>not currently implemented</i>	<p>Signal from the PaxScan 3030CB / 4030CB.</p> <p>ValidRADFrame = True indicates the radiographic acquisition has been fully processed and is currently being displayed on the 16-bit video port.</p>
Expose_Ok	<p>An active low signal from the PaxScan 3030CB / 4030CB.</p> <p>Expose_Ok = True notifies the OEM X-ray generator it is safe to deliver pulsed X-rays.</p>
ValidFrame	<p>Indicates the preceding frame has been fully exposed.</p> <p>If a frame, N, has been read by the PaxScan 3030CB / 4030CB, where ValidXrays = True during the entire preceding frame period, $N-1$, as well as during the entire period in which the frame was read, then the PaxScan 3030CB / 4030CB will tag this frame as fully exposed with ValidFrame = True.</p> <p>If a frame is fully exposed, ValidFrame will be True during the first Vblank succeeding this frame.</p> <p>If a frame is only partially exposed, or not exposed at all, ValidFrame will be False during the first Vblank succeeding this frame.</p> <p>Note: Due to the nature of the flat panel, a frame must be exposed to valid X-rays for at least two frame periods, and read out during the second frame period, in order to be a fully exposed frame (one capable of being tagged with the ValidFrame = True signal)</p> <ul style="list-style-type: none"> ■ The ValidFrame signal will not toggle during the Vblank period. <p>The PaxScan 3030CB / 4030CB will stay in active fluoroscopic mode as long as Prepare = True, independent of the ValidXray/ ValidFrame signals.</p>

16-bit Video Output Signals

The video bus consists of twenty signals, described in Table 8-4.

Table 8-4 Video Interface Signals

Signal Name	Number of Signals	Description
PixClk	1	Pixel Clock: All signals are sampled on the rising edge of this clock.
Vsync	1	Vertical Sync: Falling edge of this signal defines the beginning of a video frame.
Hsync	1	Horizontal Sync: Falling edge of this signal defines the beginning of a video line.
Dvalid	1	Data Valid: Low level of this signal implies image data is valid.
Data[15:0]	16	Data: Contains up to sixteen bits of data.

Logic Levels

All signals are defined as LVDS (low voltage differential signaling). Each individual signal contains a positive and a negative component. Thus, the twenty signals actually require forty connections. The recommended LVDS receivers are shown in the following tables.

8



Note: The signals are translated from CMOS/TTL levels, and are transmitted using LVDS.

Table 8-5 Typical LVDS Levels

Input Voltage	$0V < \text{receiver input voltage} < 2.9V$
Differential Input Threshold High	+100 mV (maximum)
Differential Input Threshold Low	-100 mV (minimum)
Input Current	-20 μA (minimum), +/- 1 μA (typical), +20 μA (maximum)


Table 8-6 Recommended LVDS Parts

Part Number	Description	Manufacturer
DS90C031TM	LVDS Quad CMOS Differential Line Drive	National Semiconductor
DS90C032TM	LVDS Quad CMOS Differential Line Receiver	National Semiconductor
DS92LV010A	Bus LVDS 3.3/5.0V Single Transceiver	National Semiconductor

Frame Timing

A video frame consists of a real data frame inside of a virtual frame. The virtual frame is increased from the real data frame by four strips of blanking: *top vertical*, *bottom vertical*, *left horizontal* and *right horizontal*, as illustrated below.

Figure 8-4 Frame Timing



Blanking allows time for processing and other delays. Historically, at VIP the *top vertical* and *left horizontal* blanking are much smaller than the *bottom vertical* and *right horizontal* blanking.



Note: This is at present opposite to the industry norm. Vsync and Hsync define the vertical and horizontal edges of the virtual frame. The minimum size for any blanking is four pixels.

Table 8-7 PixClk Timing Specifications

Model	Min	Max	Units
T_{clk}	25	31.25	ns
$F_{\text{clk}} = 1/t_{\text{clk}}$	40	32	MHz
$T_{\text{clk jitter (pp)}}$		2	ns
$T_{\text{clk duty cycle}}$	40	60	%
T_{high}	12.5		ns
T_{low}	12.5		ns

Signal: Vsync

Vsync defines the beginning of the frame. Vsync goes low at the upper left corner of the virtual frame and stays low for two to eight lines. It then returns high until the next frame. *Vsync must go low during the same clock cycle that Hsync goes low.*

Figure 8-5 Vsync Timing Diagram




Table 8-8 Vsync/Hsync/Data Valid Timing Specifications

Model	Min	Max	Units
T_s	2.5		ns
T_h	1.5		ns
T_{valid}	2	8	lines



Note: Data Valid must remain high during the valid image data frame. Thus, bursting of data with gaps are not allowed. T_{valid} , noted above, is not applicable to Data Valid.

Signal: Hsync

Hsync defines the beginning of a line. Hsync goes low at the left edge of the virtual frame and stays low for two to eight pixels. It then returns high until the next frame. The timing for Hsync is equivalent to the timing for Vsync.

Signal: DataValid

DataValid defines the real image data within the virtual frame. DataValid is high during blanking, and low when valid image data is present on the data lines, which includes the black level clamping data.

The timing figure for DataValid is equivalent to the diagram for Vsync and Hsync. DataValid must be low continuously during the valid image data frame. Thus, bursting of data with gaps are not allowed.

3030CB / 4030CB UserSync Fluoroscopy Video Timing

Figure 8-6 User Sync Fluoro Overall Timing




Figure 8-7 Detailed View of one HSYNC and Data Valid




Figure 8-8 Full Resolution Overall Video Timing with User Sync






Figure 8-9 Full Resolution Detailed Video Timing



Connector and Cable Pinouts

Presently, two connector pinouts and cables are supported. The pinout for the supported connectors are shown in Figure 8-10.

Figure 8-10 LVDS and CameraLink Connector Pin Assignments



LVDS

The connectors at both the transmitter and the receiver are AMP 50pin SCSI-II receptacles, right-angle or vertical. The cable is a standard 50 conductor SCSI-II cable with male plugs at both ends. The pinout for the connectors is shown in Figure 8-10. *Recommended: L-COM SCSI-2 Cable #CA801-XM, where X is length.*



Note: **MOUT** refers to the minus data out and **POUT** refers to the plus data out. Grounds are internal grounds, not case grounds. They are to be tied at the transmitter only.

CameraLink

The connectors at both transmitter and receiver are standard camera link connector from 3M. It is a .050" surface mount right angle, 26-pin connector with part number 10226-1A10VE. The cable is a standard camera link cable from 3M with part number 14X26-SZLB-XXX-0LC, where the first X is shell retention option, and the 3 X's are length in meters (please refer to Camera Link Specifications for more details). The pin out for the connectors is shown in figure 8-10.

User Synchronization Mode

This mode allows users utilizing External Synchronization 50 pin D-Sub connector, to introduce the Frame Start signal. The signal is introduced on pins OptPIn[11] and OptMIn[11] of the External Synchronization port. When operating User Sync mode, the User Sync signal bypasses the DPLL module in the Command Processor.



Note: Although the User Sync bypasses the DPLL module, it is received by digital logic which ignores additional triggers until the end of the video data output, i.e. the end the Real Frame. However, glitches on the User Sync line should be avoided since they could accidentally trigger the panel before the end of the Virtual Frame, causing the panel to see a frame rate potentially higher than the allowed maximum.

Timing

The Command Processor will lock the generation of all internal clocks to the rising edge of the User Synchronization signal provided by the user. Assuming the PaxScan imager is using the maximum read-out rate, which is approximately 40 usec/line, the frequency requirements for the User Sync are: Fluoro Mode < 30Hz; Full-Resolution Mode < 7.5 Hz. For slower line rates, the maximum User Sync frequency is reduced.


Table 8-9 Frame Rate vs. Vertical Blank Time

Mode	Name	Binning Row/Column	Matrix Row/Column	Frame Rate /Vblank [max]/[ms]
Innf	low noise normal fluoro	2/2	1024/768	30/1.34
Infr	low noise full resolution fluoro	1/1	2048/1536	7.5/30

Termination Scheme and Loading

The recommended termination scheme is shown in Figures 8-11. The recommended LVDS drivers and receivers in Table 8-6 do not include terminations inside the LVDS package.

Figure 8-11 LVDS Signal Termination Scheme



Pulsed X-ray Beam Applications

Timing Information

Asynchronous X-ray exposure can cause additional noise and interference appearing as stripes of different brightness, which occur at points throughout the image corresponding to the beam ON times. To avoid this interference, X-ray beam synchronization is used.



Note: A frame is composed of a panel readout period and a vertical blanking period. The X-ray pulses must be delivered within the vertical blanking period in order to prevent image artifacts.


The Command Processor Expose_OK output notifies the X-ray generator when it is safe to deliver the X-ray beam. The signal is available on the External Synchronization port. The Expose_OK is negative during the vertical blanking interval, which is the portion of the frame time after the readout (scanning) is complete.



Note: In order to prevent the stripe artifact in the image, the X-ray beam should only be on when Expose_OK is negative.

The Expose_OK signal is connected to the OptMOut(4) pin of the External Synchronization port. The OptPout(4) pin of the same port is connected to +5 Power Supply VCC. These outputs are to be connected to an opto-coupler, such as an HCPL063 from Hewlett Packard.

Figure 8-13 Timing for Systems with Pulsed X-ray Beam Delivery



Internal Power Supply Specifications

The internal Two-Output Power Supply (TOPS) has been designed for use in Varian's imaging products. It is a UL 60601-1 approved two-output power supply. There is a 5V output with remote sense used to internally power the Command Processor and a 24V supply used to externally power the Receptor.

Table 8-10 Internal Power Supply Specifications

Command Processor	Specification
Input Supply Voltage	85-264Vac, 47-63Hz single phase
Outputs	Receptor: 24V / 3A nominal, 5A maximum

Control and Monitoring

Command Processor On/Off Switch: A power switch, located at the rear of the command processor, will connect/disconnect AC power to the unit. The power switch is a DPST panel mounted rocker switch, which makes & breaks both AC lines.

On/Off Indicators: A green LED at the front of the command processor will indicate that AC power is applied to the unit and the power switch is in its on position.

Mechanical Specifications

Figure 8-14 Receptor





Figure 8-15 Command Processor



Command Processor Specifications

Serial Interfaces

Two serial ports are provided. These are implemented with two male 9-pin D-type connectors. Their pin definitions are:

Table 8-11 Serial Port One (P1)

Signal Name	Pin #	Signal Name	Pin #
	1	DTR	6
TXDA	2	CTS	7
RXDA	3	RTS	8
	4		9
GND	5		

Table 8-12 Serial Port Two (P2)

Signal Name	Pin #	Signal Name	Pin #
	1		6
TXDB	2		7
RXDB	3		8
	4		9
GND	5		

Ethernet Port

The Ethernet port shall interface through a 8-pin right angle RJ-45 connector (P3). It shall have the pin-out listed below:

Table 8-13 Ethernet Connector (P3)

Signal Name	Pin #	Signal Name	Pin #
TxD+	1	GND	5
TxD-	2	RxD-	6
RxD+	3		7
	4		8

Receptor Module



WARNING: Precautions should be taken to not open the receptor module. Depending upon the type of scintillator used, opening the receptor module may expose the user to potentially toxic materials.

Receptor Mounting

The Receptor should be mounted onto other pieces of equipment using the holes provided in the integral flange.



WARNING: The Receptor has an optional lead cap which can be used as a primary barrier to X-rays. This barrier is only effective if the X-ray beam is collimated in such a way that X-rays impinge on the active surface of the Receptor.



WARNING: If the Receptor is to be used as a primary barrier to X-rays, the X-rays must impinge on only the entrance window of the Receptor. The optional lead cap will not stop X-rays that do not hit the entrance window of the receptor.



CAUTION: The front surface of the Receptor is designed to be splash-proof, but the electrical connector at the backside of the Receptor is not sealed against moisture.

Command Processor

Rack Mounting the Command Processor

The Command Processor can be rack mounted in a standard 3U (5.2" high) slot using optional rack mounting intended for a 19" wide rack. Optional sliding brackets are also available.



CAUTION: The following precautions should be observed when rack mounting the Command Processor:

- **Elevated operating ambient temperature:** If installed in a closed or multi-unit rack assembly, the operating ambient temperature of the rack environment may be greater than room ambient. Equipment should be installed in an environment compatible with the maximum rated ambient temperature.
- **Reduced air flow:** Install the equipment so that the amount of air flow required for safe operation is not compromised.
- **Mechanical loading:** Mounting of the equipment in the rack should be loaded evenly to avoid any hazardous conditions.
- **Circuit overload:** Consideration should be given to the connection to avoid overloading of circuits on the over-current protection and supply wiring.
- **Reliable grounding:** Reliable grounding should be maintained, with particular attention given to the supply ground connection.

Environmental Conditions

Table 9-1 Environmental Conditions

Storage/Shipping Temperature	-20°C to +70°C
Storage/Shipping Humidity	10% to 90%, non-condensing
Full-spec Operating Temperature (Measured at the center of the back cover.)	10 to 35°C
Operating Humidity (non-condensing)	10 to 90%

Cooling Requirements



Important: The back surface temperature of the Receptor should not exceed 35°C when the unit is installed. This requirement may necessitate air flow over the back surface of the Receptor.



Important: Ambient air temperature should not exceed 40°C for the Command Processor.



Important: The Command Processor do not have air filters, so the air should be free of dust and particulates.



Important: Cooling air clearance requirements for the Command Processor are four inches minimum from each surface.



WARNING: The unit must comply with those standards listed under each category to the levels detailed. Assume the most stringent requirements prescribed by the standard if no levels are detailed.



WARNING: The PaxScan 3030CB / 4030CB is not classified for use in the presence of a flammable anaesthetic mixture with air, or with oxygen or nitrous oxide.



CAUTION: The unit must comply with those standards listed under each category to the levels detailed. If no levels are detailed, assume the most stringent requirements prescribed by the standard.

Electro-Magnetic Compatibility

Under normal operating conditions, the imager will comply with IEC 60601-1-2.

Referenced Standard	IEC 60601-1-2
EN61000-3-2	Class A
EN61000-3-3	Required
EN61000-4-2	+/- 6kV Contact, +/- 8kV Air
EN61000-4-3	80MHz-2.5GHz@3V/m
EN61000-4-4	+/-1kV@ I/O Cable, +/- 2kV @ PS
EN61000-4-5	+/-1kV DiffMode, +/-2kV ComMode
EN61000-4-6	150kHz - 80MHz @ 3Vrms
EN61000-4-11	Required

Electro-Magnetic Interference

This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to other devices in the vicinity. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to other devices, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures listed in the **Troubleshooting** section.

Electrical Shock protection

Class 1 Equipment per UL 60601-1

X-Ray Leakage with Pb barrier

Under normal operating conditions, no damage, and X-rays incident only on the active area: IEC 60601-1-3

Safety Agency Approvals

The imager will comply with all of the following safety agency standards and be appropriately labeled:

US: UL 60601-1.

Canada: CSA 22.2 No. 601.1-M90.

Europe: IEC 60601-1-1.

CE marked.

Preventative Maintenance



CAUTION: Substitution for any of the PaxScan components with units of a different type may cause catastrophic damage to the PaxScan imaging system, and will degrade the minimum safety of the PaxScan 3030CB / 4030CB.

No special preventative maintenance is required; however, prudent inspections should be carried out to check for:

- Damaged and worn cables
- Signs of severe shock to the Receptor, lead cap, Command Processor
- Evidence that fans are clear and running

Calibration Schedule

Offset calibration is performed automatically during times when X-rays are not impinging on the Receptor. Gain calibration needs to be performed with the assistance of an operator at regular intervals. If the Offset calibration is controlled by the user, it should be performed as often as possible.



Note: It is recommended that Gain calibration be done at least monthly, and more often if image quality degradation is observed. During Gain calibration, the map of defective pixels is also updated.

Receptor Module



WARNING: Precautions should be taken to not open the receptor module. Depending upon the type of scintillator used, opening the receptor module may expose the user to potentially toxic materials.

Repairs



Note: No user serviceable parts. If repairs are necessary, please contact the Varian Imaging Products Service Center at 1.800.432.4422, or 1.801.972.5000.

The IEC receptacle fuses on the Command Processor are replaceable by Varian service personnel. These fuses are identified by a label near the IEC receptacle, and must be replaced with the exact size and type called out on the label.

The least replaceable units (LRU) are:

- Receptor Assembly
- Command Processor Assembly
- Receptor Power Cable
- Receptor Fiber Optic Cable
- Command Processor Power Cable

Cleaning, Disinfection and Sterilization

The Receptor is the only component that is likely to be in the area of a patient. Although this component is not intended to come in contact with the patient, it is possible for the patient or user to touch the Receptor face.

The material most likely to come in contact with the patient is X-ray grade carbon fiber in a cast aluminum frame. The Receptor is not sealed against moisture.

Cleaning, disinfection and sterilization of the input window should be accomplished as needed, but cleaning of the input window should be accomplished at a minimum of one month intervals. Proper disinfection and sterilization requires that a disinfectant/sterilization solution be used. Wiping the surfaces with a soft cloth dampened with soap and water will generally clean the surfaces.

Chapter 11 Troubleshooting

HyperTerminal


HyperTerminal is a program, supplied by Microsoft, that interfaces to the serial port 1 on the Command Processor. HyperTerminal is used to monitor status and debug messages outputted from the Software running in the command processor. The Command Processor will display status and debug messages only on boot-up. After boot-up has been completed, debug messages are turned off to increase system performance.

Figure 11-1 HyperTerminal Window



Note: To enable debug messages during runtime select **Tools>Command Processor>Debug Verbosity** from the **ViVA** pull down menu.

Figure 11-2 ViVA Window



11




Note: Making these messages available to Technical Support will be very helpful in diagnosing any potential problems with the PaxScan system. To capture the debug messages to file select **Transfer>Capture Text**

Then enter a path and filename.

The COM port should be configured as follows:

Figure 11-3 Com Port Configuration



Note: HyperTerminal must be closed when attempting to use Hostdown. This is because both programs access the same COM port for communication with the Command Processor.

Problems and Solutions

Table 11-1 Troubleshooting

Problem	Solution
Imager fails to respond.	<ol style="list-style-type: none"> 1. Check the power and then Restart. 2. Check fuse and cables.
Imager causes Electro-Magnetic Interference	<ol style="list-style-type: none"> 1. Reorient or relocate the receiving device. 2. Increase the separation between the equipment. 3. Connect the equipment into an outlet on a circuit different from that to which the other device (s) are connected. 4. Consult the manufacturer or field service technician for help.
Bad Pixel Correction fails.	<ol style="list-style-type: none"> 1. Repeat measurement. 2. Re-acquire gain and offset images. 3. Assure that the acquired Light and MidField images fill the field of view and that the exposures are appropriate for Light and MidField images.
Software hangs up.	Make sure the Power Supply module is switched On and the data cable to the PC is properly connected. If External Frame time was selected, make sure the input signal is generated.
Acquired image is completely dark.	Increase the frame time and acquire a new image. If the image is still dark, verify that the cables from the Power Supply to the Receptor, and from the Receptor to the computer are properly connected. Turn the power Off and On . Acquire a new image.
Out of virtual memory.	Close some of the windows that are currently open.
Residual X-ray image from previous scan shows in current scan.	Charge on the sensor pixels from a super saturated exposure may cause a residual image. It can be erased by taking a scan or multiple scans without X-rays until the residual image is gone.

How To Reach Us

In order to provide you with the most comprehensive technical support, (hardware or software), please complete the following problem report before contacting PaxScan technical support personnel.

If you prefer e-mailing the information to us, a .pdf version of this form is included on the CD ROM you received with your system. You may also fax a completed copy of the problem report printed on the following page.

- To speak with our technical support personnel, call (800) 432-4422 or (801) 972-5000.
- E-mail the report to paxscan.service@varian.com, then call the above number.
- Fax a copy of the Problem Report to (801) 973-5023.

PaxScan 3030CB / 4030CB Problem Report

Customer Information

Date: Your Name:

Company Name: Phone:

E-mail: Fax:

Product Information

PaxScan Part Number: Receptor Serial Number:

Software Revision #:

Operation I was trying to perform (be as specific as possible):

What happened (use additional sheets as necessary):

Fax this report to: (801) 973-5023 or e-mail paxscan.service@varian.com.

Appendix A Glossary

Aliasing	Interference patterns produced by the interaction of high spatial frequency information in the image with the pixel matrix.
Amorphous Silicon a-Si	Silicon that is deposited from vapor to form a thin, non-crystalline film. Common integrated circuits are made from crystalline silicon wafers sliced from grown crystals. Amorphous silicon devices can be much larger in area than the crystalline variety because no single crystal is needed. Amorphous silicon is ideal for X-ray detectors because it is nearly immune to radiation damage. For use in imaging devices, amorphous silicon is permeated with hydrogen (a-Si:H) and diffused with P and N dopants to provide device junctions.
Cesium Iodide	The most efficient scintillator in the diagnostic X-ray energy band. Cesium iodide has both high X-ray absorption and high visible photon yield. The sodium-doped version (CsI:Na) produces blue light and is used with photocathodes in nuclear particle detectors and X-ray image intensifier tubes while the thallium-doped type (CsI:Tl) is used with silicon detectors because it produces green light. CsI:Na is strongly hygroscopic and deliquescent and generally unusable outside controlled environments. CsI:Tl is moderately hygroscopic but easily protected making it suitable for use in air. For imaging, both types are grown in the form of densely packed thin columns to provide a fiber-optic, light-guiding effect for improved resolution.
Client or Client Computer	Refers to the OEM computer.
Contrast Transfer Function (CTF)	A measure of the ability of an imaging device to accurately reproduce patterns consisting of alternating dark and light bars of various widths. These bar patterns are calibrated in line pairs (one black and one white bar of equal width together) per millimeter (lp/mm), called spatial frequency. The difference between the maximum signal in the white bar and the minimum signal in the black at several spatial frequencies divided by the difference when very wide bars are used is plotted against the spatial frequency. The curve is the contrast transfer function.
Correction	May refer to <i>offset</i> , <i>gain</i> , <i>defective pixel</i> or <i>digital line noise reduction</i> . All are selectable from the ViVA pulldown menu under Acquisition->Mode Settings .
Dark Current	Signal resulting from leakage in the devices making up the sensor pixels.
Dark Field	An image taken "in the dark;" no X-rays.
Detective Quantum Efficiency	A measure of the ability of an imaging device to convert an incoming image to an electrical signal without adding noise. Precisely, it is the square of the ratio of the outgoing signal-to-noise (SNR) in the electrical signal divided by the incoming SNR in the X-ray signal. DQE usually varies with spatial frequency because the shape of the noise spectrum almost always differs from the shape of the modulation transfer function.

Direct X-ray Detection	Detecting X-ray energy by measuring charge generated directly by absorption by absorption of X-rays. Gases (xenon), liquids (iso-octane) or solids (selenium) can serve as the conversion materials. The charge may be measured by sensing electrostatically-induced changes in surface voltage or by collecting the charge itself.
Fill Factor	The fraction of the total area of a sensor that can convert incoming light into stored charge for readout.
Flat Field or Flood	An image taken with X-rays and no object in the path of the Field beam.
Fluoroscopy	Real-time X-ray imaging, usually performed at low dose rates.
FPGA	Field Programmable Gate Array.
Indirect X-ray Detection	Detecting X-ray energy by first converting it to visible light with a scintillator. The light is detected by a photodiode or similar opto electronic device. The scintillator may be in direct contact with the photodiode detectors or coupled via fiber optics or lenses.
Lag	The percentage of the signal produced by a sensor some specified numbers of scans after illumination is terminated to the signal produced under steady-state illumination.
Limiting Resolution	The smallest set of bars visible in an image produced by a sensor. In unsampled systems, this is often specified at the 3% modulation point. In sampled systems that are limited by the first sampling mechanism, it is exactly the spatial frequency at which one line pair covers two pixels.
LVDS	Low Voltage Differential Signaling.
MIPS	Million Instruction Per Second.
Modulation Transfer Function (MTF)	Similar to Contrast Transfer Function but with a pattern consisting of sine waves rather than bars. The amplitude of the signal at any selected spatial frequency is called the “modulation depth” for that frequency. It is possible to determine the MTF of an overall system by multiplying the MTF data from the individual components together.
MOPS	Multi Output Power Supply.
NDE	Non-destructive evaluation, an industrial application.
NDT	Non-destructive testing, an industrial application.
Pixel Pitch	<p>Pseudo Emitter Coupled Logic. The limiting resolution of a specific pixel matrix is given by the formula:</p> $R = 1/2d$ <p>where d is the pixel pitch in millimeters and R is the limiting resolution in line pairs per millimeter.</p>

Quantum Efficiency	The ratio of the number of charge carriers produced to the number of incoming visible photons. Only the photons actually received on a photosensitive area are counted. The average quantum efficiency of the sensor panel is the photodiode quantum efficiency times the fill factor.
Radiography	An image produced on a radiosensitive surface by radiation other than visible light, especially by X-rays passed through an object.
Radioscopy	Examination of the internal structure of optically opaque objects by use of penetrating radiation, especially by X-rays.
Raw Image	An uncorrected image.
Recursive Filter	<p>A temporal filter used to reduce noise in low dose fluoroscopic applications, at the expense of increased image lag. The intrinsic lag of the a-Si panel is somewhat less than that found in a plumbicon. The recursive filter combines a weighted average of the prior image frames with the current input frame. The recursive filter algorithm is:</p> $\text{output frame} = (1 - \alpha) \times (\text{new frame}) + \alpha (\text{old frame})$ <p>where α can take on values between 0 and 0.99. Recursive filtering introduces a controlled amount of lag into the video output for the purpose of noise reduction. This is a common technique in fluoroscopy, where the signal levels are very low and there is significant noise introduced by the statistics of the X-ray beam itself.</p>
Scintillator	A compound that absorbs X-rays and converts the energy to visible light. A good scintillator yields many light photons for each incoming X-ray photon; 20 to 50 visible photons out per 1kV of incoming X-ray energy is typical. Scintillators typically consist of a high-atomic number material, which has high X-ray absorption, and a low-concentration dopant which provides direct band transitions to facilitate visible photon emission. Scintillators may be granular like gadolinium oxysulfide or crystalline like cesium iodide.
Server	In the Server/Client relationship, the Server refers to the PaxScan 3030CB / 4030CB Command Processor, and the Client to the OEM Computer.
SNR	Signal-to-noise ratio.
Tape Automated Bonding (TAB)	Each row and column on a sensor panel must be individually connected to external electronics. The spacing of these connections is usually less than the pixel pitch. To connect to the thousands of contacts, small, flexible printed circuits are used which each contain an integrated circuit to concentrate the many signals on the glass (typically 128 or more) into fewer contacts (perhaps 20 to 30). The lower density end is connected to the glass using an anisotropic conductive film (ACF) under controlled temperature and pressure. Since the flexible circuits typically come on a reel-like film and, at least in high volume, the attachment process is done by machine, the technique is called tape automated bonding and the process is called TAB attachment. For convenience, the small flexible circuits are now called TABs, which they conveniently resemble.
TFTs	Thin Film Transistors.

ViVA	Varian Image Viewing and Application software.
Workstation	Workstation computer, also referred to as <i>client</i> .

Appendix B Command Processor and Computer Interface

Determining IP Addresses

In order for the Command Processor and the PC Workstation to communicate over the Ethernet port, each address must be recognized. There are two possible environments. The first is simply a point-to-point connection between the Command Processor and Workstation. The second possibility is that both the Workstation and Command Processor are connected to a local network.

This section addresses the configuration and operation for the PaxScan 3030CB / 4030CB with a Basic Workstation.



Note: In this context, the Command Processor is also referred to as the *Server*. The OEM Workstation is the *Client*, since it uses the *services* provided by the Command Processor.



Note: If the Command Processor and the workstation are connected to a local network, contact the network administrator to obtain the IP address for both the workstation and the Command Processor. These addresses can then be set as described below.

If the imaging system is connected in a point-to-point configuration, a special RJ45 to RJ45 crossover cable is required. In the point-to-point configuration, we recommend the use of the following addresses:


- Command Processor 172:20:20:20
- Workstation 172:20:20:21



Important: Using these addresses will protect the local network in case of accidentally connecting the Command Processor or Workstation to the Network.


Setting the IP Address of the Command Processor

1. The Command Processor should be turned **OFF**.




2. Click the **Hostdown** icon.
The following screen appears:

- From the menu bar select **Configure->Communications Port->COM 2**; click **Connect**. The following window opens:



- When this window opens, power **ON** the Command Processor. The following window will open when a connection is established:




- Click **OK**.




Note: If the attempt to establish the connection fails, repeat the procedure using the COM1 port.

- After clicking **OK**, the following window opens:



- From the menu bar select **Target Commands->Change Target's IP Address**. The following window opens:



- Enter IP addresses and click **Set IP Now**.


- Cycle power on the Command Processor.

The address change is complete.


Setting the IP Address of the Workstation

Assuming the workstation operating system is Windows NT, the IP address can be configured as follows:

1. From the **Start** menu, select **Settings**, then **Control Panel**.
2. Double click the **Network** icon.
3. Click **Protocols** tab, as shown below:



4. Double click **TCP/IP Protocol** or select **Properties**
5. For point-to-point Ethernet connections, enter each address as shown below. For connection to a local network, contact the network administrator for IP, Subnet Mask and Gateway Default addresses.



Appendix C Calibration Procedure 3030CB / 4030CB - High Dynamic Range modes

1.0 Introduction

This document describes the calibration and image normalization of the high dynamic range modes available from Paxscan 3030CB / 4030CB imagers. Calibration and normalization of 3030CB / 4030CB "normal" 14 bit modes (or "static gain" modes) can be handled by the command processor in the same way as any Paxscan 4030A mode.

1.1 High dynamic range operation

The high dynamic range modes in the 3030CB / 4030CB are achieved by dynamically making multiple gain selection for each image pixel. Normalization of images acquired in the Paxscan 3030CB / 4030CB high dynamic range modes, is not possible using the normalization capabilities of the Paxscan command processor. These images have to be normalized on the host system computer. To facilitate this normalization, a dynamically linked library file that contains the necessary functions to calibrate and normalize these high dynamic range modes, is available.

1.1.1 Dual gain readout image format

- Signal from each pixel is "read" twice for each image frame, first at high gain and again at low gain.
- Only available as 2x2 binning option.
- Output images have 1024 x 1536 pixels (i.e. double height).
- The first line of each output image contains data for the first binned line of the imager, acquired in high gain selection. The second line contains data for the same imager lines, but acquired in low gain selection. This sequence is maintained up to the middle of the image, where two low gain lines are found, after which the low gain / high gain line sequence is reversed.

1.1.2 Dynamic gain switching image format

- Pixel signals are read out once, at either high or low gain.
- The selection is made automatically by a level sensing circuit, pixel-by-pixel, based on its exposure level. The gain is reduced automatically for pixels with high exposure and their pixel data are flagged with a gain bit for later normalization.
- Images will be standard size, but will appear wrong, due to image regions that were acquired at substantially lower gain.
- Images are standard size images containing 2048 x 1536, 1024 x 768 or 512 x 384 pixels (depending on binning).
- Each pixel contains 14 bits of pixel data (bits 0 through 13) and a gain bit (bit 14), which is set high if the pixel data was acquired at low gain.
- Images will have pixel values ranging from 0 to 16383 for high gain pixels and from 16384 to 32767 for low gain pixels.

1.2 Function of the DLL

- The VIP_4030CB.DLL library helps the user's software application to normalize 3030CB / 4030CB high dynamic range images (establish a "software command processor" on the host PC).
- Normalization involves:
 - ☐ Compensation of the imager gain and offset non-uniformities.
 - ☐ Interpolation of defective pixels.
 - ☐ Re-interpretation of the multi-gain data from each pixel into single, linear data words. This reduces the double size images from dual gain readout, to standard size.
- In order to achieve optimum speed of operation and minimal use of PC resources, the DLL uses integer mathematics for almost all normalization and restoration calculations.
- Use of the DLL also requires access to its associated header (VIP_4030CB.h) and library (VIP_4030CB.lib) file during compilation of the user application and to the .ini file during runtime. The VIP_4030CB.h file defines the class which provides the software support for the 3030CB / 4030CB. After creating the class, the user must call *initialize()* passing the path to the directory containing the INI file and the calibration files, if they exist.

1.3 The .ini file

- Configuration and setup data relevant to the particular high dynamic range mode in use, is communicated to the DLL via *VIP_4030CB.ini*.
- The .ini file is supplied/edited by the user. Most of the parameters in the INI file are self explanatory.
- The initialization call to the DLL (*initialize(const char base_dir[])*), supplies the directory where the .ini file is located. This directory will/must also be used to store calibration data, such gain and offset data and defect maps.
- The *Data_type* parameter indicates whether the panel is operating in dual readout mode or dynamic switching mode (see VIP_4030CB.h file for defined values).
- The *ROI* parameters define the region which is used when determining the median value of an image (the ROI should at least exclude the 3 mm scintillator "shoulder" region of the imager, as well as any regions that are not exposed to X-ray during gain calibration).
- The various *limit* parameters set the percentage of median that a pixel needs to exceed, to be considered a defect.

1.4 Defect map

- Locations of defective pixels are stored in defect map image files.
- A distinction is made between "auxiliary" defects and "base" defects. The base defect map is compiled at imager production and can only be changed by user editing, using the ViVA defect editor. Auxiliary defects are detected during gain calibration. The auxiliary defect map is calculated from scratch at every calculation and contains no history.
- For standard single gain modes (i.e. where the command processor is used for normalization), these defect maps are 16 bit image files that are stored on the command processor (exactly the same as the Paxscan 4030A).

- For high dynamic range modes (i.e. where the DLL is used for normalization), defect maps are stored as more efficient binary image files, in a format that combines both base and auxiliary defect information. One defect map is stored for each gain selection, on the host PC, in the same directory as the *.ini* file (filenames *Hi_G_defect_map.bin* and *Lo_G_defect_map.bin*). Each pixel on the imager is represented by 2 consecutive bits: one auxiliary defect bit, which is recalculated by the DLL at every gain calibration and one base defect bit, which can only be modified by the ViVA defect editor.

Note: Comprehensive defect detection is a complex process, requiring a range of computationally intensive search algorithms to be performed on a set of images and image sequences that are acquired over a range of conditions. Some of these algorithms require extensive operator interaction. Comprehensive defect detection is thus not a process that should form part of a user level calibration - it is best left to skilled flat panel production personnel. The purpose of the base defect bit for each pixel is thus to store the comprehensive, production level defect information, in a manner that will prevent modification during normal calibration. The auxiliary defect bit for each pixel is re-calculated, at each gain calibration, by a rudimentary algorithm that simply marks all pixels that fall outside a preset fractional range of the gain and offset image medians. These defect thresholds are programmable through the *.ini* file, by adjusting the *XXX_offset_limit_XXX* and *XXX_gain_cal_limit_XXX* parameters (these parameters indicate defect thresholds, as a percentage of the image median). Should a defect appear during the life of the imager, but it is not reliably detected by the auxiliary defect detector, it can be added to the base map, using the ViVA defect editor.

2.0 Performing Calibration

2.1 Background info

- The user software application must initiate imager calibrations:
 - Offset calibrations as frequently and as close to image acquisition time as possible. As a rule offset calibrations should be performed at least every 30 minutes, or prior to each CBCT scan. More frequent offset calibrations are important while the imager temperature is not stable (e.g. after power-up).
 - Gain calibrations periodically - experience has shown once a month to be a good rule of thumb. More exact applications, such as CBCT, may require more frequent calibrations, as determined through experience.
- "Calibration" requires the user software to accumulate 32 bit "sum" images from the receptor (the total of a sequence of frames) and passing them to either the gain or offset calibration function in the DLL.
- All command processor normalization functions have to be turned off during acquisition of calibration images.
- Gain calibration requires the acquisition of a dark field sum image (no X-ray) and a flat field sum image (exposed to X-ray) for both gain selections used in the applicable high dynamic range mode.
 - The *gain_calibrate()* function in the DLL calculates the 32 bit difference between the flat field and dark field image. This gain image is scaled and stored as either *Hi_G_gain_img.viv* or *Lo_G_gain_img.viv*, in the same directory as the *.ini* file.

- Each file contains a value for either the relative high gain (G_{HG}) or low gain (G_{LG}) of each pixel (absolute values are not relevant).
- The median values for the high gain image ($\overline{G_{HG}}$) or low gain image ($\overline{G_{LG}}$) are also calculated by the *gain_calibrate()* function and stored in the header of the applicable gain image file.
- To allow the use of bow tie filters or non-uniform X-ray fields, the median is only calculated over the region defined by the *ROI_XXX* parameters in the *.ini* file.
- If it is deemed necessary, the user software application can now re-calculate the median gain ratio (R_G) between high and low gain. The median value for both *XXX_gain_img.viv* images must be calculated (preferable in the *ROI* region only) and the ratio of these numbers stored in the *.ini* file (as the *HL_ratio* parameter), using the *set_HL_ratio()* function.
- Offset calibration requires the acquisition of a dark field sum image (no X-ray) only.
 - When passing this sum image to the *offset_calibrate()* function in the DLL, the offset image is calculated by appropriate scaling and stored as either *Hi_G_ofst_img.viv* or *Lo_G_ofst_img.viv*, in the same directory as the *.ini* file.
 - Each file contains a value for the absolute offset of each pixel, in either high gain (O_{HG}) or low gain (O_{LG}) selection.
- Defective pixels are also detected by the *gain_calibrate()* function. The only defects detected, are those pixels falling outside the boundaries set by the applicable *XXX_gain_cal_limit_XXX* or *XXX_offset_limit_XXX* parameters in the *.ini* file. These defects are stored as auxiliary defects only (see below).
- When using dual gain readout modes, the offset calibration and normalization capabilities of the command processor can be used, instead of the DLL normalization functions, as described above. To use this shortcut, the *Hi_G_ofst_img.viv* and *Lo_G_ofst_img.viv* images must be replaced by appropriate null images, with the same names, after completion of gain calibration. Offset calibration in the command processor must be turned off prior to gain calibration and turned back on after gain calibration. Offset calibrations then requires the transmission of a single "offset calibrate" command to the command processor. This approach is not valid when using dynamic gain switching modes. All command processor corrections must be turned off when using these modes.

The calibration process requires a different sequence of actions, depending on whether dual gain readout mode or dynamic gain switching mode is used.

2.2 Calibration of dual gain readout modes

Note: The DLL must be initialized for dual gain readout mode. This is done by pointing to an *.ini* file with the parameter *Data_type* = 1 during the call to the *initialize()* function in the DLL.

2.2.1 Gain Calibration procedure

- A. If not already selected, the user software selects the dual gain readout mode to be calibrated. The mode may be described by a string such as "4030CB *bin* G1 0p5/4p DGR" (where *bin* = 2x1 or 2x2).

- B. With no X-ray exposure, the user software accumulates the sum of a sequence of images (128 images will typically suffice) from the frame grabber.
- C. This sum image is passed to the *offset_calibrate()* function twice - once with the *gain_mode* function variable set to HI_G_MODE, to calculate and store the offset image for the high gain selection and once with the *gain_mode* variable set to LO_G_MODE, to calculate and store the offset image for the low gain selection.
- D. Next, the user or user software must set up an X-ray exposure that is high enough for most pixels to be near the saturation level in the high gain lines of the uncorrected composite image. The absolute value of the exposure is not of importance, but a suitable value may require some experimentation.
- E. After the X-ray exposure is initiated, the user software accumulates the sum of a sequence of images (128 images will typically suffice) from the frame grabber.
- F. This sum image is passed to the *gain_calibrate()* function, with the *gain_mode* variable set to HI_G_MODE, which calculates and stores a gain image for the high gain selection.
- G. (OPTIONAL) If the ratio between low and high gains needs to be determined, the above sum image can be passed to the *gain_calibrate()* function **again**, with the *gain_mode* variable set to LO_G_MODE, which will calculate and store a gain image for the low gain selection. The user software application can now calculate the median gain ratio (R_G) between high and low gain. The median value for both *XXX_gain_img.viv* images must be calculated (preferable in the *ROI* region only, as defined in the *.ini* file) and the ratio of these numbers stored in the *.ini* file (as the *HL_ratio* parameter), using the *set_HL_ratio()* function. In our limited experience, it is sufficient to calculate this value once for each imager, during system manufacture.
- H. It is recommended that a second gain calibration be performed at a much higher X-ray exposure, for the low gain selection only.
- I. Set up an exposure that is high enough for most pixels in the low gain lines of the uncorrected image to be near, but below the saturation level.
- J. After the X-ray exposure is initiated, the user software accumulates the sum of a sequence of composite dual gain images (128 images will typically suffice).
- K. This sum image is passed to the *gain_calibrate()* function, with the *gain_mode* variable set to LO_G_MODE, which calculates and stores a gain image for the low gain selection.

2.2.2 Offset calibration procedure

- A. If not already selected, the user software selects the dual gain read-out mode to be calibrated. The mode may be described by a string such as "4030CB *bin* G1 0p5/4p DGR" (where *bin* = 2x1 or 2x2).
- B. With no X-ray exposure, the user software accumulates the sum of a sequence of composite dual gain images (128 images will typically suffice).
- C. This sum image is passed to the *offset_calibrate()* function twice - once with the *gain_mode* variable set to HI_G_MODE, to calculate and store the offset image for the high gain selection and once with the *gain_mode* variable set to LO_G_MODE, to calculate and store the offset image for the low gain selection.

2.3 Calibration of dynamic gain switching modes

Note: The dynamic gain switching mode is not supported at this time. The DLL must be initialized for dynamic gain switching mode. This is done by pointing to an .ini file with the parameter *Data_type* = 0 during the call to the *initialize()* function in the DLL.

3.0 Performing Image Normalization and Restoration

3.1 Background

- The 3030CB / 4030CB dll performs offset and gain correction and defective pixel correction.
- Command processor normalization functions are turned off during acquisition in high dynamic range modes (except when using the command processor to perform offset correction in dual gain readout modes - see above).
- Uncorrected raw images are passed to the *correct_image()* function in the DLL.
- Normalized X-ray intensity values for each pixel are calculated according to the formula (see paragraph 2.1 for a description of the symbols):

$$I_{pixel,HG} = (D_{pixel,HG} - O_{HG}) \times \overline{G_{HG}} / G_{HG}, \text{ for high gain pixel data } (D_{pixel,HG}) \text{ and}$$

$$I_{pixel,LG} = \overline{R_G} \times (D_{pixel,LG} - O_{LG}) \times \overline{G_{LG}} / G_{LG}, \text{ for low gain pixel data } (D_{pixel,LG}).$$

- This calculation completes the normalization task for images acquired with dynamic gain switching modes. In this case, the decision to calculate and use either $I_{pixel,HG}$ or $I_{pixel,LG}$ is based solely on the value of the gain flag that is present in each pixel data word received from the imager.
- For images acquired in dual gain readout modes, the decision to use either the low gain or high gain pixel data values is made for each pixel, as part of the normalization calculation. Two software threshold levels, T_{low} and T_{high} are defined in the .ini file (parameters *Threshold_A* and *Threshold_B*). For all pixels with $D_{pixel,HG}$ below T_{low} , the $I_{pixel,HG}$ value is used as the representative equivalent intensity. For all pixels with $D_{pixel,HG}$ above T_{high} , the $I_{pixel,LG}$ value is used as the representative equivalent intensity. For pixels with $D_{pixel,HG}$ between T_{low} and T_{high} , a linear interpolation of $I_{pixel,HG}$ and $I_{pixel,LG}$ value is used, thus guaranteeing a smooth transition in image regions with intensity near the transition threshold.
- The effective image bit depth is now larger than 16 bits. To reduce data back to 16 bits per pixel, the *correct_image()* function will compress output images into a pseudo floating point format. The corrected image will again contain 14 bits of pixel data and 2 bits indicating the amount to shift the 14 data bits.
- To restore compressed images, the gain bit can be used as a look-up table address bit or it is anticipated that sufficient linearity may be achieved by multiplying pixels flagged by the gain bit, by the gain ratio value (see "calibration" above). The result of this de-compression operation will be more than 16 bits per pixel.

- Alternatively, the DLL also contains a function that can be used to provide a corrected, scaled, linear, 16 bit version of the raw image. This is achieved by scaling the data by a factor supplied by the user. Any resulting values greater than 65535 will be set to 65535.
- The dll requires a directory in which the following files are stored (A sample .ini file is provided, the other files required in the directory will be generated by the dll when calibration is performed.):
 1. INI parameter file - *This file communicates imager setup and user preference info to the DLL. It has to be edited by the user*
 2. High gain offset file - *this file is calculated by the offset_calibrate() function, from a sum image accumulated by the user software as described below.*
 3. Low gain offset file - *similar to High gain offset file.*
 4. High gain gain image file - *this file is calculated by the gain_calibrate() function, from a sum image accumulated by the user software as described below.*
 5. Low gain gain image file - *similar to High gain gain file.*
 6. High gain defective pixel map - *this file contains an auxiliary defect map, as calculated by the gain_calibrate() function and a base defect map that is calculated at imager production and editable by the ViVA defect editor.*
 7. Low gain defective pixel map - *similar to High gain defective pixel map file.*

3.2 Performing normalization

- The `correct_image()` routine performs the offset and gain correction and defective pixel correction.
- The supplied 16 bit image is replaced by the corrected 16 bit image.
- Each pixel value contains the corrected pixel value in the low order 14 bits and a shift value in the high 2 bits.
- Whenever the true pixel value must be used in an application of for display, a table lookup must be performed to obtain the desired pixel value.
- For images acquired in dual gain readout modes, the corrected image is only half the size as the supplied image.
- The .ini parameters `Threshold_A` and `Threshold_B` are only used for dual readout images. The offset and gain corrected value for the high gain reading is first determined. If the high gain value of a pixel is below `Threshold_A`, this is the corrected pixel value. If the high gain value is above `Threshold_B`, the corrected pixel value is determined from the corrected low gain reading. If the value is between `Threshold_A` and `Threshold_B`, interpolation is performed between the high gain and low gain corrected readings to insure a smooth transition.
- The `generate_scaled_image()` function can be used to produce a linearized version of the compressed data format images produced by `correct_image()`.

Appendix D Multiple gain ranging readout method to extend the dynamic range of amorphous silicon flat panel imagers.

Pieter G. Roos^{*a}, Richard E Colbeth^a, Ivan Mollov^a, Peter Munro^b, John Pavkovich^a, Edward J. Seppi^a, Edward G. Shapiro^b, Carlo A. Tognina^a, Gary F. Virshup^a, J. Michael Yu^a, George Zentai^a, Wolfgang Kaissl^c, Evangelos Matsinos^c, Jeroen Richters^c, Heinrich Riem^c,

^aVarian Medical Systems, Ginzton Technology Center, 2599 Garcia Ave, Mountain View, CA 94043

^bVarian Medical Systems, Oncology Systems Division, 3100 Hansen Way, Palo Alto, CA 94304

^cVarian Medical Systems, Imaging Laboratory, Neuenhoferstrasse 107, 5400 Baden, Switzerland

ABSTRACT

The dynamic range of many flat panel imaging systems are fundamentally limited by the dynamic range of the charge amplifier and readout signal processing. We developed two new flat panel readout methods that achieve extended dynamic range by changing the readout charge amplifier feedback capacitance dynamically and on a real-time basis. In one method, the feedback capacitor is selected automatically by a level sensing circuit, pixel-by-pixel, based on its exposure level. Alternatively, capacitor selection is driven externally, such that each pixel is read out two (or more) times, each time with increased feedback capacitance. Both methods allow the acquisition of X-ray image data with a dynamic range approaching the fundamental limits of flat panel pixels. Data with an equivalent bit depth of better than 16 bits are made available for further image processing. Successful implementation of these methods requires careful matching of selectable capacitor values and switching thresholds, with the imager noise and sensitivity characteristics, to insure X-ray quantum limited operation over the whole extended dynamic range. Successful implementation also depends on the use of new calibration methods and image reconstruction algorithms, to insure artifact free rebuilding of linear image data by the downstream image processing systems.

The multiple gain ranging flat panel readout method extends the utility of flat panel imagers and paves the way to new flat panel applications, such as cone beam CT. We believe that this method will provide a valuable extension to the clinical application of flat panel imagers.

Keywords: Flat panel, cone beam CT, charge amplifier, gain switching, dynamic range, radiography, dual gain, multiple gain

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in Proceedings of SPIE, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.


1.0 INTRODUCTION

1.1. The need for extended dynamic range

Most commonly available amorphous silicon flat panel X-ray imaging systems deliver digital image data with a digital depth of 12 bit or 14 bit. While extensive experience has shown that these systems achieve sufficient quantization resolution to perform excellent radiographic imaging, certain demanding applications, such as subtraction angiography and cone beam computer tomography (CBCT), will benefit from the higher dynamic range and better quantization resolution afforded by 16 bit, or higher, quantization. This is especially true in the case of flat panel based CBCT, where 14 bit linear projection data can be used to reconstruct only adequate volumetric images, while 16 bit data acquisition facilitates the reconstruction of good quality volumetric images.

The quality of flat panel based CBCT imaging is deteriorated by 14 bit projection data acquisition, mainly through three mechanisms: 1) large relative errors in beam intensity values measured through dense anatomy, resulting from too large quantization steps, cause streak artifacts off dense objects, 2) insufficient resolution of pixel gain and offset normalization causes ring artifacts in third generation CBCT systems and 3) truncation of low density anatomical detail at patient extremities, due to insufficient dynamic range, results in shadow artifacts and incorrect Hounsfield numbers. The effects of the first two degradation mechanisms are clearly visible in Figure 1, while the third degradation mechanism is discussed by a number of authors, such as Seeram [4].

Figure 1 Flat panel CBCT images of a head phantom: 16 bit system (left) and 14 bit system (right)



1.2. Limitations of flat panel imagers

One commonly used indicator of the dynamic range capability of a flat panel based imaging system is the ratio of the system's RMS electronic noise, expressed as an equivalent signal value, to the signal level where sufficient non-linearity occurs for the pixel normalization process to fail. The available noise-to-saturation dynamic range of commercial flat panel based imaging systems is typically less than the 16k:1 quantization range afforded by its 14 bit A/D conversion. On the other hand, the fundamental limit to the dynamic range of amorphous silicon flat panels, as imposed by amorphous

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.


This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

silicon pixels, may be well in excess of 50,000:1. The opportunity for increased dynamic range can be described by the following qualitative argument: an easy measurement of a commercially available flat panel based imaging system, with 194 μm TFT/photodiode pixels [1], shows such a system to achieve an electronic noise level of better than 1700 equivalent electrons RMS pixel noise, when used without any pixel binning. Based on the pixel capacitance and bias voltage, the pixels of this flat panel will only saturate at an accumulated signal charge of approximately 50 million electrons. Thus, the potential noise-to-saturation dynamic range for this imager is 30,000:1, when read out without any pixel binning. A similar argument concludes that this same imager could achieve a noise-to-saturation range of 60,000:1 when 2x2 pixel binning is used and 240,000:1 when 4x4 binning is used. Applying such arguments to different flat panel detector types will reveal similar unrealized dynamic range capabilities for most imaging systems.

In the majority of imager applications, the accumulated charge signals in the flat panel pixels are detected and converted to voltage signals by means of multiple, parallel charge integration amplifiers, as depicted in Figure 2. The characteristics of these charge integration amplifiers and the subsequent signal processing electronics impose the actual limits on the dynamic range available from practical flat panel based imaging systems. In TFT/photodiode type imagers, the incoming X-ray projection image is converted to a light image by a scintillator layer. This light image is detected by the matrix of amorphous silicon photodiodes of the flat panel detector and the accumulated signal charge is stored on the photodiode capacitance until readout occurs. During the readout phase, the accumulated signal charge of each pixel is transferred sequentially to the integration capacitor (C1 in Figure 2) of a readout amplifier channel, thus converting the charge signal to a voltage signal. The voltage signal is processed through a sample-and-hold circuit and correlated double sampling (CDS) corrected, multiplexed and then converted to a digital word stream.

In most systems, the charge amplifier, sample-and-hold, CDS and multiplexing functions are implemented in multi-channel custom ICs, while the analog-to-digital conversion function is performed by commercial, off-the-shelf A/D converters.

Figure 2 A symbolic representation of a typical a:Si flat panel detector readout method



Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

The low end of a flat panel imager's dynamic range is limited by noise generated in the pixels and signal processing chain. Noise sources include pixel kTC noise, thermal noise generated by imager data lines, charge amplifier voltage noise and noise generated in the signal processing chain [2, 3]. In Varian's Paxscan 3030CB / 4030CB imager, that was developed to take advantage of the read out methods that are described here, these sources add up to approximately 1700 electrons RMS equivalent integrator charge, as mentioned above. On the other hand, the high end of this dynamic range is usually determined by the voltage swing that can be achieved by the charge amplifier and signal processing chain, while maintaining sufficient linearity to facilitate subsequent pixel gain and offset normalization. For the above system, this point is reached at about 2 volt swing, or 6 million electrons stored on the 0.5 pF integration capacitor. This yields a 3,500:1 noise-to-saturation dynamic range, which matches very well with the 16k quantization steps available from a 14 bit A/D converter. Using a 1 pF integration capacitor, as in Varian's Paxscan 4030A imaging system, will achieve a dynamic range in the order of 6,000:1. These ranges are however very substantially less than the actual dynamic range available from the amorphous silicon flat panel detector.

Changing the capacitor will typically not result in an increase in dynamic range - decreasing the capacitor may decrease equivalent electronic noise, but will cause saturation at lower exposure; increasing the capacitor will increase the saturation exposure, but may cause alternate noise sources to become dominant at low exposure levels. An alternative readout architecture is required in order to realize the dynamic range capabilities of flat panel detectors in practical imaging systems.

2.0 MULTIPLE GAIN RANGING READOUT METHOD

In order to achieve a flat panel based imaging system with dynamic range approaching the capability of the amorphous silicon flat panel, we developed a new charge readout amplifier IC that is capable of changing the charge amplifier feedback capacitance of each channel dynamically and on a real-time, pixel-by-pixel basis. Each amplifier channel also includes a latched comparator that can be enabled to change the feedback capacitance automatically, based on the amount of charge presented to the amplifier, by each individual pixel. The architecture for this readout method, as implemented in Varian's Paxscan 3030CB / 4030CB flat panel imaging system, is depicted in Figure 3. Use of this readout architecture enables the implementation of two alternative high dynamic range readout methods.

2.1. Dynamic Gain Switching


In the so-called Dynamic Gain Switching mode, a comparator is used to increase the feedback capacitance automatically when pixels with large accumulated charge are selected for readout. When the voltage accumulated in the charge integrator exceeds the dynamic threshold, which is a global voltage set externally for all channels, the comparator switches an additional, much larger feedback capacitor (C4 in Figure 3), in parallel with the fixed feedback capacitor (C1 in Figure 3). In the 3030CB / 4030CB imager, capacitor values are selected to cause an 8x reduction in gain for pixels that exceed the programmable signal level. Regardless of whether a pixel was acquired with reduced gain, the signal from the charge amplifier is then processed through the standard correlated double sampling circuit and converted to a digital word by the 14 bit A/D converter. To enable recovery of linear pixel data by the downstream image processor, the output of the latched comparator is sampled by a separate multiplexer and inserted as an additional "gain bit" (bit 15 of 16 bits) into the digital video data word at the output of the A/D converter.

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in Proceedings of SPIE, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

This provides a marker flag for pixel data that were acquired with reduced gain.

Figure 3 Symbolic representation of a readout method to enhance flat panel dynamic range



2.2. Dual Gain Readout

The comparator circuit can also be disabled and the low gain mode can then be activated globally, on a pixel-by-pixel basis through the common "forced low gain" control signal. This capability is used to implement the alternative Dual Gain Readout mode, in which the signal accumulated by each pixel is read twice, first at high gain and then again at low gain (i.e. for the same X-ray exposure frame). This is done without activating the reset switch in between the two readings. This sequence allows the non-destructive double reading of each pixel signal packet. Both samples are processed in sequence by the correlated double sampling circuit and converted to a digital word each by the 14 bit A/D converter. Both a high gain and a low gain value are provided for each pixel, thus resulting in digital image frames with twice the byte size of conventional images. The Dual Gain Readout mode has the advantage that the gain decision can be made in an intelligent manner by the downstream image processor, but due to the double frame size, the imager can only operate at half the frame rate that the imaging system would otherwise be capable of.

2.3. Correlated double sampling

Correlated double sampling (CDS) is an important signal processing step in the data acquisition sequence of most flat panel imagers. With reference to Figure 2, this sequence normally consists of: 1) activate the RESET switch, 2) activate the S/H2 switch to acquire a ZERO sample of the charge amplifier output, 3) activate the pixel TFT, 4) activate the S/H1 switch to acquire a SIGNAL sample of the charge amplifier output and 5) subtract the ZERO sample from the signal sample. CDS has the threefold benefits of 1) cancellation of the reset KTC noise of the charge amplifier, 2) significant reduction of 1/f noise generated in the charge amplifier and subsequent circuits and 3) cancellation of offset voltage and the drift in offset voltage of signal processing circuits, with the exception of offset effects generated in the pixel itself.

Since both high dynamic range modes described above involve changing the charge amplifier gain after the TFT was activated, this may compromise the validity of the CDS subtraction for low gain data, as the ZERO sample would always be acquired at high gain. Cancellation of undesirable effects caused in subsequent circuits will obviously be left intact, but the design of the charge amplifier circuit required special attention, to insure that its offset and 1/f noise characteristics don't change with reduction in gain. Cancellation of the reset KTC noise will however be invalid for low gain data and an increase in electronic noise will thus be inevitable for low gain data. As will be shown in section 3, low gain data are only used where high levels of exposure are encountered and photon noise is sufficiently high to insure quantum limited operation and the impact of this additional low gain noise is thus negligible. This is only true however when the jump from high to low gain is not too large. Low gain noise thus places the limit on the size of gain step and therefore on the amount of dynamic range extension that can be achieved by any multiple gain ranging read out method.

2.4. Normalization

2.4.1. Imager calibration

When using these high dynamic range readout methods, each pixel is characterized by a unique offset and gain calibration value for both low and high gain selections. We developed a method of calibrating and correcting for these non-uniformities, without requiring an accurate knowledge of the x-beam intensity during calibration exposures. This results in an easy to perform on-site calibration that does not need any special equipment or advanced level of training.

Dark field and flat field images are acquired, as during any flat panel calibration procedure [5, 6], but this is done for both low and high gain settings of a high dynamic range mode. As for a conventional flat panel, flat field and dark field images are the average of a sufficient number of frames to reduce the image noise to an acceptable level [6]. A method exists whereby the imager can be forced into simulated dynamic gain switching, even when no X-ray exposure is present. For good calibration quality, two flat field exposures are acquired for the low gain setting: one flat field image is acquired at the same exposure level as the high gain flat field and a second flat field image is acquired at a significantly higher exposure.


In our method, "gain images" (a 2 dimensional map of relative pixel sensitivities) are calculated from each of the three flat field images, by subtracting the applicable dark field image. The high gain image and the high exposure, low gain image are stored for use during image acquisition. The low exposure, low gain image is used to calculate the ratio of high-to-low gain ("gain ratio") for each pixel, by dividing it into the high gain image. This gain ratio image is also stored for use during image acquisition. The dark field exposures acquired during calibration are discarded. Dark field images, that are used for image offset calculation, are then acquired for each gain setting, as close as possible to the time of the actual image acquisition [5]. Five calibration parameters are thus stored for each pixel (in the form of five calibration images): the relative high gain (G_{HG}) and low gain (G_{LG}) of each pixel (absolute values are not important), the absolute offset of the high gain (O_{HG}) and low gain (O_{LG}) settings and the gain ratio (R_G). The median values for the high gain image ($\overline{G_{HG}}$) and low gain image ($\overline{G_{LG}}$) are also calculated and stored.

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

In a simplified version of the calibration procedure, only the median gain ratio for the whole imager is calculated and applied to all pixels during image normalization. This obviates the need to store and load the additional gain ratio calibration image, thus potentially reducing demands placed on the system processor and memory. As can be seen in Figure 4, the gain ratios of 98% of the pixels of the 4030CB imager fall within 2% of the median gain ratio. However, most of this deviation from the nominal gain ratio is removed by the gain normalization process. It is our experience that sufficient accuracy of linearization is achieved by using just the median gain ratio. For demanding applications such as high quality cone beam CT, more accurate normalization may be required and the choice of calibration methods is thus left to the system designer.

Figure 4 Distribution of pixel gain ratios, as measured for the 4030CB imager



2.4.2. Image correction

For each image frame acquisition, the equivalent intensity value for each pixel is calculated as:

$$I_{pixel,HG} = (D_{pixel,HG} - O_{HG}) \times \overline{G_{HG}} / G_{HG}, \text{ for high gain pixel data } (D_{pixel,HG}) \text{ and}$$

$$I_{pixel,LG} = R_G \times (D_{pixel,LG} - O_{LG}) \times \overline{G_{LG}} / G_{LG}, \text{ for low gain pixel data } (D_{pixel,LG}).$$

This completes the normalization task for images acquired with the *dynamic gain switching method*. For the *dual gain readout method*, the decision to use either the low gain or high gain pixel data values is made as part of the normalization calculation. Two software threshold levels, T_{low} and T_{high} are defined in software configuration. For all pixels with $D_{pixel,HG}$ below T_{low} the $I_{pixel,HG}$ value is used as the representative equivalent intensity. For all pixels with $D_{pixel,HG}$ above T_{high} , the $I_{pixel,LG}$ value is used as the representative of $I_{pixel,HG}$ and $I_{pixel,LG}$ values is used, thus guaranteeing a smooth transition in image regions with intensity near the transition threshold.

In the case of the *dynamic gain switching method*, the decision to calculate and use either $I_{pixel, HG}$ or $I_{pixel, LG}$ is based solely on the value of the gain flag that is present in each pixel data word.

2.5. The Paxscan 4030CB imaging system

The Paxscan 4030CB imaging system is an extended version of Varian's well known Paxscan 4030A imager, which is widely used in radiography, fluoroscopy and angiography applications [7]. The 4030CB features the same 2048 x 1536 amorphous silicon flat panel matrix, with 194 μm pixels, and a 39.7 x 29.8 cm active area. The same 600 μm thick Cesium Iodide scintillator is used. The imager is housed in the same housing as the 4030A imager and is controlled by the same command processor and power supply. The command processor is used to control the imager, perform real-time image normalization for the fixed gain modes and to send these normalized images to the end-user's radiography platform, either via a real-time digital video link or via a standard Ethernet interface. See reference 1 for a more extensive description of the Paxscan 4030A system.

The 4030CB has three selectable integration capacitors (0.5 pF, 4 pF and 16 pF) available to optimize dynamic range and exposure range for specific applications. In fixed gain modes, any of these three capacitors can be selected, together with 1x1, 2x2 or 4x4 binning, and a selection of 1x, 2x or 4x electronic gain. The binning selection determines the maximum frame rate capability of the imager, as shown in Table 1. Additionally the two high dynamic range read out methods described herein are available, with selections between some of the above capacitor values. These selections are made available to the user or radiography system via pre-defined modes that are stored in the command processor. The command processor supports up to 7 selectable imaging modes at any one time. The interface to the 4030CB will be familiar to existing users of the 4030A, with the only major difference being the availability of new imaging modes and the requirements for more complex calibration procedures for the high dynamic range modes.

Table 1 Maximum frame rate capability of the Paxscan 4030CB

	Full resolution - fixed gain and dynamic gain switching modes	2x2 bin - fixed gain and dynamic gain switching modes	2x2 bin – dual gain readout	4x4 bin - fixed gain and dynamic gain switching modes
Max. frame rate	7.5 Hz	30 Hz	15 Hz	60 Hz

3.0 RESULTS

Results reported below are those results that specifically characterize the operation of the multiple gain ranging methods. Due to the similarity of the 4030CB system with Varian's 4030A flat panel imaging system, we did not deem it necessary to report the more common measures of image quality, such as MTF and DQE, as these parameters have been evaluated and reported elsewhere for the 4030A system [1] and are mostly identical between the two systems. The only exception is the low dose DQE of the 4030CB system, which benefits from the higher sensitivity of the high gain mode and the resultant reduction in quantum limit. A formal measurement of this DQE comparison is not available at this time, but will be available upon request from the authors in the near future.

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

3.1. Dynamic range

Table 2 4030CB dynamic range in available imaging modes

	Saturation-to-noise range			X-ray exposure range		Digital range	
	Electronic noise (ADU)	Saturation signal (ADU)	Dynamic range	Quantum limited exposure (μ R)	Saturation exposure (μ R)	Quantization range	Eff. bit depth (bits)
No binning, gain 2							
Dynamic gain switching	5.32	80500	15100	2.75	3550	80500:1	16.3
0.5 pF fixed	5.32	14500	2700	2.75	595	14500:1	13.8
4 pF fixed	3.57	14800	4150	35.7	4200	14800:1	13.8
2x2 binning, gain 1							
Dual gain readout	4.33	80100	18500	1.00	1800	80100:1	16.3
Dynamic gain switching	4.37	84200	19300	1.03	2062	84200:1	16.4
0.5 pF fixed	4.37	14300	3300	1.03	311	14300:1	13.8
4 pF fixed	3.14	14800	4700	15.6	2104	14800:1	13.8
0.5 pF fixed, gain 2 (fluoroscopy mode)	7.25	12900	1700	0.71	125	12900:1	13.6

Numerous definitions of dynamic range exist. For the purposes of comparison with standard readout methods, the dynamic range of the 4030CB imaging system was measured in terms of a few of the more common definitions of dynamic range. These results are shown in Table 2. For these data, electronic noise was measured as the pixel standard deviation of the subtraction of two uncorrected dark field frames, divided by $\sqrt{2}$. Quantum limited exposure was defined as that exposure where electronic noise equals quantum noise, i.e. where the total image noise = $\sqrt{2}$ x electronic noise.


The results show that multiple gain readout methods offer an increase of between 4 and 6 times in both dynamic range and usable X-ray exposure range over that offered by single gain modes. The potential 70,000:1 dynamic range, inherent to 2x2 binned read out, has not yet been achieved. This would require a larger step in gain, which would result in non-quantum limited operation near the switchover threshold (see below). Some ongoing work to improve this limitation is described in section 4.

3.2. Signal-to-noise performance

During the development of the flat panel read out methods described here, we found the signal-to-noise ratio versus dose behavior of the imaging system to be a very important measure of the successful implementation of multiple gain ranging readout methods. When the step between high gain and low gain is made too large, signal levels in low gain pixels become too low and the imager no longer achieves quantum limited operation for exposure levels near the switching threshold. This will show up in a SNR vs. dose plot as a deviation from the ideal quantum limited behavior. The same applies to most crossover artifacts due to incorrect normalization.

The SNR vs. dose results, as measured for the Paxscan 4030CB dynamic range modes, is shown in Figure 5. The thick line was overlaid to show ideal, quantum limited behavior and plot deviations from this line indicate non-quantum limited behavior.

Figure 5 Signal-to-noise performance over the extended dynamic range



The signal-to-noise versus dose results indicate that the choice of gain settings, as implemented in the Paxscan 4030CB imager, is optimal, given the constraints of the rest of the system. This can be concluded from the small deviation from ideal, quantum limited performance that is visible at exposure levels of approximately 250 μ R. This is the intensity neighborhood where low gain data starts being used. As the signal levels are relatively low compared to the electronic noise characteristic of the low gain setting, the imager is on the verge of reverting to non-quantum limited operation. A larger feedback capacitor would have resulted in a too large gain reduction and electronic noise would have dominated in the transition region. See paragraph 2.3 for an explanation of the high level of electronic noise applicable to the low gain setting.

3.3. Image artifacts

Due to the risk of producing contour type artifacts in image regions with intensity levels near the gain switchover threshold, subjective image quality serves as another important check on the applicability of our methods to diagnostic imaging. Figure 6 shows a slice reconstructed from a CBCT scan of a human pelvis and Figure 7 shows one of the projection images from this scan. These images were acquired with a Paxscan 4030CB based CBCT system using the dual gain readout method. The projection image was processed by a severe unsharp masking algorithm, to enhance any possible boundary artifacts resulting from gain switching. No such boundary artifacts are visible in either image. The general quality demonstrated by the CBCT slices of Figure 1 and Figure 6 also show in general the suitability of the Paxscan 4030CB imaging system for CBCT applications.

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

Figure 6 CBCT image of a human pelvis, acquired with the Paxscan 4030CB imaging system




Figure 7 Projection image of human pelvis, with unsharp masking




3.4. Other CBCT related performance parameters

The performance measurements reported below are not affected by the multiple gain readout methods, but due to the CBCT application focus of the Paxscan 4030CB imager, specific attention was paid to these parameters.

3.4.1 Image lag

Due to the severe image artifacts that could result from image lag in CBCT applications, the design of the Paxscan 4030CB imager was optimized to reduce image lag. The details of this optimization are beyond the scope of this article, but for information, the results of a lag measurement are shown in Figure 8.

Figure 8 Image lag of the 4030CB imager, as measured at 30 frames per second



3.4.2. X-ray absorption efficiency

Computed tomography imaging is usually carried out at the higher end of the diagnostic X-ray energy range [4, 5] in order to reduce patient dose and also to reduce the severity of beam hardening artifacts. This means however that more emphasis needs to be placed on X-ray absorption efficiency of X-ray quantum energy up to 125 keV. Table 3 shows the absorption efficiency of the 4030CB scintillator layer, for the X-ray spectra that the imager is likely to encounter in flat panel based CBCT applications. The first beam represent the likely spectrum in many CT imaging systems, while the beams with added Copper filtration represent the increasing beam hardening through patient anatomy.

Table 3 Absorption efficiency of the 4030CB scintillator

X-ray beam description	Absorption efficiency
125 kVp through 0.5 mm Cu	66.0%
125 kVp through 1 mm Cu	59.4%
125 kVp through 1.5 mm Cu	54.0%
125 kVp through 2 mm Cu	50.2%

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in *Proceedings of SPIE*, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

4.0 CONCLUSION AND FUTURE WORK

The dynamic gain switching and dual gain read out modes are very successful methods of extending the dynamic range and the usable exposure range of flat panel imagers. In their present implementation they achieve up to 6x the dynamic range of comparable single gain modes, but still don't achieve the dream of actually realizing the total dynamic range capabilities of amorphous silicon flat panels. We are at present developing an additional method, the so called "2x1 dual gain read out", that does not suffer from the correlated double sampling noise penalty described in paragraph 2.3. Preliminary work has already shown a very substantial reduction in low gain noise and it is likely that further refinement of this method will allow the utilization of the 0.5 pF to 16 pF gain step that is already available on the 4030CB. This is one way in which we hope to extend the dynamic range of flat panel imagers even further. Other extensions to the multiple gain ranging read out, such as triple gain readout and dynamic gain switching in 4x4 binning are also being developed to further extend the utility of the 4030CB imaging system.

Even in its present embodiment however, the Paxscan 4030CB imager provides a very valuable extension to the utility of flat panel imagers. Our results show that it is an excellent imager to use in flat panel cone beam CT applications.

REFERENCES

1. R. E. Colbeth et. al., "40 x 30 cm Flat Panel Imager for Angiography, R&F, and Cone-Beam CT Applications", Proc SPIE Medical Imaging 2001, Vol. 4320, Feb. 18-20, 2001, San Diego, CA.
2. R. E. Colbeth et. al., "Flat panel imaging system for fluoroscopy applications", Proc SPIE Medical Imaging 1998, Vol. 3336, Feb. 22-24, 1998, San Diego, CA.
3. R. E. Colbeth et. al., "Characterization of a third generation, multi-mode sensor panel", Proc SPIE Medical Imaging 1999, Vol. 3659, Feb. 21-23, 1999, San Diego, CA.
4. E. Seeram, "Computed Tomography - Physical Principles, Clinical Applications & Quality Control", W. B. Saunders Company, 1994.
5. Jacob Beutel, Harold L. Kundel and Richard L. Van Metter, "Handbook of Medical Imaging, Volume 1 Physics and Psychophysics" - SPIE Press, 2000.
6. J. P. Moy, B. Boset, "How does real offset and gain correction affect the DQE in images from X-ray flat detectors", Proc SPIE Medical Imaging 1999, Vol. 3659, Feb. 21-23, 1999, San Diego, CA.
7. Shigeyuki Ikeda, et. al. "Development and Evaluation of a Digital Radiography System using a Large-Area Flat Panel Detector", Proc SPIE Medical Imaging 2003, Vol. 5030, Feb. 15-20, 2001, San Diego, CA.

Copyright 2004 Society of Photo-Optical Instrumentation Engineers.

This paper was published in Proceedings of SPIE, Vol. 5368, February 2004, San Diego CA and is made available as an electronic reprint with permission of SPIE. One print or electronic copy may be made for personal use only. Systematic or multiple reproduction, distribution to multiple locations via electronic or other means, duplication of any material in this paper for a fee or for commercial purposes, or modification of the content of the paper is prohibited.

Numerics

16-bit Video Output Signals 117
3030CB Operational Modes, 21
4030CB Operational Modes, 20

A

Acquire Images, 27, 30
Acquisition, 90
Acquisition/Display, 73
Acquisition Menu/Toolbar, 65
Add All Defective Pixels, 87
Add Offset to Pixels, 92
Add/Subtract, 92
AIA Standard Serial Interface, 43
Allocate Buffers, 78
Ambient Temperature, 26
Amorphous Silicon, 16
 Features and Benefits, 16
 vs. CCD or CMOS Sensors, 16
Amorphous Silicon, 11, 16
Analog Gain, 20, 41, 42
Analog Offset Calibration, 20, 34, 40, 83
Analog Offset Settings Dialog Box, 83
Analog-to-Digital Converters, 17
Analysis Menu: Image Statistics, 39
Apply Recursive Filter, 94
Auto & Invert W/L, 61
Auto W/L Button, 61

B

Basic Gain Calibration, 29
Basic Image Manipulation, 58
Basic Menu Commands, 79
Basic Offset Calibration, 28
Boot Up, 27

C

Cable Connections, 25
Calibration, 19, 20, 33, 36
Calibration Schedule, 135
Calibration Setup, 73
Capture first N frames, 77
Capturing a Flat Field image, 34
C-Arm, 13
CCD-based Systems, 15
CE, 19
Cesium Iodide, 13, 16
Charge Integrating Detectors, 16
Circuit Overload, 27
Client/Server Relationship, 147
Close, 89
Closing Images, 54
Column Segment Editing, 87
 With keyboard actions, 88
 With mouse actions, 88
 With the column segment list, 88
Command Processor, 13, 18, 19, 21, 84, 111

Connector and Cable Pinouts, 122
Ethernet Port, 127
Hardware Specifications, 111
Hardware Configurations, 112
Internal Configuration, 18
Serial Interfaces, 126
Specifications, 126
Termination Scheme and Loading, 123
 LVDS, 123
Timing, 123
User Synchronization Mode, 123
Command Processor and Computer Interface, 147
Command Processor Component Boards, 18
Communication Link, 65
Communications Interface, 14
Components, 13, 24
Cone Beam, 95
Configuration Files, 97, 105
Configuration of the Receptor, 15
Configure a Particular Mode, 103
Configure Utility Application, 97
Connecting the Cables, 24
Connection Attributes, 56
Connection at Startup, 56
Context Menus, 59, 60
Continuous Acquisition, 20
Continuous Operation, 28
Continuous Use, 14
Control and Monitoring, 125
Control Commands, 28
Control of the Imager, 14
Cooling Requirements, 131
Copying Images, 55
Correct Image, 95
CPU, 19
CPU/Motherboard, 18
Cursor Functions, 58
Customer Configuration Mode, 98

D

Dark Field, 19, 35, 37
DataValid, 120
DCDS Enable, 84, 104
Dead Pixels, 14
Debug Verbosity, 85
Default Hardware Handshaking Interface, 114
Default Mode, 21, 27
Defects, 85
Defect Correction, 40
Defect Map Editor, 85
Defect Map Threshold Tool, 89
Defective Pixel Maps, 40
Defective Pixel, 19, 22, 86, 89
Definitions of Errors, 44
Determining IP Addresses, 147
Diagnostic Energy Imaging, 16
Disable Display During Capture, 78
Display Test Pattern, 84

Displaying Images in non-standard formats, 56
Dispose Video, 78
DRAM, 19
Dripping Moisture, 26
Dynamic Range, 16, 40

E

Edit Menu & Preferences, 56
Edit Toolbar & Image Manipulation, 58
Edit Values, 62
Edit W/L, 62
Electro-Magnetic Compatibility, 132
Electron Mobility in a-Si, 16
Electronics, 17
Engineering Mode, 98
Establishing Connection, 28
Ethernet, 14
Ethernet and High Level Serial Interface, 43
Ethernet and High Level Serial Interface Architecture, 43
Executive Software Application, 18
Extended Gain Calibration, 69
External Synchronization 112
 Pin Assignments, 113

F

File Menu & Image Files, 51
File Retrieval, 85
File Transmittal, 84
Find Noisy Pixels, 90
Find Noisy Pixels Dialog, 90
Fixed Pattern Noise, 21
Flash Memory, 18, 106, 109, 112
Flat Field, 19, 34
Flat Panel Displays, 17
Flat Panel Sensor, 13
Fluoroscopic mode, 21, 30, 36, 72
Fluoroscopy-High-Sense, 20,
Fluoroscopy (Normal)-Full Resolution, 20
Frame Rate, 20
Frame Timing, 118
Frame-to-frame Noise, 14
Full Overlay, 48
Full Specification, 27
Full-resolution Mode, 123
Function Call Paradigm, 44

G

Gain and Offset reference images, 34, 35
Gain Calibration, 20, 29, 34, 36, 39, 40
Gain Median, 39
Gain Ratio Calibration, 68
Gain Reference Image, 33
Gain Settings, 73
Gamma Function, 22
Gate Driver Chips, 17
Generate Scaled Image, 95

Get Frame from Sequence, 77
Getting Started, 23
Global Control Card, 112
Glossary, 143
Gray Levels, 57
Gray Level Mappings for Linear and
 Atan/s-curve Functions, 64

H

Hardware and Software Interface, 18
Hardware Components, 111
Hardware Handshaking, 14, 73, 112
High Level Serial Interface, 43
Hostdown Utility Application, 105, 108
How To Reach Us, 141
HSYNC, 117, 119, 120
HyperTerminal, 137

I

Identifying Noisy Pixels, 91
Idle Periods of Operation, 28
Image Acquisition, 30, 66
Image Arithmetic, 92
Image Artifacts, 168
Image Edit (vertical) Toolbar, 51, 58
Image Information, 50
 Image Tab, 50
 System Tab, 50
 Video Tab, 51
Image Intensifiers, 11
Image Lag, 21, 169
Image Layout, 48
Image Operations, 92
Image Processing, 21
Image Processing Unit, 18, 19, 34, 112
Image Quality, 19, 28
Image Retrieval, 85
Image Statistics, 79
Image Transmittal, 84
Image Window Types, 47
Imager Operation, 14
Imaging system configuration, 40
Information, 73
Inherent Lag, 34
Initial Connection to the Command Processor, 44
Initialize Video, 78
Installation, 46
Interface Files, 44
Internal Configuration of the Receptor, 15
Internal Power Supply, 19
Internal Power Supply Specifications, 124
Interpolation Of The Nearest Neighbors, 14
Intrinsic Lag, 21
Introduction, 11
Inverse Compensation Artifacts, 33
Invert W/L, 61
 Invert W/LCheckbox, 62

L

Lag, 38
Latent Image, 34
Lead Cap, 26, 129
Loading Video Sequence, 76
Logic Levels, 117
Low Frame Rates, 35
Low Signal-to-noise Ratio, 35
LVDS, 112, 117, 122

M

Main Screen, 99
Maintenance, 135
Manufacturing Mode, 98
Mechanical Loading, 27, 130
Mechanical Mounting, 26
Median Filter, 94
Median Pixel Value, 35
 Dark Field Image, 35
 Gain Image, 35
Medical Applications, 13
Mega Voltage Energy Imaging, 16
Memory, 19
Menu Options, 48
Message Options, 48
Mode Control and Verification, 112
Mode Selection, 102
Mode Settings, 71, 72
Mode Setup, 103
Modes of Operation, 20
More Video Options: Video Menu, 76
Motherboard, 112
Mounting, 26
Mouse and Key Shortcuts, 59

N

Noise And Interference, 124
Noise Reduction, 21
Non-destructive Test, 16
Non-uniformities In The Receptor, 34
Non-uniformity Correction, 33
Normalization Failures, 35
Notes on ROIList Use, 82

O

Offset and Gain Calibration, 19, 22, 33, 42, 67
Offset and Gain Calibration with 3030CB & 4030CB Receptors, 67
Offset Calibration, 20, 28, 30, 34, 36, 38, 40, 67, 135
Offset Characteristics, 34
Offset Correction, 34
Open/edit an existing file, 99
Opening Images, 52
Operational Modes - 3030CB , 21
Operational Modes - 4030CB , 20
Optimal Performance, 20
Optimize Auto Level, 93

Opto-Coupler Interface, 113
OR Image, 88
Output Voltage, 18

P

Patient Contact, 13
PaxScan Digital Imaging Subsystem, 11
PaxScan Application Software, 43
PaxScan Imager Configuration, 14
Peak Quantum Efficiency, 16
Photodiodes, 16
Pixclk Timing Specifications, 119
Pixel Binning, 20, 161
Pixel Correction Algorithm, 40
Pixel Data Format & 3030CB & 4030CB Receptors, 55
Pixel Defect Map, 40
Pixel Editing, 86
Pixel Editor, 92
Pixel Pitch, 17
Playing Sequences, 76
Post-exposure Offset, 28
Power On Sequence, 27
Power Up, 27
Precautions, 26, 129
Preferences, 56
Primary Barrier to X-rays, 26, 129
Printing Images, 54
Problem Report form, 142
Properties of Amorphous Silicon, 16
Proper Warm Up, 30, 36
Pulsed X-ray Beam Applications, 124

R

Rack Mounting, 14, 26, 130
RAD AutoSave, 73
Rad modes, 74
Radiation, 16, 30, 36
Readout Amplifiers, 19
Readout And Drive Electronics, 15
Readout Chips, 17
Real-time, 11, 18, 95
Real-Time Video Corrections, 95
Receptor, 13, 15, 97
Receptor Configuration file, 42, 97, 112
Receptor Configuration Settings, 100
Receptor Mounting, 26, 129
Recording Sequences, 74
Recursive Filter, 14, 21, 94
Reduced Air Flow, 26, 130
Reducing the Effects of Noise, 35
Region of Interest Statistics, 79, 80, 81
Regulatory Approvals, 19
Reliable Grounding, 27
Replace the Base Map, 40
Reset, 85
Reset Video, 78
Resolution, 20

- Retrieve, 88
- Retrieve Files, 85
- Retrieve Image, 30
- RJ-45 Ethernet port, 18
- ROI Basic, 79
- ROI Dialog, 80
- RoiList Commands, 82
- Row Segment Editing, 87
- S**
- Safety, 129
- Saturation of the Receptor, 35
- Saturation Threshold, 22
- Save a File, 99
- Save Between Sessions, 57
- Save Individual Images, 52
- Saving Images, 28, 51
- Save Video Sequence, 77
- Saving Video Sequences, 52
- Scintillator, 13, 16, 18
- SDRAM, 19
- Select Mode, 29
- Sensor Panel Imaging, 13
- Sensor Structure, 15
- Server, 33
- Set Threshold and Display, 91
- Setting the IP Address of the Command Processor, 147
- Setting the IP Address of the Workstation, 149
- Setup, 46
- Shipment Contents, 23
- Shortcut Keys, 59
- Signal Conversion Chain, 18
- Signal Voltage, 18
- Software Interfaces, 18
- Software Program Update, 105
- Software Programming Interfaces, 43
- Spatial Non-uniformity, 19
- Special Warnings, 27
- Specify a Threshold Value, 64
- Standard Calibration Defaults, 28
- Standard Selection Cursor, 58
- Start, 29
- Statistics, 79
- Status Bar, 48
- Steady State Temperature, 34
- Sterilization, 13, 136
- Subsystem, 13
- Supported File Formats, 51, 54
- Synchronization Of Critical Tasks, 14
- System Configuration, 97
 - Hostdown Utility Application, 105
 - ViVA Application, 108
- System Control Using ViVA™, 45
- System Overview, 13
- System Requirements, 46
- System Settings, 70

- T**
- TAB Package, 17
- Technical Support, 141
- Test Image Mode, 78
- Thin Film Transistors (TFTs), 15
- Timing Information, 124
- Toolbars, 51
- Tools Menu, 83
- Transmit, 88
- Transmit Files, 84
- Troubleshooting, 137
- TV Cameras, 11
- Typical Radiation Dose, 30

- U**
- UL, 19
- Updates via Serial Link, 105
- Updating the Base Defect Map, 91
- Usage Dialog Box, 98
- Usage, 98
- User Synchronization Mode, 123

- V**
- Varian Part Numbers, 24
- VENUS 4, 17
- Verification of Analog Offset Calibration, 42
- Versions, 46
- Video bus, 117
- Video Interface Signals, 117
- Video Menu, 76
- Video Menu/Toolbar, 74
- Viewing Images, 28
- View Menu & User Interface, 46
- View Options, 76
- ViVA, 28
- ViVA Application, 108
- ViVA Help, 45
- ViVA Screen View, 47
- ViVA Software Application, 45
- ViVA Transmit Files Selection, 109
- VSYNC, 117, 119

- W**
- Warm-Up, 36
- White Area Blanking, 57, 64
- Window/Level Mapping, 57, 62
- Window/Level Scroll Bars, 61
- Windows 2000, 28
- Write ABS Mailbox, 84

- X**
- X-ray Dose, 20
- X-ray-to-digital Conversion, 34

