

Operational Metrics Spec

PUE: target ≤ 1.15 site-wide; immersion pods 1.03-1.10. Measured = total facility kWh / IT kWh, monthly, meter-attested.

Carbon intensity: kgCO₂e per MWh IT load, split by source (grid GA avg ~ published eGRID SERC value | on-site solar 0 | gas per attested MMBtu x emission factor). Publish monthly to ReserveProofAnchor as docType "REVENUE" attachment or dedicated dashboard feed.

DSCR feed (operations/dscr-feeds/): $dscrBps = \text{hostingNOI_period} \times 10000 / \text{debtService_period}$, NET of PPA demand charges; pushed by servicer with the waterfall signal. Thresholds: cash-trap < 12000, turbo < 11000, 2-period hysteresis.