

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CHA-07/400V	Reg. No.	011-1W380
Certificate Holder			
Name	WOLF GmbH		
Address	Industriestr. 1	Zip	84048
City	Mainburg	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Strojírenský zkušební ústav, s.p. (SZU)		
Subtype title	CHA-07/400V		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass Of Refrigerant	3.1 kg		
Certification Date	30.06.2020		

Model: CHA-07/400V

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.50 kW	4.45 kW
El input	0.82 kW	1.39 kW
COP	5.47	3.10
Indoor water flow rate	0.78 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	194 %	148 %
Prated	5.59 kW	5.93 kW
SCOP	4.92	3.77
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.29 kW	5.62 kW
COP Tj = -7°C	2.95	2.22
Cdh	0.90	0.90
Pdh Tj = +2°C	3.20 kW	3.46 kW
COP Tj = +2°C	5.08	3.68
Cdh	0.90	0.90
Pdh Tj = +7°C	2.29 kW	2.25 kW
COP Tj = +7°C	6.27	5.11
Cdh	0.96	0.90
Pdh Tj = 12°C	2.33 kW	2.60 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	6.85	6.43
Cdh	0.96	0.96
Pdh Tj = Tbiv	5.59 kW	5.93 kW
COP Tj = Tbiv	2.55	1.86
Pdh Tj = TOL	5.59 kW	5.93 kW
COP Tj = TOL	2.55	1.86
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2346 kWh	3249 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 17 Dec 2020

η_s	249 %	179 %
Prated	5.70 kW	5.89 kW
SCOP	6.30	4.54
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	5.70 kW	5.89 kW
COP Tj = +2°C	3.85	2.43
Cdh	0.90	0.90
Pdh Tj = +7°C	3.84 kW	4.02 kW
COP Tj = +7°C	6.16	3.98
Cdh	0.90	0.90
Pdh Tj = 12°C	2.32 kW	2.29 kW
COP Tj = 12°C	7.17	5.77
Cdh	0.95	0.96
Pdh Tj = Tbiv	5.70 kW	5.89 kW
COP Tj = Tbiv	3.85	2.43
Pdh Tj = TOL	5.70 kW	5.89 kW
COP Tj = TOL	3.85	2.43
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1208 kWh	4215 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	174 %	127 %
Prated	6.16 kW	5.57 kW
SCOP	4.43	3.26
T _{biv}	-17 °C	-17 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	3.71 kW	3.70 kW
COP T _j = -7°C	3.85	2.69
C _{dh}	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = +2°C	2.25 kW	2.25 kW
COP Tj = +2°C	5.28	3.95
Cdh	0.90	0.90
Pdh Tj = +7°C	2.33 kW	2.29 kW
COP Tj = +7°C	6.52	5.27
Cdh	0.96	0.97
Pdh Tj = 12°C	2.27 kW	2.41 kW
COP Tj = 12°C	6.83	6.27
Cdh	0.95	0.96
Pdh Tj = Tbiv	5.35 kW	4.84 kW
COP Tj = Tbiv	2.45	1.63
Pdh Tj = TOL	4.55 kW	4.09 kW
COP Tj = TOL	2.09	1.28
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	1.61 kW	1.48 kW
Annual energy consumption Qhe	3428 kWh	4215 kWh

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = -15°C (if TOL<-20°C)	4.78	4.99
COP Tj = -15°C (if TOL<-20°C)	2.74	1.99
Cdh	0.90	0.90