

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 23 Jun 2022

#### **Login**

Summary of	TTL 20 AC	Reg. No.	011-1W0489	
Certificate Holder				
Name	tecalor GmbH	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 20 AC	TTL 20 AC		
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A	R410A		
Mass of Refrigerant	5.5 kg	5.5 kg		
Certification Date	10.04.2017	10.04.2017		



## **Model: TTL 20 AC**

Configure model		
Model name	TTL 20 AC	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	7.84 kW	7.36 kW	
El input	1.54 kW	2.33 kW	
СОР	5.09	3.16	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shutting on the heat transfer medium now	passeu
Complete power supply failure	passed
Starting and operating test	passed

#### Average Climate



This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	54 dB(A)	54 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η <sub>s</sub>	192 %	147 %
Prated	11.00 kW	12.00 kW
SCOP	4.87	3.74
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






		· · · · · · · · · · · · · · · · · · ·
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.48 kW	0.69 kW
Annual energy consumption Qhe	4663 kWh	6625 kWh

#### Warmer Climate

EN 14825		
Low temperature	Medium temperature	
245 %	177 %	
7.00 kW	8.00 kW	
6.20	4.51	
_	245 % 7.00 kW	





<b>5</b>		
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.14	2.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.90 kW	7.50 kW
$COPTj = +7^{\circ}C$	5.47	3.64
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.45
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity





This information was genera	This information was generated by the HP KEYMARK database on 23 Jun 2022		
Supplementary Heater: PSUP	0.00 kW	0.00 kW	
Annual energy consumption Qhe	1508 kWh	2369 kWh	

#### Colder Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	167 %	133 %
Prated	15.00 kW	17.00 kW
SCOP	4.25	3.41
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
	,	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# Page 7 of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8698 kWh	12299 kWh
Pdh Tj = -15°C (if TOL<-20°C)	11.80	12.60
COP Tj = -15°C (if TOL $<$ -20°C)	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90