

Page 1 of 3

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	VIESSMANN Vitocal 060-A (250 L) Typ T0E 060-A	Reg. No.	011-1W0111		
Certificate Holder					
Name	Viessmann Faulquemont SAS				
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A (250 L) Typ T0E 060-A				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R134a				
Mass of Refrigerant	1.35 kg				

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: VIESSMANN Vitocal 060-A (250 L) Typ T0E 060-A

Configure model				
Model name	VIESSMANN Vitocal 060-A (250 L) Typ T0E 060-A			
Units	Indoor			
Climate zone (for heating)	n/a			
Heat Source	n/a			
Any additional heat sources	n/a			

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	

Domestic Hot Water (DHW)

Average Climate

EN 12102-2		
Sound power level outdoor	64 dB(A)	

EN 16147				
Declared load profile	L			
Efficiency ηDHW	135 %			
СОР	3.25			
Heating up time	9h13min h:min			
Standby power input	22.0 W			
Reference hot water temperature	52.6 °C			
Mixed water at 40°C	324			

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 18 Mar 2022