

This information was generated by the HP KEYMARK database on 26 Jan 2021

Summary of	Samsung EHS R32 Mono 8kW (space heating/ 260L)	Reg. No.	011-1W0450
Certificate Holder			
Name	Samsung Electronics Air Conditioner Europe B.V.		
Address	Evert van de Beekstraat 310	Zip	1118 CX
City	Schiphol	Country	Netherlands
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Samsung EHS R32 Mono 8kW (space heating/ 260L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	1.15 kg		
Certification Date	26.01.2021		
Testing basis	HP KEYMARK certification scheme rules V7		

Model: AE080RXYDEG/EU & AE260RNWMEG/EU

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.10 kW
El input	1.77 kW	2.53 kW
COP	4.52	2.81
Indoor water flow rate	1.39 m ³ /h	0.77 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 26 Jan 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	126 %
Prated	8.00 kW	8.00 kW
SCOP	4.44	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	2.63	1.90
Cdh	0.90	0.90
Pdh Tj = +2°C	4.31 kW	4.31 kW
COP Tj = +2°C	4.24	3.11
Cdh	0.90	0.90
Pdh Tj = +7°C	3.10 kW	2.80 kW
COP Tj = +7°C	6.39	4.55
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 26 Jan 2021

Pdh Tj = 12°C	2.60 kW	2.40 kW
COP Tj = 12°C	8.22	5.77
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.10 kW	7.10 kW
COP Tj = Tbiv	2.63	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	6.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.66
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	1.20 kW
Annual energy consumption Qhe	3719 kWh	5113 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 26 Jan 2021

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.85
Heating up time	2:25 h:min
Standby power input	65.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	290 l

Model: AE080RXYDGG/EU & MIM-E03CN

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.10 kW
El input	1.77 kW	2.53 kW
COP	4.52	2.81
Indoor water flow rate	1.39 m ³ /h	0.77 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 26 Jan 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	126 %
Prated	8.00 kW	8.00 kW
SCOP	4.44	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	2.63	1.90
Cdh	0.90	0.90
Pdh Tj = +2°C	4.31 kW	4.31 kW
COP Tj = +2°C	4.24	3.11
Cdh	0.90	0.90
Pdh Tj = +7°C	3.10 kW	2.80 kW
COP Tj = +7°C	6.39	4.55
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 26 Jan 2021

Pdh Tj = 12°C	2.60 kW	2.40 kW
COP Tj = 12°C	8.22	5.77
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.10 kW	7.10 kW
COP Tj = Tbiv	2.63	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	6.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.66
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	1.20 kW
Annual energy consumption Qhe	3719 kWh	5113 kWh

Model: AE080RXYDGG/EU & AE260RNWMGG/EU

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.10 kW
El input	1.77 kW	2.53 kW
COP	4.52	2.81
Indoor water flow rate	1.39 m ³ /h	0.77 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	126 %
Prated	8.00 kW	8.00 kW
SCOP	4.44	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	2.63	1.90
Cdh	0.90	0.90
Pdh Tj = +2°C	4.31 kW	4.31 kW
COP Tj = +2°C	4.24	3.11
Cdh	0.90	0.90
Pdh Tj = +7°C	3.10 kW	2.80 kW
COP Tj = +7°C	6.39	4.55
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 26 Jan 2021

Pdh Tj = 12°C	2.60 kW	2.40 kW
COP Tj = 12°C	8.22	5.77
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.10 kW	7.10 kW
COP Tj = Tbiv	2.63	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	6.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.66
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	1.20 kW
Annual energy consumption Qhe	3719 kWh	5113 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.85
Heating up time	2:25 h:min
Standby power input	65.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	290 l