

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Ecodan Power Inverter 10 AA	Reg. No.	037-0050-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Ecodan Power Inverter 10 AA		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.2 kg		
Certification Date	09.04.2020		
Testing basis	HP Keymark scheme rules rev. no. 7		

Model: PUAZ-SW100VAA(-BS) + EHSC-M*C

Configure model	
Model name	PUHZ-SW100VAA(-BS) + EHSC-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-*M*C

Configure model

Model name	PUHZ-SW100VAA(-BS) + EHSC-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Model: PUAZ-SW100VAA(-BS) + EHST20C-M*C

Configure model	
Model name	PUHZ-SW100VAA(-BS) + EHST20C-M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUHZ-SW100VAA(-BS) + EHST20C-*M*C

Configure model	
Model name	PUHZ-SW100VAA(-BS) + EHST20C-*M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERSC-M*C

Configure model	
Model name	PUHZ-SW100VAA(-BS) + ERSC-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Model: PUAZ-SW100VAA(-BS) + ERSC-*M*C

Configure model

Model name	PUHZ-SW100VAA(-BS) + ERSC-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Model: PUAZ-SW100VAA(-BS) + ERST20C-M*C

Configure model	
Model name	PUHZ-SW100VAA(-BS) + ERST20C-M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERST20C-*M*C

Configure model

Model name	PUHZ-SW100VAA(-BS) + ERST20C-*M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHSC-M*C

Configure model

Model name	PUHZ-SW100YAA(-BS) + EHSC-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-*M*C

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHSC-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Model: PUAZ-SW100YAA(-BS) + EHST20C-M*C

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHST20C-M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUHZ-SW100YAA(-BS) + EHST20C-*M*C

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHST20C-*M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERSC-M*C

Configure model

Model name	PUHZ-SW100YAA(-BS) + ERSC-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Model: PUAZ-SW100YAA(-BS) + ERSC-*M*C

Configure model

Model name	PUHZ-SW100YAA(-BS) + ERSC-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Model: PUAZ-SW100YAA(-BS) + ERST20C-M*C

Configure model

Model name	PUHZ-SW100YAA(-BS) + ERST20C-M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERST20C-*M*C

Configure model	
Model name	PUHZ-SW100YAA(-BS) + ERST20C-*M*C
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-M*D

Configure model	
Model name	PUHZ-SW100VAA(-BS) + EHST20C-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUHZ-SW100YAA(-BS) + EHST20C-M*D

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHST20C-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHST20C-*M*D

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHSC-M*D

Configure model

Model name	PUHZ-SW100YAA(-BS) + EHSC-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-*M*D

Configure model	
Model name	PUHZ-SW100YAA(-BS) + EHSC-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.6 kW	10 kW
SCOP	4.21	3.3
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.14	3.18
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5204 kWh	6262 kWh

Model: PUHZ-SW100YAA(-BS) + ERST20C-*M*D

Configure model	
Model name	PUHZ-SW100YAA(-BS) + ERST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERSC-M*D

Configure model	
Model name	PUHZ-SW100YAA(-BS) + ERSC-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Model: PUAZ-SW100YAA(-BS) + ERSC-*M*D

Configure model

Model name	PUHZ-SW100YAA(-BS) + ERSC-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.2	3.22
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.96	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5086 kWh	6141 kWh

Model: PUAZ-SW100VAA(-BS) + EHST20C-*M*D

Configure model

Model name	PUHZ-SW100VAA(-BS) + EHST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHSC-M*D

Configure model

Model name	PUHZ-SW100VAA(-BS) + EHSC-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-*M*D

Configure model

Model name	PUHZ-SW100VAA(-BS) + EHSC-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.6 kW	10 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.16	3.2
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5156 kWh	6204 kWh

Model: PUAZ-SW100VAA(-BS) + ERST20C-*M*D

Configure model	
Model name	PUHZ-SW100VAA(-BS) + ERST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERSC-M*D

Configure model

Model name	PUHZ-SW100VAA(-BS) + ERSC-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh

Model: PUAZ-SW100VAA(-BS) + ERSC-*M*D

Configure model	
Model name	PUHZ-SW100VAA(-BS) + ERSC-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.2 kW	11.2 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.6

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.6 kW	10 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.4 kW	8.9 kW
COP Tj = -7°C	2.75	1.95
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.21	3.22
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.5 kW	4.7 kW
COP Tj = +7°C	5.55	4.79
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.3 kW	5.3 kW
COP Tj = 12°C	7.47	6.12
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	9.4 kW	8.9 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.96 kW	8.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.84
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5070 kWh	6130 kWh