

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	FDCW71VNX-A	Reg. No.	012-SC0825-18
Certificate Holder			
Name	Mitsubishi Heavy Industries Air Conditioning Europe		
Address	5 The Square	Zip	UB11 1ET
City	Uxbridge, Middlesex	Country	United Kingdom
Certification Body	RISE CERT		
Subtype title	FDCW71VNX-A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.55 kg		
Certification Date	21.01.2019		

Model: FDCW71VNX-A + HSB100

Configure model	
Model name	FDCW71VNX-A + HSB100
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.30 kW	7.10 kW
El input	2.03 kW	2.71 kW
COP	4.08	2.62

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	7.10 kW	7.00 kW
SCOP	3.73	2.98
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.20 kW
COP Tj = -7°C	2.61	1.93
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.80 kW	3.80 kW
COP Tj = +2°C	3.60	3.00
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.50 kW	2.40 kW
COP Tj = +7°C	4.92	3.90
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	2.30 kW	2.30 kW
COP Tj = 12°C	6.42	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.10 kW	6.20 kW
COP Tj = Tbiv	2.34	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.10 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.69
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	58 °C	58 °C
Poff	2 W	2 W
PTO	15 W	10 W
PSB	15 W	15 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	1.70 kW
Annual energy consumption Qhe	3856 kWh	4751 kWh

Model: FDCW71VNX-A + HMA100-S

Configure model	
Model name	FDCW71VNX-A + HMA100-S
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.30 kW	7.10 kW
El input	2.03 kW	2.71 kW
COP	4.08	2.62

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	7.10 kW	7.00 kW
SCOP	3.73	2.98
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.20 kW
COP Tj = -7°C	2.61	1.93
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.80 kW	3.80 kW
COP Tj = +2°C	3.60	3.00
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.50 kW	2.40 kW
COP Tj = +7°C	4.92	3.90
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	2.30 kW	2.30 kW
COP Tj = 12°C	6.42	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.10 kW	6.20 kW
COP Tj = Tbiv	2.34	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.10 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.69
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	58 °C	58 °C
Poff	2 W	2 W
PTO	15 W	10 W
PSB	15 W	15 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	1.70 kW
Annual energy consumption Qhe	3856 kWh	4751 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	99 %
COP	2.34
Heating up time	1:20 h:min
Standby power input	85.0 W
Reference hot water temperature	51.0 °C
Mixed water at 40°C	230 l