

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AEROTOP S15.2 / S15.2_2-part	Reg. No.	011-1W0195
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AEROTOP S15.2 / S15.2_2-part		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.4 kg		
Certification Date	17.12.2019		

Model: AEROTOP S15.2_2-part

Configure model	
Model name	AEROTOP S15.2_2-part
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.56 kW	8.08 kW
El input	1.85 kW	2.64 kW
COP	4.87	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	134 %
Prated	15.65 kW	15.03 kW
SCOP	4.45	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.84 kW	13.30 kW
COP Tj = -7°C	3.09	2.32
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	8.65 kW	8.47 kW
COP Tj = +2°C	4.17	3.28
Cdh Tj = +2 °C	0.98	0.98
Pdh Tj = +7°C	5.78 kW	5.24 kW
COP Tj = +7°C	6.30	4.56
Cdh Tj = +7 °C	0.97	0.97

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.72 kW	4.86 kW
COP Tj = 12°C	7.55	5.93
Cdh Tj = +12 °C	0.96	0.96
Pdh Tj = Tbiv	13.84 kW	13.30 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.51 kW	15.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	2.14
WTOL	65 °C	65 °C
Poff	28 W	28 W
PTO	28 W	28 W
PSB	28 W	28 W
PCK	28 W	28 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.14 kW	1.03 kW
Annual energy consumption Qhe	7259 kWh	9060 kWh

Model: AEROTOP S15.2

Configure model	
Model name	AEROTOP S15.2
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.56 kW	8.08 kW
El input	1.85 kW	2.64 kW
COP	4.87	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	134 %
Prated	15.65 kW	15.03 kW
SCOP	4.45	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.84 kW	13.30 kW
COP Tj = -7°C	3.09	2.32
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	8.65 kW	8.47 kW
COP Tj = +2°C	4.17	3.28
Cdh Tj = +2 °C	0.98	0.98
Pdh Tj = +7°C	5.78 kW	5.24 kW
COP Tj = +7°C	6.30	4.56
Cdh Tj = +7 °C	0.97	0.97

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.72 kW	4.86 kW
COP Tj = 12°C	7.55	5.93
Cdh Tj = +12 °C	0.96	0.96
Pdh Tj = Tbiv	13.84 kW	13.30 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.51 kW	15.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	2.14
WTOL	65 °C	65 °C
Poff	28 W	28 W
PTO	28 W	28 W
PSB	28 W	28 W
PCK	28 W	28 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.14 kW	1.03 kW
Annual energy consumption Qhe	7259 kWh	9060 kWh