

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	VISSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)	Reg. No.	011-1W0192
Certificate Holder			
Name	Viessmann Faulquemont SAS		
Address	Avenue André Gouy	Zip	F-57380
City	Faulquemont	Country	France
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	TÜV Rheinland Energy GmbH		
Subtype title	VISSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R1234ze		
Mass Of Refrigerant	1.25 kg		
Certification Date	27.02.2020		

# Model: VISSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)

## General Data

Power supply	1x230V 50Hz
Off-peak product	Yes

## Domestic Hot Water (DHW)

### Operating test

## EN 16147

Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

## Average Climate

## EN 12102-2

Sound power level indoor	50 dB(A)
--------------------------	----------

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	134 %
COP	3.22
Heating up time	9:07 h:min
Standby power input	24.0 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	345 l