

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AUREA 10	Reg. No.	012-SC1491-17
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	AUREA 10		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.72 kg		

## Model: AUREA 10

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	9.46 kW	4.77 kW
El input	2.27 kW	1.71 kW
COP	4.16	2.79
Indoor water flow rate	1.69 m <sup>3</sup> /h	0.54 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	117 %
Prated	7.60 kW	6.90 kW
SCOP	4.10	3.01
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.72 kW	6.10 kW
COP Tj = -7°C	2.58	1.96
Pdh Tj = +2°C	4.09 kW	3.72 kW
COP Tj = +2°C	3.95	2.88
Pdh Tj = +7°C	2.63 kW	2.39 kW
COP Tj = +7°C	6.03	4.01
Pdh Tj = 12°C	2.91 kW	3.08 kW
COP Tj = 12°C	6.42	5.93
Pdh Tj = Tbiv	6.72 kW	6.10 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.58	1.96
P <sub>dh</sub> $T_j = TOL$	6.21 kW	5.53 kW
COP $T_j = TOL$	2.36	1.64
C <sub>dh</sub>	0.87	0.90
WTOL	55 °C	55 °C
P <sub>off</sub>	5 W	5 W
PTO	60 W	50 W
PSB	5 W	5 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.40 kW	1.50 kW
Annual energy consumption Q <sub>he</sub>	3827 kWh	4736 kWh