

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	TERRA 11 HPLA	Reg. No.	011-1W0418
Certificate Holder			
Name	Ochsner Wärmepumpen GmbH		
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TERRA 11 HPLA		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.03 kg		
Certification Date	30.09.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

## Model: TERRA 11 HPLA

Configure model	
Model name	TERRA 11 HPLA
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.31 kW	9.28 kW
El input	2.05 kW	3.18 kW
COP	5.02	2.91

### Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	216 %	137 %
Prated	10.00 kW	9.00 kW
SCOP	5.61	3.63
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = +7°C	9.90 kW	9.90 kW
COP Tj = +7°C	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	5.03	2.83
P <sub>dh</sub> $T_j = TOL$ or P <sub>dh</sub> $T_j = T_{designh}$ if $TOL < T_{designh}$	9.10 kW	9.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.83	2.83
Rated airflow rate	0 m <sup>3</sup> /h	0 m <sup>3</sup> /h
C <sub>dh</sub> $T_j = TOL$ or P <sub>dh</sub> $T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	65 °C	65 °C
P <sub>off</sub>	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	3799 kWh	5167 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>

This information was generated by the HP KEYMARK database on 18 Mar 2022

$\eta_s$	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	91.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.03	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2466 kWh	3367 kWh

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	224 %	224 %
Prated	13.00 kW	13.00 kW
SCOP	5.81	5.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = -7°C	10.50 kW	10.50 kW
COP Tj = -7°C	5.75	5.74
Pdh Tj = +2°C	10.60 kW	10.60 kW
COP Tj = +2°C	6.07	6.07
Pdh Tj = +7°C	10.70 kW	10.70 kW
COP Tj = +7°C	6.36	6.36
Pdh Tj = 12°C	10.70 kW	10.70 kW
COP Tj = 12°C	6.40	6.40
Pdh Tj = Tbiv	10.50 kW	10.50 kW
COP Tj = Tbiv	5.60	5.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	5.03
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	2.55 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q <sub>he</sub>	5457 kWh	5457 kWh
---	----------	----------