

| Summary of | WPE-I 87 H 400 Premium | Reg. No. | 011-1W0335 |
|---------------------|---|----------|-------------|
| Certificate Holder | | | |
| Name | STIEBEL ELTRON GmbH & Co KG | | |
| Address | Dr. Stiebel Straße 33 | Zip | 37603 |
| City | Holzminden | Country | Germany |
| Certification Body | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH | | |
| Subtype title | WPE-I 87 H 400 Premium | | |
| Heat Pump Type | Brine/Water | | |
| Refrigerant | R410a | | |
| Mass Of Refrigerant | 9 kg | | |
| Certification Date | 05.10.2020 | | |
| Testing basis | HP KEYMARK certification scheme rules rev. 7 | | |



Model: WPE-I 87 H 400 Premium

| General Data | | |
|--------------|-------------|--|
| Power supply | 3x400V 50Hz | |

Heating

| EN 14511-2 | | | |
|-------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Heat output | 52.18 kW | 48.32 kW | |
| El input | 11.09 kW | 17.02 kW | |
| СОР | 4.71 | 2.84 | |

| EN 14511-4 | | |
|--|---------|--|
| Chutting off the heat two pefor modium flour | no cood | |
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |
| Defrost test | failed | |
| Starting and operating test | passed | |

Average Climate

| EN 12102-1 | | | |
|--------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Sound power level indoor | 50 dB(A) | 50 dB(A) | |






EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_{s} | 199 % | 157 % |
| Prated | 84.67 kW | 79.00 kW |
| SCOP | 5.17 | 4.13 |
| ГЬіν | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 74.90 kW | 69.88 kW |
| COP Tj = -7°C | 4.26 | 3.00 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = +2°C | 45.59 kW | 42.54 kW |
| COP Tj = +2°C | 5.14 | 4.08 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = +7°C | 29.31 kW | 27.35 kW |
| COP Tj = +7°C | 5.81 | 4.94 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = 12°C | 24.37 kW | 24.08 kW |
| COP Tj = 12°C | 5.65 | 5.16 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = Tbiv | 84.67 kW | 79.00 kW |
| COP Tj = Tbiv | 3.97 | 2.72 |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 84.67 kW | 79.00 kW |
|---|-----------|-----------|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.97 | 2.72 |
| WTOL | 65 °C | 65 °C |
| Poff | 9 W | 9 W |
| РТО | 11 W | 11 W |
| PSB | 11 W | 11 W |
| PCK | o w | 0 W |
| Supplementary Heater: Type of energy input | No | No |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 33804 kWh | 39457 kWh |

Warmer Climate

| EN 14825 | | | |
|---------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| η_{s} | 202 % | 160 % | |
| Prated | 84.67 kW | 79.00 kW | |
| SCOP | 5.25 | 4.21 | |
| Tbiv | 2 °C | 2 °C | |
| TOL | 2 °C | 2 °C | |
| Pdh Tj = +2°C | 84.67 kW | 79.00 kW | |
| COP Tj = +2°C | 3.97 | 2.72 | |
| | - | | |



| | ted by the in Reinna | ik database on 15 Mai 202 |
|---|----------------------|---------------------------|
| Cdh | 0.90 | 0.90 |
| Pdh Tj = +7°C | 54.43 kW | 50.79 kW |
| $COP Tj = +7^{\circ}C$ | 4.85 | 3.60 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = 12°C | 24.19 kW | 24.07 kW |
| COP Tj = 12°C | 5.85 | 5.16 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = Tbiv | 84.67 kW | 79.00 kW |
| COP Tj = Tbiv | 3.97 | 2.72 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 84.67 kW | 79.00 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.97 | 2.72 |
| WTOL | 65 °C | 65 °C |
| Poff | 9 W | 9 W |
| РТО | 11 W | 11 W |
| PSB | 11 W | 11 W |
| РСК | 0 W | 0 W |
| Supplementary Heater: Type of energy input | No | No |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 21524 kWh | 23056 kWh |



| EN 12102-1 | | | |
|--------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Sound power level indoor | 50 dB(A) | 50 dB(A) | |

Colder Climate

| EN 14825 | | | |
|---------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| η_{s} | 204 % | 165 % | |
| Prated | 84.67 kW | 79.00 kW | |
| SCOP | 5.30 | 4.32 | |
| Tbiv | -22 °C | -22 °C | |
| TOL | -22 °C | -22 °C | |
| Pdh Tj = -7°C | 51.25 kW | 48.52 kW | |
| COP Tj = -7°C | 5.06 | 3.85 | |
| Cdh | 0.90 | 0.90 | |
| Pdh Tj = +2°C | 31.20 kW | 29.11 kW | |
| COP Tj = +2°C | 5.81 | 4.83 | |
| Cdh | 0.90 | 0.90 | |
| Pdh Tj = +7°C | 24.49 kW | 24.11 kW | |
| COP Tj = +7°C | 5.85 | 5.20 | |
| Cdh | 0.90 | 0.90 | |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textsc{Page}}\ 7$$ of 8 This information was generated by the HP KEYMARK database on 15 Mar 2021

| Pdh Tj = 12°C | 24.39 kW | 24.22 kW |
|---|-----------|-----------|
| COP Tj = 12°C | 5.66 | 5.27 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = Tbiv | 84.67 kW | 79.00 kW |
| COP Tj = Tbiv | 3.97 | 2.72 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 84.67 kW | 79.00 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.97 | 2.72 |
| WTOL | 65 °C | 65 °C |
| Poff | 9 W | 9 W |
| РТО | 11 W | 11 W |
| PSB | 11 W | 11 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | No | No |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 39378 kWh | 45048 kWh |
| Pdh Tj = -15°C (if TOL<-20°C) | 84.67 | 79.00 |
| COP Tj = -15°C (if TOL $<$ -20°C) | 3.97 | 2.72 |
| Cdh | 0.90 | 0.90 |





| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 50 dB(A) | 50 dB(A) |