

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AQUATOP T43H	Reg. No.	011-1W0312
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AQUATOP T43H		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R407c		
Mass of Refrigerant	7.4 kg		
Certification Date	04.05.2019		

Model: AQUATOP T43H

Configure model	
Model name	AQUATOP T43H
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	44.44 kW	41.30 kW
El input	10.00 kW	13.50 kW
COP	4.40	3.10

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	192 %	180 %
Prated	44.00 kW	41.00 kW
SCOP	5.01	4.69
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	44.84 kW	42.54 kW
COP Tj = -7°C	4.49	3.38
Pdh Tj = +2°C	46.18 kW	45.84 kW
COP Tj = +2°C	5.02	4.65
Pdh Tj = +7°C	47.06 kW	47.50 kW
COP Tj = +7°C	5.24	5.46
Pdh Tj = 12°C	47.95 kW	49.56 kW
COP Tj = 12°C	5.54	6.39
Pdh Tj = Tbiv	44.40 kW	41.30 kW
COP Tj = Tbiv	4.40	3.10

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	44.40 kW	41.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.40	3.10
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	18311 kWh	18195 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	193 %	181 %
Prated	44.00 kW	41.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.04	4.74
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	44.40 kW	41.30 kW
COP Tj = +2°C	4.40	3.10
Pdh Tj = +7°C	45.73 kW	44.19 kW
COP Tj = +7°C	4.84	4.12
Pdh Tj = 12°C	47.06 kW	48.32 kW
COP Tj = 12°C	5.32	5.74
Pdh Tj = Tbiv	44.40 kW	41.30 kW
COP Tj = Tbiv	4.40	3.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	44.40 kW	41.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.40	3.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q _{he}	11777 kWh	11648 kWh
---	-----------	-----------

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	197 %	187 %
Prated	44.00 kW	41.00 kW
SCOP	5.13	4.87
T _{biv}	-22 °C	-22 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	46.18 kW	45.02 kW
COP T _j = -7°C	5.02	4.37
P _{dh} T _j = +2°C	47.06 kW	47.50 kW
COP T _j = +2°C	5.24	5.30
P _{dh} T _j = +7°C	47.51 kW	49.15 kW
COP T _j = +7°C	5.46	6.01
P _{dh} T _j = 12°C	47.95 kW	50.39 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.54	6.51
Pdh Tj = Tbiv	44.40 kW	41.30 kW
COP Tj = Tbiv	4.40	3.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	44.40 kW	41.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.40	3.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	21336 kWh	20905 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	47.30 kW	54.50 kW
El input	11.30 kW	39.20 kW
COP	5.20	3.60

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	224 %	199 %
Prated	59.00 kW	55.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.81	5.17
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	59.04 kW	55.74 kW
COP Tj = -7°C	5.28	3.84
Pdh Tj = +2°C	60.38 kW	59.04 kW
COP Tj = +2°C	5.81	5.11
Pdh Tj = +7°C	61.26 kW	60.70 kW
COP Tj = +7°C	6.02	5.92
Pdh Tj = 12°C	62.15 kW	62.76 kW
COP Tj = 12°C	6.33	6.85
Pdh Tj = Tbiv	58.60 kW	54.50 kW
COP Tj = Tbiv	5.19	3.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	58.60 kW	54.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.19	3.56
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	20831 kWh	21775 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	225 %	201 %
Prated	59.00 kW	55.00 kW
SCOP	5.83	5.23
T _{biv}	2 °C	2 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = +2°C	58.60 kW	54.50 kW
COP T _j = +2°C	5.19	3.56
P _{dh} T _j = +7°C	59.93 kW	57.39 kW
COP T _j = +7°C	5.63	4.58
P _{dh} T _j = 12°C	61.26 kW	61.52 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	6.11	6.20
Pdh Tj = Tbiv	58.60 kW	54.50 kW
COP Tj = Tbiv	5.19	3.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	58.60 kW	54.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.19	3.56
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	13422 kWh	13929 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	61 dB(A)	61 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
η_s	228 %	203 %
Prated	59.00 kW	55.00 kW
SCOP	5.90	5.26
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	60.38 kW	58.22 kW
COP Tj = -7°C	5.81	4.83
Pdh Tj = +2°C	61.26 kW	60.70 kW
COP Tj = +2°C	6.02	5.76
Pdh Tj = +7°C	61.71 kW	62.35 kW
COP Tj = +7°C	6.25	6.47
Pdh Tj = 12°C	62.15 kW	63.59 kW
COP Tj = 12°C	6.33	6.97
Pdh Tj = Tbiv	58.60 kW	54.50 kW
COP Tj = Tbiv	5.19	3.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	58.60 kW	54.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.19	3.56
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	24485 kWh	25527 kWh