

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (300L)	Reg. No.	011-1W0367
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (300L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	09.04.2020		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: ERGA04EV7 / ESH04P30D3

Configure model

Model name	ERGA04EV7 / ESH04P30D3
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	192 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.88	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2538 kWh	3806 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	1:23 h:min
Standby power input	31.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	137 l

Model: ERGA04EV7 / ESHB04P30D3

Configure model	
Model name	ERGA04EV7 / ESHB04P30D3
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Average Climate

EN 14825		
	Low temperature	Medium temperature
η_s	192 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.88	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2538 kWh	3806 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	1:23 h:min
Standby power input	31.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	137 l

Model: ERGA04EV7 / EHSX04P30D3

Configure model	
Model name	ERGA04EV7 / EHSX04P30D3
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Average Climate

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	1:23 h:min
Standby power input	31.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	137 l

Model: ERGA04EV7 / EHSXB04P30D3

Configure model	
Model name	ERGA04EV7 / EHSXB04P30D3
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Average Climate

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	1:23 h:min
Standby power input	31.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	137 l

Model: ERGA04EV7 / ESH(B)04P30E

Configure model

Model name	ERGA04EV7 / ESH(B)04P30E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	192 %	127 %
Prated	6.0 kW	6.0 kW
SCOP	4.88	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2538 kWh	3806 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	118 %
COP	2.80
Heating up time	1:34 h:min
Standby power input	40.4 W
Reference hot water temperature	44.6 °C
Mixed water at 40°C	140.4 l

Model: ERGA04EV7 / EHSX(B)04P30E

Configure model

Model name	ERGA04EV7 / EHSX(B)04P30E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	118 %
COP	2.80
Heating up time	1:34 h:min
Standby power input	40.4 W
Reference hot water temperature	44.6 °C
Mixed water at 40°C	140.4 l