

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>

Summary of	BoxAir Inverter BA60I-1	Reg. No.	037-0067-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA60I-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	6.9 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: BoxAir Inverter BA60I-1

Configure model			
Model name	BoxAir Inverter BA60I-1		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 3x400V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	19.83 kW	22.96 kW	
El input	4.24 kW	7.40 kW	
СОР	4.68	3.10	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	66 dB(A)	66 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	177 %	135 %	
Prated	22.57 kW	22.06 kW	
SCOP	4.50	3.45	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	20.64 kW	20.77 kW	
COP Tj = -7°C	2.64	2.04	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	12.68 kW	12.27 kW	
COP Tj = +2°C	4.21	3.22	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	8.04 kW	7.81 kW	
COP Tj = +7°C	6.61	5.06	
Cdh Tj = +7 °C	0.90	0.90	
Pdh Tj = 12°C	9.26 kW	9.01 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.02	6.13
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	22.57 kW	22.06 kW
COP Tj = Tbiv	2.35	1.55
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.57 kW	22.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.55
WTOL	60 °C	60 °C
Poff	27 W	27 W
РТО	26 W	26 W
PSB	27 W	27 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10350 kWh	13226 kWh