

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	THERMOR Alféa Excellia A.I. Tri size 16	Reg. No.	012-SC0221-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	THERMOR Alféa Excellia A.I. Tri size 16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	05.06.2019		

Model: THERMOR Alféa Excellia Duo A.I. Tri 16

Configure model

Model name	THERMOR Alféa Excellia Duo A.I. Tri 16
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.17 kW	12.24 kW
El input	3.70 kW	4.93 kW
COP	4.10	2.48

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	117 %
Prated	14.00 kW	13.00 kW
SCOP	3.80	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	7.30 kW	7.00 kW
COP Tj = +2°C	3.60	2.90
Pdh Tj = +7°C	6.30 kW	5.80 kW
COP Tj = +7°C	5.50	4.10
Pdh Tj = 12°C	7.40 kW	7.10 kW
COP Tj = 12°C	7.20	5.50
Pdh Tj = Tbiv	12.00 kW	11.50 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.40	1.80
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	10.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	88 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.70 kW
Annual energy consumption Q_{he}	7408 kWh	9062 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.30
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

Model: THERMOR Alféa Excellia A.I. Tri 16

Configure model

Model name	THERMOR Alféa Excellia A.I. Tri 16
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.17 kW	12.24 kW
El input	3.70 kW	4.93 kW
COP	4.10	2.48

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	117 %
Prated	14.00 kW	13.00 kW
SCOP	3.80	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	7.30 kW	7.00 kW
COP Tj = +2°C	3.60	2.90
Pdh Tj = +7°C	6.30 kW	5.80 kW
COP Tj = +7°C	5.50	4.10
Pdh Tj = 12°C	7.40 kW	7.10 kW
COP Tj = 12°C	7.20	5.50
Pdh Tj = Tbiv	12.00 kW	11.50 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.40	1.80
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	10.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	88 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.70 kW
Annual energy consumption Q_{he}	7408 kWh	9062 kWh