

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	Alféa Hybrid Duo gaz Tri 14	Reg. No.	012-023
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Alféa Hybrid Duo gaz Tri 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	20.12.2016		
Testing basis	EN 14511:2013, EN 14825:2013, EN 12102:2013		

Model: Alféa Hybrid Duo Gaz Tri 14

Configure model	
Model name	Alféa Hybrid Duo Gaz Tri 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	80 °C	80 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh

Model: Alféa Condensol Hybrid Duo Gaz Tri 14

Configure model	
Model name	Alféa Condensol Hybrid Duo Gaz Tri 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	80 °C	80 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh