

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 22 Jun 2022

#### **Login**

Summary of	Assure Mono 12 16	Reg. No.	ICIM-PDC-000082-00		
Certificate Holder		<u> </u>			
Name	BAXI Heating UK Limited	BAXI Heating UK Limited			
Address	Acordn House, Coventry road	Acordn House, Coventry road Zip CV34 4RT			
City	Warwick	Country	United Kingdom		
Certification Body	ICIM S.p.A.				
Subtype title	Assure Mono 12 16				
Heat Pump Type	Outdoor Air/Water				
Refrigerant	R32				
Mass of Refrigerant	2.8 kg				
Certification Date	25.06.2020				
Testing basis	HP KEYMARK certification scheme rules rev. 7				



This information was generated by the HP KEYMARK database on 22 Jun 2022

# **Model: Assure Mono 12**

Configure model		
Model name	Assure Mono 12	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.30 kW	11.90 kW
El input	2.56 kW	4.28 kW
СОР	4.81	2.78

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

#### **Average Climate**



 $$\operatorname{\textit{Page}}\ 3$$  of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
COP Tj = -7°C	2.88	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.12 kW	4.96 kW
COP Tj = +7°C	5.74	4.25
Cdh Tj = +7 °C	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.23 kW	2.37 kW
COP Tj = 12°C	5.40	4.94
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW
COP Tj = Tbiv	2.88	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.01 kW	11.88 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	15 W	15 W
PSB	9 W	9 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5726 kWh	8164 kWh



This information was generated by the HP KEYMARK database on 22 Jun 2022

# **Model: Assure Mono 16**

Configure model		
Model name	Assure Mono 16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	16.10 kW
El input	3.66 kW	5.90 kW
СОР	4.45	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

#### **Average Climate**



 $$\operatorname{\textit{Page}}\xspace$  6 of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	dB(A)	dB(A)		
Sound power level outdoor	71 dB(A)	71 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
$\eta_{s}$	169 %	128 %	
Prated	16.00 kW	15.00 kW	
SCOP	4.30	3.27	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	14.15 kW	12.90 kW	
COP Tj = -7°C	2.72	2.04	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	8.92 kW	8.25 kW	
COP Tj = +2°C	4.17	3.21	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	5.64 kW	5.45 kW	
COP Tj = +7°C	5.86	4.32	
Cdh Tj = +7 °C	0.90	0.90	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$  of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.47 kW	2.57 kW
COP Tj = 12°C	6.28	5.12
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW
COP Tj = Tbiv	2.72	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.93 kW	11.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	41 W	41 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption Qhe	7687 kWh	9216 kWh