Summary of	WPE-I 04/06/08 H(K)(W) Premium	Reg. No.	011-1W0394
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	RISE Research Institutes of Sweden AB		
Subtype title	WPE-I 04/06/08 H(K)(W) Premium		
Heat Pump Type	Brine/Water		
Refrigerant	Other		
Mass Of Refrigerant	2.2 kg		
Certification Date	08.09.2020		

Model: WPE-I 04 H(K)(W) Premium

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	1.96 kW	1.26 kW
El input	0.43 kW	0.47 kW
COP	4.60	2.73
Indoor water flow rate	0.34 m³/h	0.14 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	195 %	153 %
Prated	4.23 kW	3.76 kW
SCOP	5.07	4.02
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.73 kW	3.32 kW
COP Tj = -7°C	5.01	3.58
Cdh	0.90	0.90
Pdh Tj = +2°C	2.26 kW	2.02 kW
COP Tj = +2°C	5.38	4.22
Cdh	0.90	0.90
Pdh Tj = +7°C	1.45 kW	1.30 kW
COP Tj = +7°C	5.34	4.47
Cdh	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.08 kW

COP Tj = 12°C	5.32	4.49
Cdh	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL	4.23 kW	3.76 kW
COP Tj = TOL	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1723 kWh	1934 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	187 %	147 %
Prated	4.23 kW	3.76 kW
SCOP	4.87	3.87
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.23 kW	3.76 kW
COP Tj = +2°C	4.86	3.43
Cdh	0.90	0.90
Pdh Tj = +7°C	2.71 kW	2.41 kW
COP Tj = +7°C	5.24	3.95
Cdh	0.90	0.90
Pdh Tj = 12°C	1.20 kW	1.08 kW
COP Tj = 12°C	5.31	4.39
Cdh	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL	4.23 kW	3.76 kW
COP Tj = TOL	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W

PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1159 kWh	1300 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	201 %	157 %
Prated	4.23 kW	3.76 kW
SCOP	5.21	4.12
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.55 kW	2.27 kW
COP Tj = -7°C	5.37	4.10
Cdh	0.90	0.90

Pdh Tj = +2°C	1.55 kW	1.38 kW
COP Tj = +2°C	5.45	4.37
Cdh	0.90	0.90
Pdh Tj = +7°C	1.13 kW	1.09 kW
COP Tj = +7°C	5.31	4.51
Cdh	0.90	0.90
Pdh Tj = 12°C	1.12 kW	1.09 kW
COP Tj = 12°C	5.21	4.52
Cdh	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL	4.23 kW	3.76 kW
COP Tj = TOL	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2000 kWh	2252 kWh

Model: WPE-I 06 H(K)(W) Premium

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.37 kW	2.01 kW
El input	0.52 kW	0.69 kW
COP	4.60	2.91
Indoor water flow rate	0.41 m³/h	0.22 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	200 %	160 %
Prated	6.70 kW	6.05 kW
SCOP	5.20	4.18
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.91 kW	5.34 kW
COP Tj = -7°C	4.71	3.55
Cdh	0.90	0.90
Pdh Tj = +2°C	3.59 kW	3.25 kW
COP Tj = +2°C	5.39	4.27
Cdh	0.90	0.90
Pdh Tj = +7°C	2.30 kW	2.09 kW
COP Tj = +7°C	5.60	4.76
Cdh	0.90	0.90
Pdh Tj = 12°C	1.14 kW	1.08 kW

COP Tj = 12°C	5.47	4.61
Cdh	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL	6.70 kW	6.05 kW
COP Tj = TOL	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2662 kWh	2988 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	198 %	158 %
Prated	6.70 kW	6.05 kW
SCOP	5.14	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.70 kW	6.05 kW
COP Tj = +2°C	4.52	3.34
Cdh	0.90	0.90
Pdh Tj = +7°C	4.29 kW	3.88 kW
COP Tj = +7°C	5.19	3.97
Cdh	0.90	0.90
Pdh Tj = 12°C	1.90 kW	1.72 kW
COP Tj = 12°C	5.71	4.81
Cdh	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL	6.70 kW	6.05 kW
COP Tj = TOL	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W

PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1741 kWh	1954 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	207 %	166 %
Prated	6.70 kW	6.05 kW
SCOP	5.38	4.34
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.04 kW	3.65 kW
COP Tj = -7°C	5.36	4.15
Cdh	0.90	0.90

Pdh Tj = +2°C	2.45 kW	2.22 kW
COP Tj = +2°C	5.64	4.68
Cdh	0.90	0.90
Pdh Tj = +7°C	1.57 kW	1.42 kW
COP Tj = +7°C	5.76	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.10 kW
COP Tj = 12°C	5.32	4.73
Cdh	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL	6.70 kW	6.05 kW
COP Tj = TOL	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3069 kWh	3439 kWh

Model: WPE-I 08 H(K)(W) Premium

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.78 kW	2.42 kW
El input	0.60 kW	0.79 kW
COP	4.67	3.07
Indoor water flow rate	0.48 m³/h	0.27 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	197 %	158 %
Prated	7.66 kW	6.93 kW
SCOP	5.12	4.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.76 kW	6.12 kW
COP Tj = -7°C	4.53	3.44
Cdh	0.90	0.90
Pdh Tj = +2°C	4.11 kW	3.72 kW
COP Tj = +2°C	5.25	4.21
Cdh	0.90	0.90
Pdh Tj = +7°C	2.64 kW	2.39 kW
COP Tj = +7°C	5.59	4.69
Cdh	0.90	0.90
Pdh Tj = 12°C	1.16 kW	1.08 kW

COP Tj = 12°C	5.52	4.61
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL	7.66 kW	6.93 kW
COP Tj = TOL	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3094 kWh	3461 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	197 %	157 %
Prated	7.66 kW	6.93 kW
SCOP	5.13	4.13
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.66 kW	6.93 kW
COP Tj = +2°C	4.29	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	4.91 kW	4.45 kW
COP Tj = +7°C	5.09	3.88
Cdh	0.90	0.90
Pdh Tj = 12°C	2.17 kW	1.97 kW
COP Tj = 12°C	5.75	4.85
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL	7.66 kW	6.93 kW
COP Tj = TOL	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W

PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1997 kWh	2243 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	163 %
Prated	7.66 kW	6.93 kW
SCOP	5.29	4.29
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.62 kW	4.18 kW
COP Tj = -7°C	5.17	4.07
Cdh	0.90	0.90

Pdh Tj = +2°C	2.81 kW	2.54 kW
COP Tj = +2°C	5.60	4.60
Cdh	0.90	0.90
Pdh Tj = +7°C	1.80 kW	1.63 kW
COP Tj = +7°C	5.76	4.90
Cdh	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.09 kW
COP Tj = 12°C	5.34	4.75
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL	7.66 kW	6.93 kW
COP Tj = TOL	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3570 kWh	3985 kWh