

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	BoxAir Inverter BA22IS-1	Reg. No.	037-0068-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA22IS-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.3 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: BoxAir Inverter BA22IS-1

Configure model			
Model name	BoxAir Inverter BA22IS-1		
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	4.91 kW	4.52 kW	
El input	1.04 kW	1.49 kW	
СОР	4.72	3.05	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	48 dB(A)	48 dB(A)	
Sound power level outdoor	55 dB(A)	55 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	172 %	130 %
Prated	4.51 kW	4.44 kW
SCOP	4.38	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.99 kW	3.93 kW
COP Tj = -7°C	2.74	2.03
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.58 kW	2.45 kW
COP Tj = +2°C	4.16	3.15
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.64 kW	1.69 kW
COP Tj = +7°C	6.22	4.74
Cdh Tj = +7 °C	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	2.08 kW	1.96 kW
COP Tj = 12°C	7.50	5.74
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	3.99 kW	3.93 kW
COP Tj = Tbiv	2.74	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.64 kW	3.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	1.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
РТО	17 W	17 W
PSB	18 W	18 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.87 kW	0.77 kW
Annual energy consumption Qhe	2128 kWh	2759 kWh