

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	LWDV 91-1/3	Reg. No.	041-K001-24
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	WPZ		
Subtype title	LWDV 91-1/3		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass Of Refrigerant	1.05 kg		
Certification Date	27.08.2019		

## Model: LWDV 91-1/3-HDV 12-3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.77 kW	4.23 kW
El input	0.52 kW	1.26 kW
COP	5.41	3.35
Indoor water flow rate	0.47 m <sup>3</sup> /h	0.46 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	147 %
Prated	9.50 kW	8.90 kW
SCOP	4.75	3.75
Tbiv	-5 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.28 kW	7.07 kW
COP Tj = -7°C	2.96	2.19
Pdh Tj = +2°C	5.43 kW	4.86 kW
COP Tj = +2°C	5.17	4.86
Pdh Tj = +7°C	3.37 kW	3.18 kW
COP Tj = +7°C	6.90	5.36
Pdh Tj = 12°C	3.28 kW	3.18 kW
COP Tj = 12°C	8.22	6.77
Pdh Tj = Tbiv	7.68 kW	7.50 kW
COP Tj = Tbiv	3.11	2.35

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.63 kW	6.79 kW
COP Tj = TOL	3.05	2.07
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.87 kW	2.11 kW
Annual energy consumption Qhe	4135 kWh	4904 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	218 %	171 %
Prated	9.50 kW	9.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.53	4.36
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.98 kW	8.10 kW
COP Tj = +2°C	3.49	2.32
Pdh Tj = +7°C	5.89 kW	6.24 kW
COP Tj = +7°C	5.99	4.07
Pdh Tj = 12°C	3.12 kW	3.24 kW
COP Tj = 12°C	7.47	6.53
Pdh Tj = Tbiv	8.15 kW	8.06 kW
COP Tj = Tbiv	3.81	2.70
Pdh Tj = TOL	7.98 kW	8.10 kW
COP Tj = TOL	3.49	2.32
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.52 kW	1.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption $Q_{he}$	2295 kWh	2910 kWh
------------------------------------	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	160 %	119 %
Prated	7.50 kW	6.50 kW
SCOP	4.07	3.04
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.50 kW	3.87 kW
COP Tj = -7°C	3.49	2.57
Pdh Tj = +2°C	2.87 kW	2.35 kW
COP Tj = +2°C	4.82	3.57
Pdh Tj = +7°C	2.97 kW	2.88 kW
COP Tj = +7°C	7.17	5.76
Pdh Tj = 12°C	3.05 kW	3.17 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	7.39	6.91
Pdh Tj = Tbiv	6.43 kW	5.70 kW
COP Tj = Tbiv	2.50	1.72
Pdh Tj = TOL	5.59 kW	5.06 kW
COP Tj = TOL	2.14	1.53
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.91 kW	1.44 kW
Annual energy consumption Qhe	4541 kWh	5277 kWh

## Model: LWDV 91-1/3-HDV 9-1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.77 kW	4.23 kW
El input	0.52 kW	1.26 kW
COP	5.41	3.35
Indoor water flow rate	0.47 m <sup>3</sup> /h	0.46 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	147 %
Prated	9.50 kW	8.90 kW
SCOP	4.90	3.85
Tbiv	-5 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.28 kW	7.07 kW
COP Tj = -7°C	2.96	2.19
Pdh Tj = +2°C	5.43 kW	4.86 kW
COP Tj = +2°C	5.17	4.86
Pdh Tj = +7°C	3.37 kW	3.18 kW
COP Tj = +7°C	6.90	5.36
Pdh Tj = 12°C	3.28 kW	3.18 kW
COP Tj = 12°C	8.22	6.77
Pdh Tj = Tbiv	7.68 kW	7.50 kW
COP Tj = Tbiv	3.11	2.35

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.63 kW	6.79 kW
COP Tj = TOL	3.05	2.07
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.87 kW	1.87 kW
Annual energy consumption Qhe	4135 kWh	4904 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	218 %	172 %
Prated	9.50 kW	9.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.53	4.36
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.98 kW	8.10 kW
COP Tj = +2°C	3.49	2.32
Pdh Tj = +7°C	5.89 kW	6.24 kW
COP Tj = +7°C	5.99	4.07
Pdh Tj = 12°C	3.12 kW	3.24 kW
COP Tj = 12°C	7.47	6.53
Pdh Tj = Tbiv	8.15 kW	8.06 kW
COP Tj = Tbiv	3.81	2.70
Pdh Tj = TOL	7.98 kW	8.10 kW
COP Tj = TOL	3.49	2.32
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.52 kW	1.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption $Q_{he}$	2295 kWh	2910 kWh
------------------------------------	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	160 %	118 %
Prated	7.50 kW	6.50 kW
SCOP	4.07	3.04
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.50 kW	3.87 kW
COP Tj = -7°C	3.49	2.57
Pdh Tj = +2°C	2.87 kW	2.35 kW
COP Tj = +2°C	4.82	3.57
Pdh Tj = +7°C	2.97 kW	2.88 kW
COP Tj = +7°C	7.17	5.76
Pdh Tj = 12°C	3.05 kW	3.17 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	7.39	6.91
Pdh Tj = Tbiv	6.43 kW	5.70 kW
COP Tj = Tbiv	2.50	1.72
Pdh Tj = TOL	5.59 kW	5.06 kW
COP Tj = TOL	2.14	1.53
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.91 kW	1.44 kW
Annual energy consumption Qhe	4541 kWh	5277 kWh

## Model: LWDV 91-1/3-HSDV 12M3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.77 kW	4.23 kW
El input	0.52 kW	1.26 kW
COP	5.41	3.35
Indoor water flow rate	0.47 m <sup>3</sup> /h	0.46 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	147 %
Prated	9.50 kW	8.90 kW
SCOP	4.90	3.85
Tbiv	-5 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.28 kW	7.07 kW
COP Tj = -7°C	2.96	2.19
Pdh Tj = +2°C	5.43 kW	4.86 kW
COP Tj = +2°C	5.17	4.86
Pdh Tj = +7°C	3.37 kW	3.18 kW
COP Tj = +7°C	6.90	5.36
Pdh Tj = 12°C	3.28 kW	3.18 kW
COP Tj = 12°C	8.22	6.77
Pdh Tj = Tbiv	7.68 kW	7.50 kW
COP Tj = Tbiv	3.11	2.35

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.63 kW	6.79 kW
COP Tj = TOL	3.05	2.07
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.87 kW	2.11 kW
Annual energy consumption Qhe	4135 kWh	4904 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	218 %	171 %
Prated	9.50 kW	9.50 kW



This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.53	4.36
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.98 kW	8.10 kW
COP Tj = +2°C	3.49	2.32
Pdh Tj = +7°C	5.89 kW	6.24 kW
COP Tj = +7°C	5.99	4.07
Pdh Tj = 12°C	3.12 kW	3.24 kW
COP Tj = 12°C	7.47	6.53
Pdh Tj = Tbiv	8.15 kW	8.06 kW
COP Tj = Tbiv	3.81	2.70
Pdh Tj = TOL	7.98 kW	8.10 kW
COP Tj = TOL	3.49	2.32
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.52 kW	1.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption $Q_{he}$	2295 kWh	2910 kWh
------------------------------------	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	160 %	119 %
Prated	7.50 kW	6.50 kW
SCOP	4.07	3.04
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.50 kW	3.87 kW
COP Tj = -7°C	3.49	2.57
Pdh Tj = +2°C	2.87 kW	2.35 kW
COP Tj = +2°C	4.82	3.57
Pdh Tj = +7°C	2.97 kW	2.88 kW
COP Tj = +7°C	7.17	5.76
Pdh Tj = 12°C	3.05 kW	3.17 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	7.39	6.91
Pdh Tj = Tbiv	6.43 kW	5.70 kW
COP Tj = Tbiv	2.50	1.72
Pdh Tj = TOL	5.59 kW	5.06 kW
COP Tj = TOL	2.14	1.53
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.91 kW	1.44 kW
Annual energy consumption Qhe	4541 kWh	5277 kWh

## Model: LWDV91-1/3-HSDV 9M-1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.77 kW	4.23 kW
El input	0.52 kW	1.26 kW
COP	5.41	3.35
Indoor water flow rate	0.47 m <sup>3</sup> /h	0.46 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	187 %	147 %
Prated	9.50 kW	8.90 kW
SCOP	4.75	3.75
Tbiv	-5 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.28 kW	7.07 kW
COP Tj = -7°C	2.96	2.19
Pdh Tj = +2°C	5.43 kW	4.86 kW
COP Tj = +2°C	5.17	4.86
Pdh Tj = +7°C	3.37 kW	3.18 kW
COP Tj = +7°C	6.90	5.36
Pdh Tj = 12°C	3.28 kW	3.18 kW
COP Tj = 12°C	8.22	6.77
Pdh Tj = Tbiv	7.68 kW	7.50 kW
COP Tj = Tbiv	3.11	2.35

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.63 kW	6.79 kW
COP Tj = TOL	3.05	2.07
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.87 kW	2.11 kW
Annual energy consumption Qhe	4135 kWh	4904 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	218 %	171 %
Prated	9.50 kW	9.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.53	4.36
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.98 kW	8.10 kW
COP Tj = +2°C	3.49	2.32
Pdh Tj = +7°C	5.89 kW	6.24 kW
COP Tj = +7°C	5.99	4.07
Pdh Tj = 12°C	3.12 kW	3.24 kW
COP Tj = 12°C	7.47	6.53
Pdh Tj = Tbiv	8.15 kW	8.06 kW
COP Tj = Tbiv	3.81	2.70
Pdh Tj = TOL	7.98 kW	8.10 kW
COP Tj = TOL	3.49	2.32
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.52 kW	1.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption $Q_{he}$	2295 kWh	2910 kWh
------------------------------------	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	54 dB(A)	54 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	160 %	119 %
Prated	7.50 kW	6.50 kW
SCOP	4.07	3.04
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.50 kW	3.87 kW
COP Tj = -7°C	3.49	2.57
Pdh Tj = +2°C	2.87 kW	2.35 kW
COP Tj = +2°C	4.82	3.57
Pdh Tj = +7°C	2.97 kW	2.88 kW
COP Tj = +7°C	7.17	5.76
Pdh Tj = 12°C	3.05 kW	3.17 kW



This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	7.39	6.91
Pdh Tj = Tbiv	6.43 kW	5.70 kW
COP Tj = Tbiv	2.50	1.72
Pdh Tj = TOL	5.59 kW	5.06 kW
COP Tj = TOL	2.14	1.53
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.91 kW	1.44 kW
Annual energy consumption Qhe	4541 kWh	5277 kWh