

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ecodan Power Inverter 10 AA	Reg. No.	037-0050-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Name of testing laboratory	RISE Research Institute of Sweden		
Subtype title	Ecodan Power Inverter 10 AA		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	4.2 kg		
Certification Date	09.04.2020		
Testing basis	HP Keymark scheme rules rev. no. 7		

Model: PUAZ-SW100VAA(-BS) + EHSC-M*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-VM*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-YM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + EHST20C-M*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-VM*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-YM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERSC-M*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + ERSC-VM*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + ERST20C-M*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERST20C-VM*C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.97	0.98
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.97	0.98
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	42.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHSC-M*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-VM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-YM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + EHST20C-M*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHST20C-VM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHST20C-YM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERSC-M*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + ERSC-VM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + ERST20C-M*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERST20C-VM*C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m ³ /h	1.20 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.96	0.97
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.96	0.97
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.97
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	103 %
COP	2.45
Heating up time	01:57 h:min
Standby power input	46.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-M*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-VM*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHST20C-YM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + EHSC-M*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-VM*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + EHSC-YM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + ERST20C-VM*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100VAA(-BS) + ERSC-M*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100VAA(-BS) + ERSC-VM*D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Model: PUAZ-SW100YAA(-BS) + EHST20C-M*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHST20C-VM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHST20C-YM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + EHSC-M*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-VM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + EHSC-YM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + ERST20C-VM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.41
Heating up time	01:58 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUAZ-SW100YAA(-BS) + ERSC-M*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Model: PUAZ-SW100YAA(-BS) + ERSC-VM*D

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.52 kW	4.31 kW
COP	4.45	2.60
Indoor water flow rate	1.93 m ³ /h	1.21 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	0.99	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.98	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.97	0.98

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.96	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	7.50 kW	7.50 kW
COP Tj = TOL	1.42	1.49
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.64 kW	1.42 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh