

This information was generated by the HP KEYMARK database on 2 May 2022

[Login](#)

Summary of	R32 THERMAV IWT(2ND) 5,7,9kW	Reg. No.	011-1W0526
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu	Zip	51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	R32 THERMAV IWT(2ND) 5,7,9kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	29.04.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: HU051MR U44 / HN0913T NK0

Configure model	
Model name	HU051MR U44 / HN0913T NK0
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.12 kW	2.04 kW
COP	4.90	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 2 May 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	126 %
Prated	5.50 kW	6.00 kW
SCOP	4.65	3.23
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.90 kW	5.30 kW
COP Tj = -7°C	2.80	2.05
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.00 kW	3.20 kW
COP Tj = +2°C	4.50	3.10
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.20 kW	3.00 kW
COP Tj = +7°C	6.40	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 2 May 2022

Pdh Tj = 12°C	2.60 kW	3.60 kW
COP Tj = 12°C	9.20	6.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.50	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.50 kW	5.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	2444 kWh	3837 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 2 May 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	133 %
COP	3.15
Heating up time	1:44 h:min
Standby power input	30.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	250 l

Model: HU071MR U44 / HN0913T NK0

Configure model	
Model name	HU071MR U44 / HN0913T NK0
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.00 kW	5.50 kW
El input	1.43 kW	2.04 kW
COP	4.90	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	126 %
Prated	5.80 kW	6.00 kW
SCOP	4.65	3.23
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.10 kW	5.30 kW
COP Tj = -7°C	2.80	2.05
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.10 kW	3.20 kW
COP Tj = +2°C	4.50	3.10
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	3.00 kW
COP Tj = +7°C	6.50	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 2 May 2022

Pdh Tj = 12°C	2.80 kW	3.60 kW
COP Tj = 12°C	9.00	6.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.50	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.80 kW	5.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	2575 kWh	3837 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 2 May 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	133 %
COP	3.15
Heating up time	1:44 h:min
Standby power input	30.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	250 l

Model: HU091MR U44 / HN0913T NK0

Configure model

Model name	HU091MR U44 / HN0913T NK0
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	9.00 kW	5.50 kW
El input	1.94 kW	2.04 kW
COP	4.65	2.70

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	126 %
Prated	6.00 kW	6.00 kW
SCOP	4.65	3.23
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	5.30 kW
COP Tj = -7°C	2.75	2.05
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.20 kW	3.20 kW
COP Tj = +2°C	4.50	3.10
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.30 kW	3.00 kW
COP Tj = +7°C	6.50	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 2 May 2022

Pdh Tj = 12°C	2.80 kW	3.60 kW
COP Tj = 12°C	9.00	6.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.00 kW	5.30 kW
COP Tj = Tbiv	2.45	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.45	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	2666 kWh	3837 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 2 May 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	140 %
COP	3.40
Heating up time	1:44 h:min
Standby power input	30.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	250 l