

Page 1 of 4 This information was generated by the HP KEYMARK database on 23 Dec 2020

C	The way of the County County TCC12 1C/TCC12DIV	Dan Na	012 6700001
Summary of	Thermastage Compact Combi TSC13-16/ TOC13RIY	Reg. No.	012-C700091
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Thermastage Compact Combi TSC13-16/ TOC13RIY		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.5 kg		
Certification Date	22.12.2020		
Testing basis	HP Keymark Scheme 2017		



This information was generated by the HP KEYMARK database on 23 Dec 2020

Model: Compact Combi TSC13-16/ TOC13RIY

General Data	
Power supply 1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
СОР	4.25	2.47
Indoor water flow rate	1.90 m³/h	0.90 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 4 This information was generated by the HP KEYMARK database on 23 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	151 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Pdh Tj = $+7^{\circ}$ C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Pdh Tj = Tbiv	10.00 kW	8.20 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 23 Dec 2020

COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	8 W	8 W
РТО	45 W	22 W
PSB	12 W	12 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6623 kWh