Login

Summary of	DAIKIN ALTHERMA LT SPLIT / ROTEX HPSU BI-BLOC 16 KW (3PH)	Reg. No.	011-1W0078
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA LT SPLIT / ROTEX HPSU BI-BLOC 16 KW (3PH)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.4 kg		
Certification Date	31.03.2017		
Testing basis	HP KEYMARK certification scheme rules rev. no. 1.1		

Model: ERLQ016CW1 / EHBH16CB *

Configure model	
Model name	ERLQ016CW1 / EHBH16CB *
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Model: ERLQ016CW1 / EHBX16CB *

Configure model	
Model name	ERLQ016CW1 / EHBX16CB *
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Model: ERLQ016CW1 / EHVH16S18CB *

Configure model	
Model name	ERLQ016CW1 / EHVH16S18CB *
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	87 %
COP	2.14
Heating up time	1:04 h:min
Standby power input	50.0 W
Reference hot water temperature	50.1 °C
Mixed water at 40°C	224 l

Model: ERLQ016CW1 / EHVH16S26CB *

Configure model	
Model name	ERLQ016CW1 / EHVH16S26CB *
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	98 %
COP	2.02
Heating up time	1:25 h:min
Standby power input	45.1 W
Reference hot water temperature	50.2 °C
Mixed water at 40°C	338 l

Model: ERLQ016CW1 / EHVX16S18CB *

Configure model	
Model name	ERLQ016CW1 / EHVX16S18CB *
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	87 %
COP	2.14
Heating up time	1:04 h:min
Standby power input	50.0 W
Reference hot water temperature	50.1 °C
Mixed water at 40°C	224 l

Model: ERLQ016CW1 / EHVX16S26CB *

Configure model	
Model name	ERLQ016CW1 / EHVX16S26CB *
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	98 %
COP	2.02
Heating up time	1:25 h:min
Standby power input	45.1 W
Reference hot water temperature	50.2 °C
Mixed water at 40°C	338 l

Model: ERLQ016CW1 / EHVZ16S18CB *

Configure model	
Model name	ERLQ016CW1 / EHVZ16S18CB *
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	15.90 kW	15.04 kW
El input	3.77 kW	5.37 kW
COP	4.22	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	87 %
COP	2.14
Heating up time	1:04 h:min
Standby power input	50.0 W
Reference hot water temperature	50.1 °C
Mixed water at 40°C	224 l

Model: RRLQ016CW1 / RHBH16CB *

Configure model	
Model name	RRLQ016CW1 / RHBH16CB *
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Cdh Tj = +7 °C	0.94	1.00

Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Cdh Tj = +12 °C	0.92	0.93
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh

Model: RRLQ016CW1 / RHBX16CB *

Configure model	
Model name	RRLQ016CW1 / RHBX16CB *
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.25	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	149 %	119 %
Prated	16.00 kW	13.90 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.62 kW	7.61 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.74 kW	4.83 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.38 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW

COP Tj = Tbiv	2.56	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.05	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.35 kW	0.58 kW
Annual energy consumption Qhe	8270 kWh	8970 kWh