

		<u>- </u>	
Summary of	WPL 17 I(K)CS classic	Reg. No.	011-1W0224
Certificate Holder		· ·	-
Name	STIEBEL ELTRON GmbH & C	o KG	
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut GmbH		
Subtype title	WPL 17 I(K)CS classic		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.6 kg		
Certification Date	04.09.2019		
Testing basis	HP KEYMARK certification scheme rules rev. no. 5		



Model: WPL 17 IKCS classic

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	4.22 kW	3.75 kW	
El input	0.92 kW	1.49 kW	
СОР	4.60	2.51	
Indoor water flow rate	0.60 m³/h	0.60 m³/h	

Average Climate

EN 14825





	Low temperature	Medium temperature
η_{s}	161 %	126 %
Prated	9.20 kW	7.10 kW
SCOP	4.11	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.93 kW	6.28 kW
COP Tj = -7°C	2.61	2.13
Cdh	0.90	0.90
Pdh Tj = +2°C	5.16 kW	4.73 kW
COP Tj = +2°C	4.03	3.04
Cdh	0.90	0.90
Pdh Tj = +7°C	4.20 kW	4.20 kW
COP Tj = +7°C	5.25	4.44
Cdh	0.90	0.90
Pdh Tj = 12°C	3.39 kW	3.14 kW
COP Tj = 12°C	8.03	6.21
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.93 kW	6.28 kW
COP Tj = Tbiv	2.61	2.13
Pdh Tj = TOL	7.29 kW	2.77 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = TOL	2.55	1.83
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
РТО	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.91 kW	4.43 kW
Annual energy consumption Qhe	4621 kWh	4564 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	44 dB(A)

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	207 %	142 %
Prated	4.95 kW	4.30 kW
SCOP	5.24	3.63





	<u> </u>	
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = $+2$ °C	4.95 kW	4.34 kW
COP Tj = +2°C	3.70	2.21
Cdh	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.21 kW	3.96 kW
$COP Tj = +7^{\circ}C$	4.90	3.21
Cdh	0.90	0.90
Pdh Tj = 12°C	3.31 kW	2.98 kW
COP Tj = 12°C	7.35	5.30
Cdh	0.90	0.90
Pdh Tj = Tbiv	4.95 kW	4.34 kW
COP Tj = Tbiv	3.70	2.21
Pdh Tj = TOL	4.95 kW	4.34 kW
COP Tj = TOL	3.70	2.21
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
РТО	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
	1	!





Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1262 kWh	1584 kWh

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	40 dB(A)	44 dB(A)	

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	43 dB(A)	48 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	126 %	105 %
Prated	13.20 kW	12.70 kW
SCOP	3.23	2.69
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.96 kW	7.69 kW





	· · · · · · · · · · · · · · ·	ANK database on 17 Dec 2020
COP Tj = -7°C	2.73	2.26
Cdh	0.90	0.90
Pdh Tj = $+2$ °C	5.29 kW	4.89 kW
COP Tj = +2°C	4.24	3.49
Cdh	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.19 kW	4.21 kW
$COPTj = +7^{\circ}C$	5.45	4.82
Cdh	0.90	0.90
Pdh Tj = 12°C	3.39 kW	3.23 kW
COP Tj = 12°C	8.03	6.75
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.96 kW	7.69 kW
COP Tj = Tbiv	2.73	2.26
Pdh Tj = TOL	5.13 kW	5.24 kW
COP Tj = TOL	2.27	1.00
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
РТО	21 W	21 W
PSB	56 W	56 W
РСК	26 W	26 W



Page 8 of 15

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	7.38 kW	6.79 kW
Annual energy consumption Qhe	10074 kWh	11651 kWh
Pdh Tj = -15°C (if TOL $<$ -20°C)	6.21	6.18
COP Tj = -15°C (if TOL<-20°C)	2.43	1.48
Cdh	0.90	0.90



Model: WPL 17 ICS classic

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.27 kW	3.81 kW
El input	0.90 kW	1.48 kW
СОР	4.74	2.58
Indoor water flow rate	0.60 m³/h	0.60 m³/h

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	167 %	129 %
Prated	9.00 kW	7.20 kW
SCOP	4.24	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.98 kW	6.39 kW
COP Tj = -7°C	2.65	2.17
Cdh	0.90	0.90
Pdh Tj = +2°C	5.25 kW	4.81 kW
COP Tj = +2°C	4.19	3.14
Cdh	0.90	0.90
Pdh Tj = +7°C	4.26 kW	4.25 kW
COP Tj = +7°C	5.44	4.56
Cdh	0.90	0.90
Pdh Tj = 12°C	3.43 kW	3.18 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






$$\operatorname{\textit{Page}}\ 11$$ of 15 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.21	6.33
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.98 kW	6.39 kW
COP Tj = Tbiv	2.65	2.17
Pdh Tj = TOL	7.35 kW	2.77 kW
COP Tj = TOL	2.59	1.83
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
РТО	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.65 kW	4.43 kW
Annual energy consumption Qhe	4387 kWh	4506 kWh
•		

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	48 dB(A)


EN 14825





	Low temperature	Medium temperature
η_{s}	212 %	145 %
Prated	5.02 kW	4.40 kW
SCOP	5.38	3.69
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.02 kW	4.42 kW
COP Tj = +2°C	3.83	2.27
Cdh	0.90	0.90
Pdh Tj = +7°C	4.27 kW	4.02 kW
COP Tj = +7°C	5.06	3.30
Cdh	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.01 kW
COP Tj = 12°C	7.50	5.35
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.02 kW	4.42 kW
COP Tj = Tbiv	3.83	2.27
Pdh Tj = TOL	5.02 kW	4.42 kW
COP Tj = TOL	3.83	2.27
Cdh	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





WTOL 60 °C 60 °C Poff 56 W 56 W	
Poff 56 W 56 W	
PTO 21 W 21 W	
PSB 56 W 56 W	
PCK 26 W 26 W	
Supplementary Heater: Type of energy input electricity electricity	
Supplementary Heater: PSUP 0.00 kW 0.00 kW	
Annual energy consumption Qhe 1247 kWh 1592 kWh	

Colder Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	43 dB(A)	48 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{S}	130 %	112 %	
Prated	13.40 kW	13.00 kW	
SCOP	3.33	2.86	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
	·		





This information was generated by the HP REYMARK database on 17 Dec 2020				
Pdh Tj = -7°C	8.13 kW	7.84 kW		
COP Tj = -7°C	2.81	2.31		
Cdh	0.90	0.90		
Pdh Tj = +2°C	5.39 kW	4.96 kW		
COP Tj = +2°C	4.42	3.61		
Cdh	0.90	0.90		
Pdh Tj = $+7^{\circ}$ C	4.26 kW	4.27 kW		
$COPTj = +7^{\circ}C$	5.65	4.98		
Cdh	0.90	0.90		
Pdh Tj = 12°C	3.43 kW	3.26 kW		
COP Tj = 12°C	8.21	6.88		
Cdh	0.90	0.90		
Pdh Tj = Tbiv	8.13 kW	7.84 kW		
COP Tj = Tbiv	2.81	2.31		
Pdh Tj = TOL	5.24 kW	5.24 kW		
COP Tj = TOL	2.33	2.33		
Cdh	0.90	0.90		
WTOL	60 °C	60 °C		
Poff	56 W	56 W		
РТО	21 W	21 W		
PSB	56 W	56 W		



$$\operatorname{\textit{Page}}\ 15$$ of 15 This information was generated by the HP KEYMARK database on 17 Dec 2020

PCK	26 W	26 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	7.45 kW	7.08 kW
Annual energy consumption Qhe	9919 kWh	11197 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.29	6.24
COP Tj = -15°C (if TOL $<$ -20°C)	2.47	2.32
Cdh	0.90	0.90