

Page 1 of 4

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	IDEAL HEATING Alféa Extensa A.I. 6	Reg. No.	012-SC0138-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	IDEAL HEATING Alféa Extensa A.I. 6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.1 kg		
Certification Date	04.04.2020		



This information was generated by the HP KEYMARK database on 21 Jun 2022

Model: IDEAL HEATING Alféa Extensa A.I. 6

Configure model		
Model name	IDEAL HEATING Alféa Extensa A.I. 6	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	
Phase-out Date	12.03.2024	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	4.50 kW
El input	1.41 kW	1.79 kW
СОР	4.26	2.51

This information was generated by the HP KEYMARK database on 21 Jun 2022

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	46 dB(A)	46 dB(A)	
Sound power level outdoor	63 dB(A)	63 dB(A)	

EN 14825		
Low temperature	Medium temperature	
169 %	115 %	
5.00 kW	5.00 kW	
4.30	2.95	
-7 °C	-7 °C	
-10 °C	-10 °C	
4.60 kW	4.00 kW	
2.70	1.80	
2.80 kW	2.50 kW	
4.20	2.90	
2.30 kW	1.70 kW	
6.00	4.00	
2.30 kW	2.10 kW	
8.30	5.80	
	Low temperature 169 % 5.00 kW 4.30 -7 °C -10 °C 4.60 kW 2.70 2.80 kW 4.20 2.30 kW 6.00 2.30 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 21 Jun 2022

Pdh Tj = Tbiv	4.60 kW	4.00 kW
COP Tj = Tbiv	2.70	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	3.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
РТО	23 W	16 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption Qhe	2505 kWh	3180 kWh