

Page 1 of 8

This information was generated by the HP KEYMARK database on 22 Jun 2022

<u>Login</u>

Summary of	THERMOR Alféa Extensa A.I. 8 R32	Reg. No.	012-C700011		
Certificate Holder	Certificate Holder				
Name	Groupe Atlantic	Groupe Atlantic			
Address	44 boulevard des Etats-Unis	Zip	85000		
City	La Roche Sur Yon	Country	France		
Certification Body	RISE CERT				
Subtype title	THERMOR Alféa Extensa A.I. 8 R32				
Heat Pump Type	Outdoor Air/Water				
Refrigerant	R32				
Mass of Refrigerant	1.02 kg				
Certification Date	04.03.2020	04.03.2020			
Testing basis	HP Keymark Scheme Rules rev 7				



Model: THERMOR Alféa Extensa A.I. 8 R32

Configure model		
Model name THERMOR Alféa Extensa A.I. 8 R32		
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	7.00 kW
El input	1.69 kW	2.63 kW
СОР	4.43	2.66

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	128 %
Prated	6.50 kW	6.20 kW
SCOP	4.50	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.50 kW
COP Tj = -7°C	2.70	1.91
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = $+2$ °C	3.50 kW	3.30 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = $+7^{\circ}$ C	2.30 kW	2.10 kW
COP Tj = +7°C	6.32	4.60
Cdh Tj = +7 °C	0.960	0.970

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 8 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.07	6.37
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.80 kW	5.50 kW
COP Tj = Tbiv	2.70	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.69
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	55 °C	55 °C
Poff	4 W	4 W
РТО	14 W	14 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	2982 kWh	3903 kWh

Model: THERMOR Alféa Extensa Duo A.I. 8 R32

Configure model		
Model name THERMOR Alféa Extensa Duo A.I. 8 R32		
Application	Heating + DHW + low temp	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility No		
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	7.00 kW
El input	1.69 kW	2.63 kW
СОР	4.43	2.66

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	40 dB(A)	40 dB(A)		
Sound power level outdoor	60 dB(A)	60 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
η_{s}	177 %	128 %		
Prated	6.50 kW	6.20 kW		
SCOP	4.50	3.28		
Tbiv	-7 °C	-7 °C		
TOL	-10 °C	-10 °C		
Pdh Tj = -7°C	5.80 kW	5.50 kW		
COP Tj = -7°C	2.70	1.91		
Cdh Tj = -7 °C	0.990	1.000		
Pdh Tj = +2°C	3.50 kW	3.30 kW		
COP Tj = +2°C	4.35	3.18		
Cdh Tj = +2 °C	0.980	0.990		
Pdh Tj = +7°C	2.30 kW	2.10 kW		
COP Tj = +7°C	6.32	4.60		
Cdh Tj = +7 °C	0.960	0.970		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.07	6.37
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.80 kW	5.50 kW
COP Tj = Tbiv	2.70	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.69
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	55 °C	55 °C
Poff	4 W	4 W
РТО	14 W	14 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	2982 kWh	3903 kWh

Domestic Hot Water (DHW)

Average Climate





EN 16147				
Declared load profile	L			
Efficiency ηDHW	130 %			
СОР	3.10			
Heating up time	1:35 h:min			
Standby power input	30.0 W			
Reference hot water temperature	54.0 °C			
Mixed water at 40°C	245 I			