

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	TERRA 6 HPLB	Reg. No.	011-1W0415
Certificate Holder			
Name	Ochsner Wärmepumpen GmbH		
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut		
Subtype title	TERRA 6 HPLB		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.4 kg		
Certification Date	30.09.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: TERRA 6 HPLB, AVERAGE CLIMATE

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.89 kW	5.26 kW
El input	1.23 kW	1.80 kW
COP	4.80	2.92
Indoor water flow rate	1.02 m ³ /h	0.57 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	201 %	137 %
Prated	6.00 kW	5.00 kW
SCOP	5.22	3.63
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.30 kW
COP Tj = -7°C	4.84	3.05
Cdh		
Pdh Tj = +2°C	6.00 kW	5.50 kW
COP Tj = +2°C	5.16	3.58
Cdh		
Pdh Tj = +7°C	6.00 kW	5.70 kW
COP Tj = +7°C	5.48	3.98
Cdh		
Pdh Tj = 12°C	6.10 kW	5.80 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	5.84	4.45
Cdh		
Pdh Tj = Tbiv	5.90 kW	5.30 kW
COP Tj = Tbiv	4.78	2.92
Pdh Tj = TOL	5.90 kW	5.30 kW
COP Tj = TOL	4.78	2.92
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	55 W	55 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2326 kWh	2990 kWh

Model: TERRA 6 HPLB, low temperature, all climates

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

Low temperature

Heat output	5.89 kW
El input	1.23 kW
COP	4.80
Indoor water flow rate	1.02 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 14825

Low temperature

This information was generated by the HP KEYMARK database on 17 Dec 2020

η_s	201 %
Prated	6.00 kW
SCOP	5.22
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	5.90 kW
COP Tj = -7°C	4.84
Cdh	
Pdh Tj = +2°C	6.00 kW
COP Tj = +2°C	5.16
Cdh	
Pdh Tj = +7°C	6.00 kW
COP Tj = +7°C	5.48
Cdh	
Pdh Tj = 12°C	6.10 kW
COP Tj = 12°C	5.84
Cdh	
Pdh Tj = Tbiv	5.90 kW
COP Tj = Tbiv	4.78
Pdh Tj = TOL	5.90 kW
COP Tj = TOL	4.78

This information was generated by the HP KEYMARK database on 17 Dec 2020

WTOL	60 °C
Poff	0 W
PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2326 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	46 dB(A)

Warmer Climate

EN 14825	
	Low temperature
η_s	199 %
Prated	6.00 kW
SCOP	4.90
Tbiv	2 °C
TOL	2 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = +2°C	5.90 kW
COP Tj = +2°C	4.78
Cdh	
Pdh Tj = +7°C	5.90 kW
COP Tj = +7°C	5.09
Cdh	
Pdh Tj = 12°C	6.00 kW
COP Tj = 12°C	5.60
Cdh	
Pdh Tj = Tbiv	5.90 kW
COP Tj = Tbiv	4.78
Pdh Tj = TOL	5.90 kW
COP Tj = TOL	4.78
WTOL	60 °C
Poff	0 W
PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1517 kWh

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1	
	Low temperature
Sound power level indoor	46 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	207 %
Prated	7.00 kW
SCOP	5.11
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	6.00 kW
COP Tj = -7°C	5.33
Cdh	
Pdh Tj = +2°C	6.00 kW
COP Tj = +2°C	5.58
Cdh	
Pdh Tj = +7°C	6.10 kW
COP Tj = +7°C	5.79
Cdh	

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	6.10 kW
COP Tj = 12°C	5.52
Cdh	
Pdh Tj = Tbiv	6.00 kW
COP Tj = Tbiv	5.22
Pdh Tj = TOL	6.00 kW
COP Tj = TOL	5.22
WTOL	60 °C
Poff	0 W
PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.44 kW
Annual energy consumption Qhe	3362 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	46 dB(A)