

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	HP08L-M-BC	Reg. No.	011-1W0203
Certificate Holder			
Name	Heliotherm GmbH		
Address	Sportplatzweg 18	Zip	A-6336
City	Langkampfen	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	HP08L-M-BC		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	7.4 kg		
Certification Date	14.12.2017		
Testing basis	HP KEYMARK certification scheme rules rev. 8		

Model: HELIOTHERM - Luft-/Wasserwärmepumpe in Splittbauweise modulierend Baureihe Basic Comfort

Configure model	
Model name	HELIOTHERM - Luft-/Wasserwärmepumpe in Splittbauweise modulierend Baureihe Basic Comfort
Application	Heating (low temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2	
	Low temperature
Heat output	10.22 kW
El input	1.92 kW
COP	5.33

Average Climate

EN 14825	
	Low temperature
η_s	185 %
Prated	10.00 kW
SCOP	4.71
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	8.84 kW
COP Tj = -7°C	2.84
Cdh Tj = -7 °C	0.990
Pdh Tj = +2°C	5.50 kW
COP Tj = +2°C	4.78
Cdh Tj = +2 °C	0.990
Pdh Tj = +7°C	5.97 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = +7°C	5.93
Cdh Tj = +7 °C	0.990
Pdh Tj = 12°C	6.74 kW
COP Tj = 12°C	7.38
Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	10.20 kW
COP Tj = Tbiv	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990
WTOL	62 °C
Poff	1 W
PTO	7 W
PSB	7 W
PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	4400 kWh

EN 12102-1

	Low temperature
Sound power level indoor	40 dB(A)
Sound power level outdoor	40 dB(A)

Warmer Climate

EN 14825

	Low temperature
η_s	241 %
Prated	10.00 kW
SCOP	6.10
Tbiv	2 °C
TOL	2 °C
Pdh Tj = +2°C	10.03 kW
COP Tj = +2°C	4.36
Cdh Tj = +2 °C	0.990
Pdh Tj = +7°C	6.45 kW
COP Tj = +7°C	5.96
Cdh Tj = +7 °C	0.990
Pdh Tj = 12°C	4.63 kW
COP Tj = 12°C	6.62

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	10.03 kW
COP Tj = Tbiv	4.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.03 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990
WTOL	62 °C
Poff	1 W
PTO	7 W
PSB	7 W
PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2295 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	40 dB(A)
Sound power level outdoor	40 dB(A)

Colder Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature
η_s	167 %
Prated	10.00 kW
SCOP	4.25
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	6.20 kW
COP Tj = -7°C	3.83
Cdh Tj = -7 °C	0.990
Pdh Tj = +2°C	3.77 kW
COP Tj = +2°C	5.05
Cdh Tj = +2 °C	0.990
Pdh Tj = +7°C	3.90 kW
COP Tj = +7°C	5.59
Cdh Tj = +7 °C	0.990
Pdh Tj = 12°C	4.69 kW
COP Tj = 12°C	6.68
Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	8.91 kW
COP Tj = Tbiv	2.23

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.84 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.38
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990
WTOL	62 °C
Poff	1 W
PTO	7 W
PSB	7 W
PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	2.16 kW
Annual energy consumption Qhe	4941 kWh
Pdh Tj = -15°C (if TOL<-20°C)	8.22
COP Tj = -15°C (if TOL<-20°C)	2.49
Cdh Tj = -15 °C	0.990

EN 12102-1

	Low temperature
Sound power level indoor	40 dB(A)
Sound power level outdoor	40 dB(A)