

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	NEVIS PLUS R32 35 MUD0	Reg. No.	ICIM-PDC-000101
Certificate Holder			
Name	Ariston Thermo Group		
Address	Viale Aristide Merloni 45	Zip	I-60044
City	Fabriano (AN)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	NEVIS PLUS R32 35 MUD0		
Heat Pump Type	Air/Air Single Split		
Refrigerant	R32		
Mass of Refrigerant	0.62 kg		
Certification Date	07.06.2021		
Testing basis	V9		

Model: NEVIS PLUS R32 35 MUD0

Configure model	
Model name	NEVIS PLUS R32 35 MUD0
Application	Heating + Cooling
Climate zone (for heating)	n/a
EN14511-2 certification (heating mode)	Yes

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	A35/A27
Heating capacity	3.81
El input	1.03 kW
COP	3.71

Average Climate

EN 14825	
	Indoor dry bulb temperature: 20°C
P _{designh}	2.50 kW
SCOP	4.60
T _{biv}	-7 °C
TOL	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = -7°C	2.21 kW
COP Tj = -7°C	3.18
Cdh Tj = -7 °C	0.250
Pdh Tj = +2°C	1.35 kW
COP Tj = +2°C	4.58
Cdh Tj = +2 °C	0.250
Pdh Tj = +7°C	0.87 kW
COP Tj = +7°C	5.61
Cdh Tj = +7 °C	0.250
Pdh Tj = 12°C	0.60 kW
COP Tj = 12°C	6.65
Cdh Tj = +12 °C	0.250
Pdh Tj = Tbiv	2.21 kW
COP Tj = Tbiv	3.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52
Poff	1 W
PTO	12 W
PSB	1 W
PCK	0 W
Backup Heater	0.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q _{he}	761 kWh
---	---------

Cooling

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2	
El input	1.03 kW
Cooling capacity	3.50
EER	3.38

EN 12102-1	
Sound power level indoor	53 dB(A)
Sound power level outdoor	61 dB(A)

EN 14825	
-----------------	--

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Indoor dry(wet) bulb temperature 27(19)°C
P _{designc}	3.50 kW
SEER	8.50
P _{dc} T _j = 35°C	3.50 kW
EER T _j = 35°C	3.40
P _{dc} T _j = 30°C	2.34 kW
EER T _j = 30°C	5.90
C _{dc}	0.3
P _{dc} T _j = 25°C	1.51 kW
EER T _j = 25°C	10.71
C _{dc}	0.3
P _{dc} T _j = 20°C	0.90 kW
EER T _j = 20°C	15.00
C _{dc}	0.3
P _{off}	1 W
PTO	12 W
PSB	1 W
PCK	0 W
Annual energy consumption Q _{ce}	144 kWh