

# $$\operatorname{\textit{Page}}\ 1$$ of 3 This information was generated by the HP KEYMARK database on 22 Jun 2022

١.	$\overline{}$	$\sim$	ın	
	u	u		

Summary of	AQUA PLUS SWAN-2 190S	Reg. No.	ICIM-PDC-000030	
Certificate Holder		<u> </u>		
Name	Clivet s.p.a.			
Address	Via camp lonc 25 c.ap.	Zip	I-32032	
City	z.i. Villapaiera - Feltre (BL)	Country	Italy	
Certification Body	ICIM S.p.A.	ICIM S.p.A.		
Subtype title	AQUA PLUS SWAN-2 190S			
Heat Pump Type	Heat Pump for Domestic Hot Wa	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a			
Mass of Refrigerant	1.1 kg			
Certification Date	02.05.2019			
Testing basis	HP KEYMARK certification scheme rules rev. no. 4			



This information was generated by the HP KEYMARK database on 22 Jun 2022

## Model: SWAN-2 190S

Configure model		
Model name	SWAN-2 190S	
Units	Indoor	
Climate zone (for heating)	n/a	
Heat Source	n/a	
Any additional heat sources	n/a	

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



# This information was generated by the HP KEYMARK database on 22 Jun 2022

#### Domestic Hot Water (DHW)

### Average Climate

EN 12102-2	
Sound power level indoor	51 dB(A)

EN 16147		
Declared load profile	L	
Efficiency ηDHW	115 %	
СОР	2.76	
Heating up time	7:01 h:min	
Standby power input	26.3 W	
Reference hot water temperature	53.8 °C	
Mixed water at 40°C	234	

## Operating test

EN 16147		
To any order to a second black and a second black a		
Temperature operating range	passed	
Safety devices checking test	passed	
Condensate draining	passed	