

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Buderus Logatherm WPS 10K-1	Reg. No.	011-1W0179
Certificate Holder			
Name	Bosch Thermotechnik GmbH (Buderus)		
Address	Sophienstraße 30-32	Zip	35576
City	Wetzlar	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WPS 10K-1		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.2 kg		

Model: Buderus Logatherm WPS 10K-1

Configure model

Model name	Buderus Logatherm WPS 10K-1
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	10.15 kW	9.33 kW
El input	2.17 kW	3.22 kW
COP	4.68	2.90

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	11.00 kW	11.00 kW
SCOP	4.95	3.60
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.90 kW	9.30 kW
COP Tj = -7°C	4.74	3.09
Pdh Tj = +2°C	10.00 kW	9.50 kW
COP Tj = +2°C	4.95	3.55
Pdh Tj = +7°C	10.00 kW	9.60 kW
COP Tj = +7°C	5.14	3.98
Pdh Tj = 12°C	10.10 kW	9.80 kW
COP Tj = 12°C	5.34	4.41
Pdh Tj = Tbiv	9.90 kW	9.20 kW
COP Tj = Tbiv	4.63	2.88

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	9.90 kW	9.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.63	2.88
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Q_{he}	4672 kWh	6022 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
COP	2.08
Heating up time	01:05 h:min
Standby power input	66.0 W
Reference hot water temperature	49.6 °C
Mixed water at 40°C	220 l
Efficiency η_{DHW}	89 %