This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Daikin Altherma LT split integrated solar 11 kW 3ph / ROTEX HPSU Compact (BIV) 11 kW 3ph	Reg. No.	011-1W0102

Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	CETIAT		
Subtype title	Daikin Altherma LT split integrated solar 11 kW 3ph / ROTEX HPSU Compact (BIV) 11 kW 3ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3.4 kg		
Certification Date	21.03.2017		

Model: ERLQ011C*W1 / EHSX16P50B

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.80 kW	10.21 kW
El input	2.69 kW	3.97 kW
COP	4.38	2.57
Indoor water flow rate	2.03 m³/h	1.25 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	156 %	128 %
Prated	11.20 kW	10.00 kW
SCOP	3.98	3.29
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.88 kW	9.00 kW
COP Tj = -7°C	2.63	1.94
Cdh	1.00	1.00
Pdh Tj = +2°C	6.03 kW	5.40 kW
COP Tj = +2°C	4.05	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.60 kW
COP Tj = +7°C	6.77	4.26
Cdh	0.94	0.90

Pdh Tj = 12°C	6.50 kW	5.50 kW
COP Tj = 12°C	8.97	6.30
Cdh	0.92	0.90
Pdh Tj = Tbiv	9.09 kW	9.00 kW
COP Tj = Tbiv	2.82	1.94
Pdh Tj = TOL	8.76 kW	9.10 kW
COP Tj = TOL	2.34	1.78
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5380 kWh	6345 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	83 %
COP	2.11
Heating up time	1:20 h:min
Standby power input	67.4 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: RRLQ011C*W1 / HPSU Compact 516

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.80 kW	10.21 kW
El input	2.69 kW	3.97 kW
COP	4.38	2.57
Indoor water flow rate	2.03 m³/h	1.25 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	156 %	128 %
Prated	11.20 kW	10.00 kW
SCOP	3.98	3.29
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.88 kW	9.00 kW
COP Tj = -7°C	2.63	1.94
Cdh	1.00	1.00
Pdh Tj = +2°C	6.03 kW	5.40 kW
COP Tj = +2°C	4.05	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.60 kW
COP Tj = +7°C	6.77	4.26
Cdh	0.94	0.90

Pdh Tj = 12°C	6.50 kW	5.50 kW
COP Tj = 12°C	8.97	6.30
Cdh	0.92	0.90
Pdh Tj = Tbiv	9.09 kW	9.00 kW
COP Tj = Tbiv	2.82	1.94
Pdh Tj = TOL	8.76 kW	9.10 kW
COP Tj = TOL	2.34	1.78
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5380 kWh	6345 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	83 %
COP	2.11
Heating up time	1:20 h:min
Standby power input	67.4 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERLQ011C*W1 / EHSXB16P50B

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.80 kW	10.21 kW
El input	2.69 kW	3.97 kW
COP	4.38	2.57
Indoor water flow rate	2.03 m³/h	1.25 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	128 %
Prated	11.20 kW	10.00 kW
SCOP	3.98	3.29
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.88 kW	9.00 kW
COP Tj = -7°C	2.63	1.94
Cdh	1.00	1.00
Pdh Tj = +2°C	6.03 kW	5.40 kW
COP Tj = +2°C	4.05	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.60 kW
COP Tj = +7°C	6.77	4.26
Cdh	0.94	0.90

Pdh Tj = 12°C	6.50 kW	5.50 kW
COP Tj = 12°C	8.97	6.30
Cdh	0.92	0.90
Pdh Tj = Tbiv	9.09 kW	9.00 kW
COP Tj = Tbiv	2.82	1.94
Pdh Tj = TOL	8.76 kW	9.10 kW
COP Tj = TOL	2.34	1.78
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5380 kWh	6345 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	84 %
COP	2.14
Heating up time	1:20 h:min
Standby power input	66.1 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

Model: RRLQ011C*W1 / HPSU Compact 516 Biv

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.80 kW	10.21 kW
El input	2.69 kW	3.97 kW
COP	4.38	2.57
Indoor water flow rate	2.03 m³/h	1.25 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	128 %
Prated	11.20 kW	10.00 kW
SCOP	3.98	3.29
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.88 kW	9.00 kW
COP Tj = -7°C	2.63	1.94
Cdh	1.00	1.00
Pdh Tj = +2°C	6.03 kW	5.40 kW
COP Tj = +2°C	4.05	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.74 kW	4.60 kW
COP Tj = +7°C	6.77	4.26
Cdh	0.94	0.90

Pdh Tj = 12°C	6.50 kW	5.50 kW
COP Tj = 12°C	8.97	6.30
Cdh	0.92	0.90
Pdh Tj = Tbiv	9.09 kW	9.00 kW
COP Tj = Tbiv	2.82	1.94
Pdh Tj = TOL	8.76 kW	9.10 kW
COP Tj = TOL	2.34	1.78
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5380 kWh	6345 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	84 %
COP	2.14
Heating up time	1:20 h:min
Standby power input	66.1 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l