Login

Summary of	TTF 4.6, TTF 6.6, TTF 8.6	Reg. No.	011-1W0396
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTF 4.6, TTF 6.6, TTF 8.6		
Heat Pump Type	Brine/Water		
Refrigerant	R454C		
Mass of Refrigerant	2.2 kg		
Certification Date	08.09.2020		

Model: TTF 4.6 (cool) / TTC 4.6 (cool)

Configure model	
Model name	TTF 4.6 (cool) / TTC 4.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	1.96 kW	1.26 kW
El input	0.43 kW	0.47 kW
COP	4.60	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	187 %	147 %
Prated	4.23 kW	3.76 kW
SCOP	4.87	3.87
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.23 kW	3.76 kW
COP Tj = +2°C	4.86	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.71 kW	2.41 kW
COP Tj = +7°C	5.24	3.95
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.20 kW	1.08 kW
COP Tj = 12°C	5.31	4.39
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW

COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1159 kWh	1300 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	201 %	157 %
Prated	4.23 kW	3.76 kW

SCOP	5.21	4.12
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.55 kW	2.27 kW
COP Tj = -7°C	5.37	4.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	1.55 kW	1.38 kW
COP Tj = +2°C	5.45	4.37
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.13 kW	1.09 kW
COP Tj = +7°C	5.31	4.51
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.12 kW	1.09 kW
COP Tj = 12°C	5.21	4.52
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W

PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2000 kWh	2252 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	195 %	153 %
Prated	4.23 kW	3.76 kW
SCOP	5.07	4.02
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.73 kW	3.32 kW
COP Tj = -7°C	5.01	3.58

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.26 kW	2.02 kW
COP Tj = +2°C	5.38	4.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.45 kW	1.30 kW
COP Tj = +7°C	5.34	4.47
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.08 kW
COP Tj = 12°C	5.32	4.49
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1723 kWh	1934 kWh

Model: TTF 6.6 (cool) / TTC 6.6 (cool)

Configure model	
Model name	TTF 6.6 (cool) / TTC 6.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.37 kW	2.01 kW
El input	0.52 kW	0.69 kW
COP	4.60	2.91

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	198 %	158 %
Prated	6.70 kW	6.05 kW
SCOP	5.14	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.70 kW	6.05 kW
COP Tj = +2°C	4.52	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.29 kW	3.88 kW
COP Tj = +7°C	5.19	3.97
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.90 kW	1.72 kW
COP Tj = 12°C	5.71	4.81
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW

COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1741 kWh	1954 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	207 %	166 %
Prated	6.70 kW	6.05 kW

SCOP	5.38	4.34
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.04 kW	3.65 kW
COP Tj = -7°C	5.36	4.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.45 kW	2.22 kW
COP Tj = +2°C	5.64	4.68
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.57 kW	1.42 kW
COP Tj = +7°C	5.76	4.80
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.10 kW
COP Tj = 12°C	5.32	4.73
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W

PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3069 kWh	3439 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	200 %	160 %
Prated	6.70 kW	6.05 kW
SCOP	5.20	4.18
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.91 kW	5.34 kW
COP Tj = -7°C	4.71	3.55

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.59 kW	3.25 kW
COP Tj = +2°C	5.39	4.27
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.30 kW	2.09 kW
COP Tj = +7°C	5.60	4.76
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.14 kW	1.08 kW
COP Tj = 12°C	5.47	4.61
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	2662 kWh	2988 kWh

Model: TTF 8.6 (cool) / TTC 8.6 (cool)

Configure model	
Model name	TTF 8.6 (cool) / TTC 8.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.78 kW	2.42 kW
El input	0.60 kW	0.79 kW
COP	4.67	3.07

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	197 %	157 %
Prated	7.66 kW	6.93 kW
SCOP	5.13	4.13
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.66 kW	6.93 kW
COP Tj = +2°C	4.29	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.91 kW	4.45 kW
COP Tj = +7°C	5.09	3.88
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.17 kW	1.97 kW
COP Tj = 12°C	5.75	4.85
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW

COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1997 kWh	2243 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	163 %
Prated	7.66 kW	6.93 kW

SCOP	5.29	4.29
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.62 kW	4.18 kW
COP Tj = -7°C	5.17	4.07
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.81 kW	2.54 kW
COP Tj = +2°C	5.60	4.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.80 kW	1.63 kW
COP Tj = +7°C	5.76	4.90
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.09 kW
COP Tj = 12°C	5.34	4.75
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W

PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3570 kWh	3985 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	197 %	158 %
Prated	7.66 kW	6.93 kW
SCOP	5.12	4.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.76 kW	6.12 kW
COP Tj = -7°C	4.53	3.44

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.11 kW	3.72 kW
COP Tj = +2°C	5.25	4.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.64 kW	2.39 kW
COP Tj = +7°C	5.59	4.69
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.16 kW	1.08 kW
COP Tj = 12°C	5.52	4.61
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	3094 kWh	3461 kWh