

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 23 Jun 2022

#### **Login**

Summary of	WPL 20 A	Reg. No.	011-1W0071	
Certificate Holder		<u> </u>		
Name	STIEBEL ELTRON GmbH & Co	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPL 20 A	WPL 20 A		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R410A	R410A		
Mass of Refrigerant	4.7 kg	4.7 kg		
Certification Date	15.02.2017	15.02.2017		



## Model: WPL 20 A

Configure model		
Model name	WPL 20 A	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

### Heating

EN 14511-2				
Low temperature Medium temperature				
Heat output	7.84 kW	7.36 kW		
El input	1.54 kW	2.33 kW		
СОР	5.09	3.16		

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shutting on the heat transfer medium now	passeu
Complete power supply failure	passed
Starting and operating test	passed

#### Average Climate



This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
Low temperature Medium temperature			
Sound power level outdoor	54 dB(A)	54 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	185 %	143 %
Prated	11.00 kW	12.00 kW
SCOP	4.70	3.65
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.48 kW	0.69 kW
Annual energy consumption Qhe	4839 kWh	6801 kWh

#### Warmer Climate

EN 14825		
	Low temperature	Medium temperature
ης	214 %	163 %
Prated	7.00 kW	8.00 kW
SCOP	5.44	4.14





<u> </u>		
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.14	2.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.90 kW	7.50 kW
$COPTj = +7^{\circ}C$	5.47	3.64
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.45
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity





This information was genera	ted by the HP KEYMAI	RK database on 23 Jun 2022	2
ementary Heater: PSIIP	0 00 kW	0 00 kW	

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1720 kWh	2581 kWh

#### Colder Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	165 %	132 %
Prated	15.00 kW	17.00 kW
SCOP	4.20	3.38
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# Page 7 of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

	<u> </u>	
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8804 kWh	12405 kWh
Pdh Tj = -15°C (if TOL<-20°C)	11.80	12.60
COP Tj = -15°C (if TOL<-20°C)	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90
t control of the cont	The state of the s	