

Page 1 of 8

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	TTF 20	Reg. No.	011-1W0279		
Certificate Holder	Certificate Holder				
Name	tecalor GmbH	tecalor GmbH			
Address	Fürstenbergerstr. 77	Zip	37603		
City	Holzminden	Country	Germany		
Certification Body	DIN CERTCO Gesellschaft für I	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	TTF 20				
Heat Pump Type	Brine/Water				
Refrigerant	R410A	R410A			
Mass of Refrigerant	5.99 kg				



Model: TTF 20

Configure model		
Model name TTF 20		
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional) n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

COP

EN 14511-2				
Low temperature Medium temperature				
Heat output	21.50 kW	20.10 kW		
El input	4.61 kW	7.08 kW		

3.16

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

Average Climate

4.66



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	54 dB(A)	54 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	192 %	131 %	
Prated	22.00 kW	20.00 kW	
SCOP	5.00	3.48	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	21.50 kW	20.20 kW	
COP Tj = -7°C	4.72	2.96	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	21.70 kW	20.70 kW	
COP Tj = +2°C	5.06	3.48	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	21.80 kW	21.00 kW	
COP Tj = +7°C	5.41	3.88	
Cdh Tj = +7 °C	0.90	0.90	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 8 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	22.00 kW	21.30 kW
COP Tj = 12°C	5.80	4.36
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	21.50 kW	20.10 kW
COP Tj = Tbiv	4.66	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	20.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	o w	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	8904 kWh	11988 kWh

Warmer Climate




This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	54 dB(A)	54 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	188 %	128 %	
Prated	22.00 kW	20.00 kW	
SCOP	4.90	3.40	
Tbiv	2 °C	2 °C	
TOL	2 °C	2 °C	
Pdh Tj = +2°C	21.50 kW	20.10 kW	
$COP Tj = +2^{\circ}C$	4.66	2.84	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = $+7^{\circ}$ C	21.70 kW	20.50 kW	
$COPTj = +7^{\circ}C$	4.99	3.24	
Cdh Tj = +7 °C	0.90	0.90	
Pdh Tj = 12°C	21.90 kW	21.10 kW	
COP Tj = 12°C	5.54	4.03	
Cdh Tj = +12 °C	0.90	0.90	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = Tbiv21.50 kW 20.10 kW COP Tj = Tbiv 4.66 2.84 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 21.50 kW 20.10 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 4.66 2.84 Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 0.90 0.90 WTOL 60 °C 60 °C 0 W 0 W Poff PTO 7 W 7 W **PSB** 7 W 7 W **PCK** 74 W 74 W

Electricity

0.00 kW

5871 kWh

Electricity

0.00 kW

7884 kWh

Colder Climate

Supplementary Heater: PSUP

Annual energy consumption Qhe

Supplementary Heater: Type of energy input

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	54 dB(A)	54 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	

EN 14825



Page 7 of 8 This information was generated by the HP KEYMARK database on 18 Mar 2022

This information was general	Low temperature	Medium temperature
η_{S}	201 %	137 %
Prated	27.00 kW	25.00 kW
SCOP	5.23	3.63
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7° C	21.80 kW	20.70 kW
COP Tj = -7° C	5.24	3.46
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = $+2$ °C	21.90 kW	21.00 kW
$COP Tj = +2^{\circ}C$	5.51	3.87
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	21.90 kW	21.30 kW
$COP Tj = +7^{\circ}C$	5.74	4.26
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	22.00 kW	21.50 kW
COP Tj = 12°C	5.78	4.60
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	21.70 kW	20.50 kW
COP Tj = Tbiv	5.12	3.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	21.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 8 of 8 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	o w	o w
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	5.05 kW
Annual energy consumption Qhe	12535 kWh	17067 kWh
Pdh Tj = -15°C (if TOL<-20°C)	21.50	21.10
COP Tj = -15°C (if TOL $<$ -20°C)	4.66	2.84
Cdh Tj = -15 °C	0.90	0.90