

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Austria Email LWP 6 A.I.	Reg. No.	012-C700016
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	Cetiat		
Subtype title	Austria Email LWP 6 A.I.		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	0.97 kg		
Certification Date	04.03.2020		
Testing basis	HP Keymark Scheme Rules rev 7		

Model: Austria Email LWP 6 A.I.

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67
Indoor water flow rate	0.43 m ³ /h	0.51 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	125 %
Prated	6.00 kW	5.00 kW
SCOP	4.46	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.70 kW
COP Tj = -7°C	2.74	1.97
Cdh	0.96	0.97
Pdh Tj = +2°C	3.00 kW	2.90 kW
COP Tj = +2°C	4.68	3.11
Cdh	0.96	0.97
Pdh Tj = +7°C	2.10 kW	1.80 kW
COP Tj = +7°C	6.04	4.29
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	7.43	6.06
Cdh	0.96	0.97
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL	4.50 kW	4.00 kW
COP Tj = TOL	2.67	1.73
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh

Model: Austria Email LWPK 6 A.I.

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67
Indoor water flow rate	0.43 m ³ /h	0.51 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	125 %
Prated	6.00 kW	5.00 kW
SCOP	4.46	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.70 kW
COP Tj = -7°C	2.74	1.97
Cdh	0.96	0.97
Pdh Tj = +2°C	3.00 kW	2.90 kW
COP Tj = +2°C	4.68	3.11
Cdh	0.96	0.97
Pdh Tj = +7°C	2.10 kW	1.80 kW
COP Tj = +7°C	6.04	4.29
Cdh	0.96	0.97

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	7.43	6.06
Cdh	0.96	0.97
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL	4.50 kW	4.00 kW
COP Tj = TOL	2.67	1.73
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.10
Heating up time	1:35 h:min
Standby power input	30.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	245 l