

Page 1 of 8

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	CHA-07/400V	Reg. No.	011-1W380	
Certificate Holder				
Name	WOLF GmbH			
Address	Industriestr. 1	Zip	84048	
City	Mainburg	Country	Germany	
Certification Body	DIN CERTCO Gesellscha	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	CHA-07/400V	CHA-07/400V		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R290	R290		
Mass of Refrigerant	3.1 kg	3.1 kg		
Certification Date	30.06.2020	30.06.2020		



Model: CHA-07/400V

Configure model			
Model name	CHA-07/400V		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	Colder Climate + Warmer Climate		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2				
Low temperature Medium temperature				
Heat output	4.50 kW	4.45 kW		
El input	0.82 kW	1.39 kW		
СОР	5.47	3.10		

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1			
Low temperature Medium temperature			
Sound power level outdoor	52 dB(A)	52 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	194 %	148 %
Prated	5.59 kW	5.93 kW
SCOP	4.92	3.77
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.29 kW	5.62 kW
COP Tj = -7°C	2.95	2.22
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.20 kW	3.46 kW
COP Tj = +2°C	5.08	3.68
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.29 kW	2.25 kW
$COP Tj = +7^{\circ}C$	6.27	5.11
Cdh Tj = +7 °C	0.96	0.90
Pdh Tj = 12°C	2.33 kW	2.60 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C6.85 6.43 Cdh Tj = +12 °C 0.96 0.96 Pdh Tj = Tbiv5.59 kW 5.93 kW COP Tj = Tbiv2.55 1.86 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 5.59 kW 5.93 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.55 1.86 WTOL 35 °C 55 °C Poff 13 W 13 W PTO 15 W 15 W **PSB** 15 W 15 W **PCK** 0 W 0 W

Warmer Climate

Supplementary Heater: PSUP

Annual energy consumption Qhe

Supplementary Heater: Type of energy input

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	52 dB(A)	52 dB(A)	

Electricity

0.00 kW

2346 kWh

Electricity

0.00 kW

3249 kWh

EN 14825		
	Low temperature	Medium temperature





		THE THE PARTY OF T
η_{s}	249 %	179 %
Prated	5.70 kW	5.89 kW
SCOP	6.30	4.54
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = $+2$ °C	5.70 kW	5.89 kW
$COP Tj = +2^{\circ}C$	3.85	2.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.84 kW	4.02 kW
$COP Tj = +7^{\circ}C$	6.16	3.98
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.32 kW	2.29 kW
COP Tj = 12°C	7.17	5.77
Cdh Tj = +12 °C	0.95	0.96
Pdh Tj = Tbiv	5.70 kW	5.89 kW
COP Tj = Tbiv	3.85	2.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	5.70 kW	5.89 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.85	2.43
WTOL	35 °C	55 °C
Poff	13 W	13 W





PTO	15 W	15 W
PSB	15 W	15 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1208 kWh	4215 kWh

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	52 dB(A)	52 dB(A)	

EN 14825			
	Low temperatu	re Medium temperature	
η_{s}	174 %	127 %	
Prated	6.16 kW	5.57 kW	
SCOP	4.43	3.26	
Tbiv	-17 °C	-17 °C	
TOL	-22 °C	-22 °C	
Pdh Tj = -7°C	3.71 kW	3.70 kW	
COP Tj = -7°C	3.85	2.69	





Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.25 kW	2.25 kW
COP Tj = +2°C	5.28	3.95
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	2.33 kW	2.29 kW
$COPTj = +7^{\circ}C$	6.52	5.27
Cdh Tj = +7 °C	0.96	0.97
Pdh Tj = 12°C	2.27 kW	2.41 kW
COP Tj = 12°C	6.83	6.27
Cdh Tj = +12 °C	0.95	0.96
Pdh Tj = Tbiv	5.35 kW	4.84 kW
COP Tj = Tbiv	2.45	1.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.55 kW	4.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.09	1.28
WTOL	35 °C	55 °C
Poff	13 W	13 W
РТО	15 W	15 W
PSB	15 W	15 W
РСК	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.61 kW	1.48 kW



Annual energy consumption Qhe	3428 kWh	4215 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.78	4.99
COP Tj = -15°C (if TOL $<$ -20°C)	2.74	1.99
Cdh Tj = -15 °C	0.90	0.90