Login

Summary of	AQUATOP S14	Reg. No.	011-1W0307
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AQUATOP S14		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.4 kg		
Certification Date	04.05.2019		

Model: AQUATOP S14

Configure model	
Model name	AQUATOP S14
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	13.47 kW	11.99 kW
El input	2.73 kW	4.27 kW
COP	4.94	2.80

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	198 %	158 %
Prated	13.00 kW	12.00 kW
SCOP	5.15	4.15
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	13.40 kW	11.92 kW
COP Tj = +2°C	4.65	2.79
Pdh Tj = +7°C	13.93 kW	12.99 kW
COP Tj = +7°C	5.20	3.62
Pdh Tj = 12°C	14.07 kW	14.42 kW
COP Tj = 12°C	5.34	5.13
Pdh Tj = Tbiv	13.40 kW	11.92 kW
COP Tj = Tbiv	4.65	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.40 kW	11.92 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.65	2.79

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	3478 kWh	3834 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	201 %	162 %
Prated	13.00 kW	12.00 kW
SCOP	5.23	4.26
Tbiv	-22 °C	-22 °C

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	14.07 kW	13.11 kW
COP Tj = -7°C	5.34	3.85
Pdh Tj = +2°C	14.07 kW	14.06 kW
COP Tj = +2°C	5.34	4.71
Pdh Tj = +7°C	14.07 kW	14.66 kW
COP Tj = +7°C	5.34	5.41
Pdh Tj = 12°C	14.07 kW	14.90 kW
COP Tj = 12°C	5.34	5.71
Pdh Tj = Tbiv	13.40 kW	11.92 kW
COP Tj = Tbiv	4.65	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.40 kW	11.92 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.65	2.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW

Annual energy consumption Qhe	6318 kWh	6899 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	199 %	157 %
Prated	13.00 kW	12.00 kW
SCOP	5.18	2.00
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.52 kW	12.27 kW
COP Tj = -7°C	4.78	3.04
Pdh Tj = +2°C	14.07 kW	13.35 kW
COP Tj = +2°C	5.34	4.10
Pdh Tj = +7°C	14.07 kW	14.18 kW
COP Tj = +7°C	5.34	4.85
Pdh Tj = 12°C	14.07 kW	14.90 kW

COP Tj = 12°C	5.34	5.71
Pdh Tj = Tbiv	13.40 kW	11.92 kW
COP Tj = Tbiv	4.65	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.40 kW	11.92 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.65	2.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5348 kWh	5981 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	17.06 kW	15.52 kW
El input	2.81 kW	4.22 kW
COP	6.07	3.68

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	260 %	211 %
Prated	17.00 kW	16.00 kW

SCOP	6.71	5.47
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	17.06 kW	15.52 kW
COP Tj = +2°C	6.07	3.68
Pdh Tj = +7°C	17.73 kW	16.91 kW
COP Tj = +7°C	6.79	4.77
Pdh Tj = 12°C	17.91 kW	18.78 kW
COP Tj = 12°C	6.97	6.77
Pdh Tj = Tbiv	17.06 kW	15.52 kW
COP Tj = Tbiv	6.07	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.06 kW	15.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	6.07	3.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW

Annual energy consumption Qhe	3397 kWh	3788 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	265 %	217 %
Prated	17.00 kW	16.00 kW
SCOP	6.82	5.62
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	17.91 kW	17.07 kW
COP Tj = -7°C	6.97	5.08
Pdh Tj = +2°C	17.91 kW	18.31 kW
COP Tj = +2°C	6.97	6.21
Pdh Tj = +7°C	17.91 kW	19.09 kW
COP Tj = +7°C	6.97	7.14
Pdh Tj = 12°C	17.91 kW	19.40 kW

COP Tj = 12°C	6.97	7.53
Pdh Tj = Tbiv	17.06 kW	15.52 kW
COP Tj = Tbiv	6.07	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.06 kW	15.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	6.07	3.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	6162 kWh	6804 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	262 %	209 %
Prated	17.00 kW	16.00 kW
SCOP	6.75	5.43
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	17.21 kW	15.98 kW
COP Tj = -7°C	6.24	4.01
Pdh Tj = +2°C	17.91 kW	17.38 kW
COP Tj = +2°C	6.97	5.41
Pdh Tj = +7°C	17.91 kW	18.46 kW
COP Tj = +7°C	6.97	6.40
Pdh Tj = 12°C	17.91 kW	19.40 kW
COP Tj = 12°C	6.97	7.53
Pdh Tj = Tbiv	17.06 kW	15.52 kW
COP Tj = Tbiv	6.07	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.06 kW	15.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	6.07	3.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W

PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5221 kWh	5901 kWh