

Page 1 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	LWC 100	Reg. No.	041-K001-29	
Certificate Holder				
Name	ait-deutschland GmbH			
Address	Industriestr. 3	Zip	95359	
City	Kasendorf	Country	Germany	
Certification Body	BRE Global Limited	BRE Global Limited		
Subtype title	LWC 100	LWC 100		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R404A	R404A		
Mass of Refrigerant	4.1 kg	4.1 kg		
Certification Date	06.09.2019	06.09.2019		



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: LWC 100

Configure model		
Model name	LWC 100	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Starting and operating test	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	12.20 kW	11.20 kW	
El input	2.98 kW	5.01 kW	
СОР	4.10	2.20	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	55 dB(A)	55 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	146 %	116 %
Prated	11.89 kW	11.19 kW
SCOP	3.73	2.97
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.43 kW	7.83 kW
COP Tj = -7°C	2.86	2.01
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	10.51 kW	10.17 kW
COP Tj = +2°C	3.77	2.93
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	12.41 kW	12.15 kW
COP Tj = +7°C	4.63	3.93
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	14.06 kW	14.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 18 Mar		
COP Tj = 12°C	5.03	4.88
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.14 kW	8.61 kW
COP Tj = Tbiv	3.19	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.69 kW	7.17 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.79
WTOL	58 °C	58 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.20 kW	4.02 kW

Warmer Climate

Annual energy consumption Qhe

EN 14825		
Low temperature	Medium temperature	
175 %	137 %	
13.05 kW	12.23 kW	
4.45	3.51	
	175 % 13.05 kW	

6587 kWh

7791 kWh



Page 5 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

This information was genera	The The The Television	KK database on 18 Mar 202
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = $+2$ °C	10.40 kW	9.73 kW
$COP Tj = +2^{\circ}C$	3.47	2.25
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	12.31 kW	11.69 kW
$COPTj = +7^{\circ}C$	4.35	3.07
Cdh Tj = $+7$ °C	1.00	1.00
Pdh Tj = 12°C	13.99 kW	13.76 kW
COP Tj = 12°C	4.92	4.43
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.18 kW	10.49 kW
COP Tj = Tbiv	3.87	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.40 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.47	2.25
WTOL	58 °C	58 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity





This information was general	ted by the HP KEYMAR	ik database on 18 Mar 2022	
plementary Heater: PSUP	2.65 kW	2.50 kW	

Supplementary Heater: PSUP	2.65 kW	2.50 kW
Annual energy consumption Qhe	3920 kWh	4652 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	131 %	107 %
Prated	9.21 kW	8.82 kW
SCOP	3.34	2.74
Tbiv	-13 °C	-13 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	8.53 kW	8.10 kW
COP Tj = -7°C	3.04	2.32
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	10.57 kW	10.33 kW
COP Tj = +2°C	3.94	3.28
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	12.47 kW	12.34 kW
COP Tj = +7°C	4.75	4.36
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	14.04 kW	14.12 kW



 $$\operatorname{\textsc{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

	· · · · · · · · · · · · · · · · · · ·	
COP Tj = 12°C	4.86	5.04
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.03 kW	6.73 kW
COP Tj = Tbiv	2.54	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.31 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.89	1.42
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	9.21 kW	8.82 kW
Annual energy consumption Qhe	6791 kWh	7942 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.53	6.30
COP Tj = -15°C (if TOL $<$ -20°C)	2.35	1.73
Cdh Tj = -15 °C	1.00	1.00
1	T. Control of the Con	1