

This information was generated by the HP KEYMARK database on 27 Jan 2021

Summary of	AquaMaster Inverter AQ22I	Reg. No.	037-0062-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	AquaMaster Inverter AQ22I		
Heat Pump Type	Brine/Water		
Refrigerant	R32		
Mass Of Refrigerant	1 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		

## Model: AquaMaster Inverter AQ22I

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.18 kW	3.81 kW
El input	0.90 kW	1.32 kW
COP	4.66	2.89
Indoor water flow rate	0.72 m <sup>3</sup> /h	0.41 m <sup>3</sup> /h

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 27 Jan 2021

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	208 %	152 %
Prated	7.08 kW	5.91 kW
SCOP	5.39	4.01
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.39 kW	5.27 kW
COP Tj = -7°C	4.12	2.96
Cdh	0.90	0.90
Pdh Tj = +2°C	3.54 kW	3.37 kW
COP Tj = +2°C	5.51	4.02
Cdh	0.90	0.90
Pdh Tj = +7°C	2.45 kW	2.12 kW
COP Tj = +7°C	6.28	4.87
Cdh	0.90	0.90
Pdh Tj = 12°C	1.16 kW	1.07 kW

This information was generated by the HP KEYMARK database on 27 Jan 2021

COP Tj = 12°C	6.37	5.02
Cdh	0.90	0.94
Pdh Tj = Tbiv	7.08 kW	5.91 kW
COP Tj = Tbiv	4.00	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.08 kW	5.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.00	2.67
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2713 kWh	3051 kWh