Login

Summary of	Vitocal 2xx-G M B06	Reg. No.	011-1W0288
Certificate Holder			
Name	Viessmann Wärmepumpen GmbH		
Address	Viessmannstr. 1	Zip	35107
City	Allendorf/Eder	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Vitocal 2xx-G M B06		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.4 kg		
Certification Date	11.07.2019		

Model: VITOCAL 200-G BWC-M 201.B06

Configure model	
Model name	VITOCAL 200-G BWC-M 201.B06
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.79 kW	5.19 kW
El input	1.34 kW	2.07 kW
COP	4.31	2.51

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	130 %
Prated	5.59 kW	5.22 kW
SCOP	5.16	3.46
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.59 kW	5.22 kW
COP Tj = +2°C	4.69	2.80
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.60 kW	5.15 kW
COP Tj = +7°C	4.93	3.17
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.68 kW	5.48 kW
COP Tj = 12°C	5.43	3.96
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.59 kW	5.22 kW

COP Tj = Tbiv	4.69	2.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.59 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.69	2.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1447 kWh	2014 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	183 %	132 %

Prated	9.15 kW	8.41 kW
SCOP	4.79	3.51
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.60 kW	5.17 kW
COP Tj = -7°C	5.32	3.46
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.65 kW	5.39 kW
COP Tj = +2°C	5.63	4.00
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.67 kW	5.46 kW
COP Tj = +7°C	5.85	4.43
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.71 kW	5.49 kW
COP Tj = 12°C	5.95	4.80
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.60 kW	5.17 kW
COP Tj = Tbiv	5.32	3.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99

WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.62 kW	3.18 kW
Annual energy consumption Qhe	4713 kWh	5907 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.82	5.23
COP Tj = -15°C (if TOL<-20°C)	4.85	2.91
Cdh Tj = -15 °C	0.99	0.99

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	**Medium temperature**
Pdesignh	6.37 kW		
η_s	201 %	133 %	

Prated	6.37 kW	5.75 kW
SCOP	5.23	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.61 kW	5.06 kW
COP Tj = -7°C	4.92	2.95
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.66 kW	5.12 kW
COP Tj = +2°C	5.26	3.50
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.69 kW	5.27 kW
COP Tj = +7°C	5.54	3.91
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.72 kW	5.37 kW
COP Tj = 12°C	5.86	4.41
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	5.06 kW
COP Tj = Tbiv	4.92	2.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.85

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.77 kW	0.59 kW
Backup Heater	0.00 kW	
Annual energy consumption Qhe	2516 kWh	3378 kWh

Model: VITOCAL 222-G BWT-M 221.B06

Configure model	
Model name	VITOCAL 222-G BWT-M 221.B06
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	Yes

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.79 kW	5.19 kW
El input	1.34 kW	2.07 kW
COP	4.31	2.51

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	130 %
Prated	5.59 kW	5.22 kW
SCOP	5.16	3.46
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.59 kW	5.22 kW
COP Tj = +2°C	4.69	2.80
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.60 kW	5.15 kW
COP Tj = +7°C	4.93	3.17
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.68 kW	5.48 kW
COP Tj = 12°C	5.43	3.96
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.59 kW	5.22 kW

COP Tj = Tbiv	4.69	2.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.59 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.69	2.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1447 kWh	2014 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	183 %	132 %

Prated	9.15 kW	8.41 kW
SCOP	4.79	3.51
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.60 kW	5.17 kW
COP Tj = -7°C	5.32	3.46
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.65 kW	5.39 kW
COP Tj = +2°C	5.63	4.00
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.67 kW	5.46 kW
COP Tj = +7°C	5.85	4.43
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.71 kW	5.49 kW
COP Tj = 12°C	5.95	4.80
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.60 kW	5.17 kW
COP Tj = Tbiv	5.32	3.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99

WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.62 kW	3.18 kW
Annual energy consumption Qhe	4713 kWh	5907 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.82	5.23
COP Tj = -15°C (if TOL<-20°C)	4.85	2.91
Cdh Tj = -15 °C	0.99	0.99

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	**Medium temperature**
Pdesignh	6.37 kW		
η_s	201 %	133 %	

Prated	6.37 kW	5.75 kW
SCOP	5.23	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.61 kW	5.06 kW
COP Tj = -7°C	4.92	2.95
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.66 kW	5.12 kW
COP Tj = +2°C	5.26	3.50
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.69 kW	5.27 kW
COP Tj = +7°C	5.54	3.91
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.72 kW	5.37 kW
COP Tj = 12°C	5.86	4.41
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	5.06 kW
COP Tj = Tbiv	4.92	2.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.85

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.77 kW	0.59 kW
Backup Heater	0.00 kW	
Annual energy consumption Qhe	2516 kWh	3378 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l

Model: VITOCAL 222-G BWT-M 221.B06 SC

Configure model	
Model name	VITOCAL 222-G BWT-M 221.B06 SC
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	Yes

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.79 kW	5.19 kW
El input	1.34 kW	2.07 kW
COP	4.31	2.51

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	130 %
Prated	5.59 kW	5.22 kW
SCOP	5.16	3.46
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.59 kW	5.22 kW
COP Tj = +2°C	4.69	2.80
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.60 kW	5.15 kW
COP Tj = +7°C	4.93	3.17
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.68 kW	5.48 kW
COP Tj = 12°C	5.43	3.96
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.59 kW	5.22 kW

COP Tj = Tbiv	4.69	2.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.59 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.69	2.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1447 kWh	2014 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	183 %	132 %

Prated	9.15 kW	8.41 kW
SCOP	4.79	3.51
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.60 kW	5.17 kW
COP Tj = -7°C	5.32	3.46
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.65 kW	5.39 kW
COP Tj = +2°C	5.63	4.00
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.67 kW	5.46 kW
COP Tj = +7°C	5.85	4.43
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.71 kW	5.49 kW
COP Tj = 12°C	5.95	4.80
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.60 kW	5.17 kW
COP Tj = Tbiv	5.32	3.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99

WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.62 kW	3.18 kW
Annual energy consumption Qhe	4713 kWh	5907 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.82	5.23
COP Tj = -15°C (if TOL<-20°C)	4.85	2.91
Cdh Tj = -15 °C	0.99	0.99

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	**Medium temperature**
Pdesignh	6.37 kW		
η_s	201 %	133 %	

Prated	6.37 kW	5.75 kW
SCOP	5.23	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.61 kW	5.06 kW
COP Tj = -7°C	4.92	2.95
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.66 kW	5.12 kW
COP Tj = +2°C	5.26	3.50
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.69 kW	5.27 kW
COP Tj = +7°C	5.54	3.91
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.72 kW	5.37 kW
COP Tj = 12°C	5.86	4.41
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	5.06 kW
COP Tj = Tbiv	4.92	2.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.85

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.77 kW	0.59 kW
Backup Heater	0.00 kW	
Annual energy consumption Qhe	2516 kWh	3378 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	130 %
COP	3.05
Heating up time	2:10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 l