

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Bosch CS7000iLW 12 M/MS	Reg. No.	011-1W0150
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Bosch CS7000iLW 12 M/MS		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.39 kg		

Model: Compress7000iLW12M

Configure model

Model name	Compress7000iLW12M
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	7.81 kW	9.81 kW
El input	1.79 kW	3.45 kW
COP	4.36	2.84

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	213 %	158 %
Prated	11.00 kW	10.00 kW
SCOP	5.32	4.08
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.27 kW
COP Tj = -7°C	4.19	3.12
Pdh Tj = +2°C	6.02 kW	5.55 kW
COP Tj = +2°C	5.51	4.13
Pdh Tj = +7°C	3.80 kW	3.65 kW
COP Tj = +7°C	5.99	4.77
Pdh Tj = 12°C	2.64 kW	2.77 kW
COP Tj = 12°C	6.21	4.95
Pdh Tj = Tbiv	10.50 kW	9.81 kW
COP Tj = Tbiv	3.86	2.84

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.30 kW	9.80 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	3.97	2.64
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	62 °C	62 °C
Poff	0 W	0 W
PTO	18 W	18 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4269 kWh	5231 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	93 %
COP	2.33
Heating up time	02:42 h:min
Standby power input	68.5 W
Reference hot water temperature	54.9 °C
Mixed water at 40°C	281 l

Model: Compress7000iLW12MS

Configure model	
Model name	Compress7000iLW12MS
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.81 kW	9.81 kW
El input	1.79 kW	3.45 kW
COP	4.36	2.84

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	213 %	158 %
Prated	11.00 kW	10.00 kW
SCOP	5.32	4.08
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.27 kW
COP Tj = -7°C	4.19	3.12
Pdh Tj = +2°C	6.02 kW	5.55 kW
COP Tj = +2°C	5.51	4.13
Pdh Tj = +7°C	3.80 kW	3.65 kW
COP Tj = +7°C	5.99	4.77
Pdh Tj = 12°C	2.64 kW	2.77 kW
COP Tj = 12°C	6.21	4.95
Pdh Tj = Tbiv	10.50 kW	9.81 kW
COP Tj = Tbiv	3.86	2.84

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.30 kW	9.80 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	3.97	2.64
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	62 °C	62 °C
Poff	0 W	0 W
PTO	18 W	18 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4269 kWh	5231 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	93 %
COP	2.33
Heating up time	02:42 h:min
Standby power input	68.5 W
Reference hot water temperature	54.9 °C
Mixed water at 40°C	281 l